ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY

Premises SHELL FENSTANTON Person Seen WAYNE

Address A14 EASTBOUND FENSTANTON, CAMBS

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:
As a result of the inspection of your premises your attention is drawn to the following matters:

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N Satisfactory Y/N

Notes: SITE REGISTER IN PLACE

b) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES

Inspected Y/N Satisfactory Y/N

Notes: 05/2012 DUE 15

c) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N Satisfactory Y/N

Notes: SITE REGISTER AS ABOVE

d) STAFF COMPETENCE & TRAINING

No of Staff 6 No Questioned 1

Inspected Y/N Satisfactory Y/N

Notes:

e) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N Satisfactory Y/N

Notes: FADED BUT LEGIBLE.

Does the site have stage II vapour recovery? Y/N

Notes: YES.

f) SITE MANAGEMENT & OTHER COMMENTS

YES ALL OK Satisfactory Y/N

Notes:

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes: SHELL POLICY

Signed [signature] Tel /Email alan.ewer@cambridgeshire.gov.uk 01954 284621

Received by [signature] Date/Time 8/10/2014

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.