



Exova Catalyst, Unit 11, Aspen Close, Swindon, SN2 8AJ
T: 0800 328 1821 (or + 44 161 432 3286 from overseas)
E: stuart.davidson@cat-env.com
Your Exova Catalyst Contact: Stuart Davidson (07957 554 956)

Stack Emissions Testing Report Commissioned by
PCME Ltd

Installation Name & Address

Clark-Drain Ltd
Station Road
Yaxley
Peterborough
Cambridgeshire
PE7 3EQ

EPR Permit: A12/92; Variation: PPC 20/09

Stack Reference
Galvanising Plant

Dates of the Monitoring Campaign
27th January 2015

Job Reference Number
CSW-1625

Report Written by
Wayne Gurbuz Technician MCERTS Level 1 MM 13 1252 None

Report Approved by
Rob Hester Team Leader MCERTS Level 2 MM 06 766 TE1 TE2 TE3 TE4

Report Date
17th February 2015

Version
Version 1

Signature of Report Approver



CONTENTS

TITLE PAGE

CONTENTS 2

EXECUTIVE SUMMARY

Monitoring Objectives 3

Monitoring Results 4

Monitoring Dates & Times 5

Process Details 6

Monitoring & Analytical Methods 7

Summary of Method Deviations 7

Sampling Location 8

Plant Photos / Sample Points 9

APPENDIX 1 - Monitoring Personnel & List of Equipment

APPENDIX 2 - Raw Data, Sampling Equations & Charts

APPENDIX 3 - PCME Meter

Opinions and interpretations expressed herein are outside the scope of Exova Catalyst's ISO 17025 accreditation.

This test report shall not be reproduced, except in full, without the written approval of Exova Catalyst.

Executive Summary

(Page 1 of 7)

MONITORING OBJECTIVES

Clark-Drain Ltd , Yaxley

Galvanising Plant

27th January 2015

Overall Aim of the Monitoring Campaign

Exova Catalyst, in partnership with PCME Ltd, were commissioned to carry out stack emissions testing on the Galvanising Plant by Clark-Drain Ltd at Yaxley.

The aim of the monitoring campaign was to demonstrate compliance with a set of emission limit values (ELVs) as specified in the Site's Permit.

Special Requirements

Record the PCME Meter readings. These can be found on the back page of this Report.

Target Parameters

Total Particulate Matter, Lead, Hydrogen Chloride

Executive Summary

(Page 2 of 7)

MONITORING RESULTS

Clark-Drain Ltd , Yaxley

Galvanising Plant

27th January 2015

where MU = Measurement Uncertainty associated with the Result

Concentration					Mass Emission			
Parameter	Units	Result	MU +/-	Limit	Units	Result	MU +/-	Limit
Total Particulate Matter	¹ mg/m ³	5.0	0.33	15	g/hr	89.8	8.8	-
Lead	¹ mg/m ³	0.0084	0.0022	-	g/hr	0.15	0.04	-
Hydrogen Chloride	¹ mg/m ³	0.11	0.016	-	g/hr	2.1	0.33	-
Water Vapour	% v/v	1.1	0.06					
Stack Gas Temperature	°C	24						
Stack Gas Velocity	m/s	13.2	0.74					
Volumetric Flow Rate (ACTUAL)	m ³ /hr	19323	1395					
Volumetric Flow Rate (REF)	¹ m ³ /hr	18012	1300					

NOTE: VOLUMETRIC FLOW RATE DATA TAKEN FROM THE PRELIMINARY VELOCITY TRAVERSE.



Executive Summary
(Page 3 of 7)

MONITORING DATE(S) & TIMES

Clark-Drain Ltd , Yaxley
Galvanising Plant
27th January 2015

Parameter		Units	Concentration	Units	Mass Emission	Sampling Date(s)	Sampling Times	Duration mins
Total Particulate Matter	R1	mg/m ³	4.4	g/hr	79.6	27/01/2015	11:00 - 12:00	60
Total Particulate Matter	R2	mg/m ³	6.9	g/hr	124	27/01/2015	13:30 - 14:30	60
Total Particulate Matter	R3	mg/m ³	3.6	g/hr	65.7	27/01/2015	14:41 - 15:41	60
Lead	R1	mg/m ³	0.01	g/hr	0.15	27/01/2015	12:19 - 13:19	60
Hydrogen Chloride	R1	mg/m ³	0.11	g/hr	2.1	27/01/2015	14:41 - 15:41	60
Velocity & Volumetric Flow Rate	R1					27/01/2015	10:00 - 10:10	

All results are expressed at the respective reference conditions.



Executive Summary
(Page 4 of 7)

PROCESS DETAILS

Clark-Drain Ltd , Yaxley
Galvanising Plant
27th January 2015

Standard Operating Conditions

Parameter	Value
Process Status	Normal
Capacity (of 100%) and Tonnes / Hour	100% Throughput
Continuous or Batch Process	Batch
Feedstock (if applicable)	Steel Components
Abatement System	Wet Scrubber
Abatement System Running Status	On - Normal
Fuel	N/A
Plume Appearance	No Plume Visible

Executive Summary

(Page 5 of 7)

MONITORING & ANALYTICAL METHODS

Clark-Drain Ltd , Yaxley

Galvanising Plant

27th January 2015

Parameter	Monitoring				Analysis				MCERTS Testing	LOD (Average)
	Standard	Technical Procedure	ISO 17025 Testing	Testing Lab	Analytical Procedure	Analytical Technique	ISO 17025 Analysis	Analysis Lab		
Total Particulate Matter	EN 13284-1	CAT-TP-01	Yes	CAT	CAT-TP-03	Gravimetric	Yes	CAT	Yes	0.1 mg/m ³
Lead	EN 14385	CAT-TP-06	Yes	CAT	M31	ICP-MS	Yes	RPS	Yes	0.0004 mg/m ³
Hydrogen Chloride	EN 1911	CAT-TP-11	Yes	CAT	CAT-AP-01	IC	Yes	CAT	Yes	0.016 mg/m ³
Water Vapour	EN 14790	CAT-TP-05	Yes	CAT	CAT-TP-05	Gravimetric	Yes	CAT	Yes	0.1 % v/v
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41	Yes	CAT	Pitot Tube and Thermocouple				Yes	1.8 m/s

ANALYSIS LABORATORIES

(with short name reference as appears in the table above)

Exova Catalyst (CAT)	ISO 17025 Accreditation Number: 4279
RPS Laboratories Ltd (RPS)	ISO 17025 Accreditation Number: 0605

SUMMARY OF SAMPLING DEVIATIONS

Parameter	Run	Deviation
Total Particulate Matter, Lead	All	One out of two sampling lines was used due to sampling location restrictions, however the number of sample points used on the available line were increased to meet the requirements of the Standard.

Executive Summary

(Page 6 of 7)

SUITABILITY OF SAMPLING LOCATION

Duct Characteristics

Parameter	Units	Value
Type	-	Circular
Depth	m	0.72
Width	m	-
Area	m ²	0.41
Port Depth	cm	9
Orientation of Duct	-	Vertical
Sample Port Size	-	4" BSP

Location of Sampling Platform

General Platform Information	Value
Permanent / Temporary Platform	Permanent
Inside / Outside	Outside

Platform Details

EA Technical Guidance Note M1 / EN 15259 Platform Requirements	Value
Sufficient working area to manipulate probe and operate the measuring instruments	Yes
Platform has 2 levels of handrails (approx. 0.5m & 1.0m high)	Yes
Platform has vertical base boards (approx. 0.25m high)	Yes
Platform has chains / self closing gates at top of ladders	No
There are no obstructions present which hamper insertion of sampling equipment	Yes
Safe Access Available	Yes
Easy Access Available	Yes

Sampling Location / Platform Improvement Recommendations

All platforms should be designed in accordance with the requirements in the Environment Agency's Technical Guidance Note M1 and EN 15259.

EN 15259 Homogeneity Test Requirements

There is no requirement to perform a EN 15259 Homogeneity Test on this Stack.

Sampling Plane Validation Criteria (from EN 15259)

Criteria in EN 15259	Units	Traverse 1		Required	Compliant
Lowest Differential Pressure	Pa	127.5		> 5 Pa	Yes
Mean Velocity	m/s	13.18		-	-
Lowest Gas Velocity	m/s	12.39		-	-
Highest Gas Velocity	m/s	14.58		-	-
Ratio of Above	: 1	1.18		< 3 : 1	Yes
Maximum Angle of Swirl	°	3		< 15°	Yes
No Local Negative Flow	-	Yes		-	Yes

Executive Summary

(Page 7 of 7)

PLANT PHOTOS

Photo 1




Photo 2




Photo 3



Photo 4



SAMPLE POINTS



where

○ = isokinetic point sampled at

● = isokinetic point not sampled at

APPENDICES

APPENDIX CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Personnel, List of Equipment & Methods and Technical Procedures Used

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - PCME Meter

STACK EMISSIONS MONITORING PERSONNEL

Position	Name	MCERTS Accreditation	MCERTS Number	Technical Endorsements
Team Leader	Robert Hester	MCERTS Level 2	MM 06 766	TE1 TE2 TE3 TE4
Technician	Wayne Gurbuz	MCERTS Level 1	MM 13 1252	None

LIST OF EQUIPMENT

Extractive Sampling		Instrumental Analysers		Miscellaneous Items	
Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.	Equipment Type	Equipment I.D.
Control Box DGM (1)	CAT 7.8	Horiba PG-250	-	Digital Manometer (1)	-
Control Box DGM (2)	-	Horiba PG-250	-	Digital Manometer (2)	-
Box Thermocouples (1)	CAT 3.21	Servomex 4900	-	Digital Temperature Meter	CAT 3.23
Box Thermocouples (2)	-	Eco Physics CLD 822Mh	-	Stopwatch	CAT 14.53
Umbilical (1)	CAT 3.21	ABB AO2020-URAS26	-	Barometer	CAT 13.19
Umbilical (2)	-	Servomex 5200MP	-	Stack Thermocouple (1)	CAT 4.581
Oven Box (1)	CAT 12.96	JCT JCC P1 Cooler	-	Stack Thermocouple (2)	-
Oven Box (2)	-	Gasmet DX4000	-	Stack Thermocouple (3)	-
Heated Probe (1)	CAT 5.99	Gasmet Sampling System	-	1m Heated Line (1)	-
Heated Probe (2)	-	Bernath 3006 FID	-	1m Heated Line (2)	-
Heated Probe (3)	-	M&C PSS	-	1m Heated Line (3)	-
S-Pitot (1)	CAT 215.61	Mass Flow Controller (1)	-	5m Heated Line (1)	-
S-Pitot (2)	-	Mass Flow Controller (2)	-	15m Heated Line (1)	-
L-Pitot	-	Mass View (1)	-	20m Heated Line (1)	-
500g Check Weight	CAT 17.5	Mass View (2)	-	20m Heated Line (2)	-
1Kg Check Weight	CAT 17.5	Easylogger EN-EL-12 Bit	-	Dual Channel Heater Controller	-
Last Impinger Arm	CAT 4.891	Easylogger EN-EL-12 Bit	-	Single Channel Heater Controller	-
Callipers	CAT 23.15	Bioaerosols Temperature Logger	-	Laboratory Balance	CAT 1.18 / 1.18a
Tubes Kit Thermocouple	-	Electronic Refrigerator	-	Tape Measure	CAT 16.17

METHODS & TECHNICAL PROCEDURES USED

Parameter	Standard	Technical Procedure
Total Particulate Matter	EN 13284-1	CAT-TP-01
Lead	EN 14385	CAT-TP-06
Hydrogen Chloride	EN 1911	CAT-TP-11
Water Vapour	EN 14790	CAT-TP-05
Velocity & Vol. Flow Rate	EN 16911-1 (MID)	CAT-TP-41

PRELIMINARY STACK SURVEY: CALCULATIONS

General Stack Details

Stack Details (from Traverse)	Units	Value
Stack Diameter / Depth, D	m	0.7
Stack Width, W	m	-
Stack Area, A	m ²	0.41
Average Stack Gas Temperature, T _a	°C	24
Average Stack Gas Pressure	mmH ₂ O	14.8
Average Stack Static Pressure, P _{static}	kPa	0.23
Average Barometric Pressure, P _b	kPa	102.5
Average Pitot Tube Calibration Coefficient, C _p	-	0.85

Stack Gas Composition & Molecular Weights

Component	Conc ppm	Conc Dry % v/v	Conc Wet % v/v	Volume Fraction r	Molar Mass M	Density kg/m ³ p	Conc kg/m ³ p _i
CO ₂ (Estimated)	-	0.06	0.06	0.0006	44.01	1.9635	0.00118
O ₂ (Estimated)	-	20.8	20.57	0.208	32	1.4277	0.29696
N ₂	-	79.14	78.27	0.7914	28.01	1.2498	0.98913
Moisture (H ₂ O)	-	-	1.10	0.0110	18.02	0.8037	0.00887

Where: $p = M / 22.41$
 $p_i = r \times p$

Calculation of Stack Gas Densities

Determinand	Units	Result
Dry Density (STP), P _{STD}	kg/m ³	1.287
Wet Density (STP), P _{STW}	kg/m ³	1.282
Dry Density (Actual), P _{Actual}	kg/m ³	1.2
Average Wet Density (Actual), P _{ActualW}	kg/m ³	1.195

Where: P_{STD} = sum of component concentrations, kg/m³ (not including water vapour)
 P_{STW} = sum of all wet concentrations / 100 x density, kg/m³ (including water vapour)
 $P_{Actual} = P_{STD} \times (T_{STP} / (P_{static} + P_b) / T_a)$
 $P_{ActualW}$ (at each sampling point) = $P_{STW} \times (T_s / P_s) \times (P_a / T_a)$

Calculation of Stack Gas Volumetric Flowrate, Q

Duct gas flow conditions	Units	Actual	REF ¹
Temperature	°C	24	0
Total Pressure	kPa	102.7	101.3
Moisture	%	1.10	1.10

Gas Volumetric Flowrate (from Traverse)	Units	Result
Gas Volumetric Flowrate (Actual)	m ³ /hr	19323
Gas Volumetric Flowrate (STP, Wet)	m ³ /hr	18012
Gas Volumetric Flowrate (STP, Dry)	m ³ /hr	17813
Gas Volumetric Flowrate REF ¹	m ³ /hr	18012

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID)
(1 of 1)

Parameter	Units	Value
Date of Survey	-	27/01/2015
Time of Survey	-	10:00 - 10:10
Atmospheric Pressure	kPa	102.5
Average Stack Static Pressure	Pa	230
Result of Pitot Stagnation Test	-	Pass
Are Water Droplets Present?	-	No
Device Used	S-Type Pitot with Liquid Incline Manometer	

Parameter	Units	Value
Initial Pitot Leak Check	-	Pass
Final Pitot Leak Check	-	Pass
Orientation of Duct	-	Vertical
Pitot Tube, C _p	-	0.85
Number of Lines Available	-	2
Number of Lines Used	-	1

Traverse Point	Depth m	ΔP	Sampling Line A - Cap Stuck				Sampling Line B				
			Temp °C	Wet Density kg/m³	Velocity m/s	Swirl °	ΔP mmH₂O	Temp °C	Wet Density kg/m³	Velocity m/s	Swirl °
STATIC (Units: Pa)							230.0				
Mean							14.8	24	1.195	13.18	
1	0.05						13	24	1.195	12.39	2
2	0.18						13.2	24	1.195	12.49	2
3	0.54						14.9	24	1.195	13.27	3
4	0.67						18	24	1.195	14.58	1

PRELIMINARY STACK SURVEY: VELOCITY TRAVERSE TO EN 16911-1 (MID) - MEASUREMENT UNCERTAINTY

(1 of 1)

Performance characteristics (Uncertainty Components)	Uncertainty	Value	Units
Standard Uncertainty on the coefficient of the Pitot Tube	$u(k)$	0.005	-
Standard Uncertainty associated with the mean local dynamic pressures	$u(\Delta p_i)$	1.618	Pa
- Resolution	$u(res)$	0.52154	
- Calibration	$u(cal)$	0	
- Drift	$u(drift)$	1.096	
- Lack of Fit	$u(fit)$	0	
- Overall corrections to dynamic measurements	$u(C_f)$	1.618	
Standard uncertainty associated with the molar mass of the gas	$u(M)$	0.00003	-
- $\phi_{O_2,w}$	-	20.570	
- $\phi_{CO_2,w}$	-	0.059	
- Oxygen, dry	$u(\phi_{O_2,d})$	0.637	
- Carbon Dioxide, dry	$u(\phi_{CO_2,d})$	0.002	
- Water Vapour	$u(\phi_{H_2O})$	0.056	
- Oxygen, wet	$u(\phi_{O_2,w})$	0.63	
- Carbon Dioxide, wet	$u(\phi_{CO_2,w})$	0.002	
Standard uncertainty associated with the stack temperature	$u(T_c)$	1.515	K
Standard uncertainty associated with the absolute pressure in the duct	$u(p_c)$	175.699	Pa
- Atmospheric Pressure	$u(p_{atm})$	175.692	
- Static Pressure	$u(p_{stat})$	1.618	
Standard uncertainty associated with the density in the duct	$u(\rho)$	0.00643	-
Standard uncertainty associated with the local velocities	$u(v_i)$	0.735	Pa
Standard uncertainty associated with the mean velocity	$u(\bar{v})$	0.378	m/s
Standard uncertainty associated with the mean velocity (95% Confidence)	$U_c(v)$	0.741	m/s
Standard uncertainty associated with the mean velocity (95% Confidence), relative	$U_{c,rel}(v)$	5.62	%
Standard uncertainty associated with the volume flow rate (95% Confidence)	$U_c(qV,w)$	1394.9	m ³ /hr
- $u^2(a)/a^2$	-	0.00053	
- $u^2(qV,w)/q^2V,w$	-	0.00136	
- $u^2(qV,w)$	-	506481	
- $u(qV,w)$	-	711.7	
Standard uncertainty associated with the volume flow rate (95% Confidence), relative	$U_{c,rel}(qV,w)$	7.22	%

TOTAL PARTICULATE MATTER: RESULTS SUMMARY

Clark-Drain Ltd , Yaxley
Galvanising Plant

Sample Runs

Parameter	Units	Run 1	Run 2	Run 3		Mean
Concentration	mg/m ³	4.4	6.9	3.6		5.0
Uncertainty	±mg/m ³	0.3	0.42	0.27		0.33
Mass Emission	g/hr	79.6	124	65.7		89.8
Uncertainty	±g/hr	7.8	11.7	6.8		8.8

Parameter	Units	Run 1	Run 2	Run 3		Mean
Water Vapour	% v/v	0.73	1.2	0.90		0.95
Uncertainty	±% v/v	0.04	0.07	0.05		0.05

Blank Runs

Parameter	Units	Blank 1		Maximum
Concentration	mg/m ³	0.10		0.10

NOTE: Where the Balance Uncertainty / Limit of Detection is higher than the Blank concentration, the Balance Uncertainty / Limit of Detection concentration has been reported.

General Sampling Information

Parameter	Value	
Standard	EN 13284-1	
Technical Procedure	CAT-TP-01	
Probe Material	Titanium	
Filter Housing Material	Titanium	
Positioning of Filter	In Stack	
Filter Size and Material	47mm Glass Fibre	
Number of Sampling Lines Used	1 / 2	FORMAT: Number Used / Number Required
Number of Sampling Points Used	4 / 4	FORMAT: Number Used / Number Required
Sample Point I.D.'s	B1, B2, B3, B4	

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

TOTAL PARTICULATE MATTER: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	Run 2	Run 3	
Absolute pressure of stack gas, P_s					
Barometric pressure, P_b	mmHg	768.8	768	768.8	
Stack static pressure, P_{static}	mmH ₂ O	23.5	23.5	23.5	
$P_s = (P_b + (P_{static} / 13.6))$	mmHg	770.5	769.7	770.5	
Volume of water vapour collected, V_{wstd}					
Total mass collected in impingers (liquid trap)	g	-0.3	6.4	5.8	
Total mass collected in impingers (silica trap)	g	7.9	4.6	3.7	
Total mass of liquid collected, V_{lc}	g	7.6	11	9.5	
$V_{wstd} = (0.001246)(V_{lc})$	m ³	0.0095	0.0137	0.0118	
Volume of gas metered dry, V_{mstd}					
Volume of gas sample through gas meter, V_m	m ³	1.2115	1.068	1.238	
Gas meter correction factor, Y_d	-	1.098	1.098	1.098	
Average dry gas meter temperature, T_m	°C	14.6	16.8	17.4	
Average pressure drop across orifice, ΔH	mmH ₂ O	50.4	44.6	54.1	
$V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)) / (T_m + 273)$	m ³	1.2832	1.1205	1.2992	
Moisture content, B_{wo} & R_{wv}					
$B_{wo} = V_{wstd} / (V_{mstd} + V_{wstd})$	m ³	0.0073	0.0121	0.009	
B_{wo} as a percentage	% v/v	0.73	1.21	0.9	
Reported Water Vapour, checked with Tables in EN 14790, R_{wv}	% v/v	0.73	1.21	0.9	
Volume of gas metered wet, V_{mstw}					
$V_{mstw} = (V_{mstd})(100/(100 - R_{wv}))$	m ³	1.2927	1.1342	1.311	
Volume of gas metered at Oxygen Reference Conditions, $V_{mstd@X\%O_2}$ & $V_{mstw@X\%O_2}$					
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	No	No	
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	N/A	N/A	
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	N/A	N/A	
% oxygen reference condition, REF%O ₂	% v/v	N/A	N/A	N/A	
O ₂ Reference Factor wet ($O_{2REFw} = (21 - REF\%O_2) / (21 - ACT\%O_{2w})$)	-	N/A	N/A	N/A	
O ₂ Reference Factor dry ($O_{2REFd} = (21 - REF\%O_2) / (21 - ACT\%O_{2d})$)	-	N/A	N/A	N/A	
$V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$	m ³	N/A	N/A	N/A	
$V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$	m ³	N/A	N/A	N/A	
Molecular weight of dry gas stream, M_d					
CO ₂ (Estimated)	% v/v	0.06	0.06	0.06	
O ₂ (Estimated)	% v/v	20.8	20.8	20.8	
Total	% v/v	20.86	20.86	20.86	
N ₂	% v/v	79.14	79.14	79.14	
$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	g/gmol	28.84	28.84	28.84	
Molecular weight of stack gas (wet), M_s					
$M_s = M_d(1 - (R_{wv}/100)) + 18(R_{wv}/100)$	g/gmol	28.76	28.71	28.74	
Velocity of stack gas, V_s					
Pitot tube velocity constant, K_p	-	34.97	34.97	34.97	
Velocity pressure coefficient, C_p	-	0.85	0.85	0.85	
Average of velocity heads, ΔP_{avg}	mmH ₂ O	14.13	12.45	15.18	
Average square root of velocity heads, $\sqrt{\Delta P}$	$\sqrt{\text{mmH}_2\text{O}}$	3.76	3.53	3.9	
Average stack gas temperature, T_s	°C	30.9	31.6	34.5	
$V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (V(M_s)(P_s))$	m/s	13.08	12.3	13.65	
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO_2}), Dry@O_{2REF} (Q_{stdO_2})					
Area of stack, A_s	m ²	0.41	0.41	0.41	
$Q_a = (60)(A_s)(V_s)$	m ³ /min	319.7	300.9	333.4	
Conversion factor (K/mm.Hg), C_f	-	0.3592	0.3592	0.3592	
$Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$	m ³ /min	291.1	273.1	300.1	
$Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273)$	m ³ /min	289	269.8	297.4	
$Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$	m ³ /min	N/A	N/A	N/A	
$Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273) / (O_{2REFd})$	m ³ /min	N/A	N/A	N/A	
Percent isokinetic, %I					
Nozzle diameter, D_n	mm	6.04	6.04	6.04	
Nozzle area, A_n	mm ²	28.69	28.69	28.69	
Total sampling time, q	min	60	60	60	
$\%I = (4.6398E^6)(T_s + 273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{wv}/100))$	%	105	98.3	103.3	

TOTAL PARTICULATE MATTER: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1	Run 2	Run 3	
Sampling Times	-	11:00 - 12:00	13:30 - 14:30	14:41 - 15:41	
Sampling Dates	-	27/01/2015	27/01/2015	27/01/2015	
Sampling Device	-	ISO	ISO	ISO	
Volume Sampled (REF)	m ³	1.2927	1.1342	1.311	
Filter I.D. Number	-	47-23815	47-23816	47-23817	
Start Filter Mass	g	0.1519	0.14974	0.15084	
End Filter Mass	g	0.15724	0.15712	0.15293	
Total Mass on Filter	g	0.00534	0.00738	0.00209	
Probe Rinse I.D. Number	-	PR-47-23815	PR-47-23816	PR-47-23817	
Start Probe Rinse Mass	g	3.09671	2.95757	3.05832	
End Probe Rinse Mass	g	3.09708	2.958	3.06101	
Total Mass in Probe Rinse	g	0.00037	0.00043	0.00269	
Total Mass Collected	mg	5.71	7.81	4.78	
Calculated Concentration	mg/m ³	4.42	6.89	3.65	
Balance Uncertainty / LOD	mg/m ³	0.1	0.11	0.1	

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1	
Blank Dates	-	27/01/2015	
Average Volume Sampled (REF)	m ³	1.2460	
Filter I.D. Number	-	47-23807	
Start Filter Mass	g	0.15306	
End Filter Mass	g	0.15311	
Total Mass on Filter	g	0.00005	
Probe Rinse I.D. Number	-	PR-47-23807	
Start Probe Rinse Mass	g	2.92795	
End Probe Rinse Mass	g	2.92801	
Total Mass in Probe Rinse	g	0.00006	
Total Mass Collected	mg	0.11	
Calculated Concentration	mg/m ³	0.09	
Balance Uncertainty / LOD	mg/m ³	0.10	

TOTAL PARTICULATE MATTER: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1	Run 2	Run 3	
Mean Sampling Rate	l/min	22.17	19.54	22.66	
Pre-Sampling Leak Rate	l/min	0.08	0.3	0.35	
Post-Sampling Leak Rate	l/min	0.07	0.3	0.18	
Allowable Leak Rate	l/min	0.44	0.39	0.45	
Leak Test Acceptable	-	Yes	Yes	Yes	
Water Droplets	Units	Run 1	Run 2	Run 3	
Are Water Droplets Present	-	No	No	No	
MU (Concurrent Water Vapour)	Units	Run 1	Run 2	Run 3	
Measurement Uncertainty (MU)	%	6	5.6	5.6	
Allowable MU	%	20	20	20	
MU Acceptable	%	Yes	Yes	Yes	
Silica Gel (Concurrent Water Vapour)	Units	Run 1	Run 2	Run 3	
Less than 50% Faded	%	Yes	Yes	Yes	
Isokinetic Criterion Compliance	Units	Run 1	Run 2	Run 3	
Isokinetic Variation	%	105	98.3	103.3	
Allowable Isokinetic Range	%	95 - 115	95 - 115	95 - 115	
Isokineticity Acceptable	-	Yes	Yes	Yes	
Weighing Uncertainty Criteria	Units	Run 1	Run 2	Run 3	
Overall Weighing Uncertainty	± mg	0.24	0.24	0.24	
Overall Weighing Uncertainty	± mg/m ³	0.19	0.21	0.18	
ELV [Daily ELV for IED]	mg/m ³	15	15	15	
Allowable Weighing Uncertainty	mg/m ³	0.75	0.75	0.75	
Weighing Uncertainty Acceptable	-	Yes	Yes	Yes	
Filter Temperatures	Units	Run 1	Run 2	Run 3	
Pre-Conditioning Temperature	°C	180	180	180	
Post-Conditioning Temperature	°C	160	160	160	
Maximum Filter Temperature	°C	31	32	35	
Test Conditions	Units	Run 1	Run 2	Run 3	
Ambient Temperature Recorded?	-	Yes	Yes	Yes	

TOTAL PARTICULATE MATTER: QUALITY ASSURANCE
(PAGE 2 OF 2)

Blank Runs

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	20	
Pre-Sampling Leak Rate	l/min	0.1	
Post-Sampling Leak Rate	l/min	0.11	
Allowable Leak Rate	l/min	0.4	
Leak Test Acceptable	-	Yes	

Validity of Blank vs ELV	Units	Blank 1	
Allowable Blank	mg/m ³	1.5	
Blank Acceptable	-	Yes	

Acetone / Water Rinse Blank	Units	Blank
Acetone / Water Rinse Value	mg/l	2.7
Allowable Blank	mg/l	10
Blank Acceptable	-	Yes

Method Deviations

Nature of Deviation	Run Number			
	1	2	3	
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)				
One out of two sampling lines was used due to sampling location restrictions, however the number of sample points used on the available line were increased to meet the requirements of the Standard.	x	x	x	

TOTAL PARTICULATE MATTER: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value					Standard uncertainty					
	Symbol	Run 1	Run 2	Run 3		Symbol	Units	Run 1	Run 2	Run 3	
Sampled Volume (Actual)	V _m	1.2115	1.068	1.238		uV _m	m ³	0.0242	0.0214	0.0248	
Sampled Gas Temperature	T _m	287.6	289.8	290.4		uT _m	K	2	2	2	
Sampled Gas Pressure	p _m	102.7	102.6	102.7		up _m	kPa	0.5	0.5	0.5	
Sampled Gas Humidity	H _m	0.0000	0.0000	0.0000		uH _m	% v/v	1	1	1	
Leak	L	0.32	1.54	0.79		uL	%	-	-	-	
Mass of Particulate	m	5.71	7.81	4.78		um	mg	0.13	0.13	0.13	
Uncollected Mass	UCM	0.11	0.11	0.11		uUCM	mg	-	-	-	

Measured Quantities	Uncertainty as a Percentage					Requirement of Standard
	Units	Run 1	Run 2	Run 3		
Sampled Volume (Actual)	%	2	2	2		≤2%
Sampled Gas Temperature	%	0.7	0.69	0.69		≤1%
Sampled Gas Pressure	%	0.49	0.49	0.49		≤1%
Sampled Gas Humidity	%	1	1	1		≤1%
Leak	%	0.32	1.54	0.79		≤2%
Mass of Particulate	%	0.67	0.76	0.66		<5% of ELV
Uncollected Mass	%	-	-	-		-

Measured Quantities	Uncertainty in Measurement Units					Sensitivity Coefficient			
	Symbol	Units	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3	
Sampled Volume (STP)	V _m	m ³	1.2832	1.1205	1.2992	3.44	6.15	2.81	
Leak	L	mg/m ³	0.008	0.061	0.017	1	1	1	
Mass of Particulate	L _r	mg	5.71	7.81	4.78	0.77	0.88	0.76	
Uncollected Mass	UCM	mg	0.06	0.06	0.06	0.77	0.88	0.76	

Measured Quantities	Uncertainty in Result				
	Units	Run 1	Run 2	Run 3	
Sampled Volume (STP)	mg/m ³	0.102	0.159	0.084	
Leak	mg/m ³	0.0081	0.0611	0.0167	
Mass of Particulate	mg/m ³	0.1006	0.1146	0.0992	
Uncollected Mass	mg/m ³	0.0491	0.0560	0.0484	

Measured Quantities	Oxygen Correction Part of MU Budget				
	Units	Run 1	Run 2	Run 3	
O ₂ Correction Factor	-	N/A	N/A	N/A	
Stack Gas O ₂ Content	% v/v	N/A	N/A	N/A	
MU for O ₂ Correction	-	N/A	N/A	N/A	
Overall MU For O ₂ Measurement	%	N/A	N/A	N/A	

Parameter	Units	Run 1	Run 2	Run 3	
Combined uncertainty	mg/m ³	0.15	0.21	0.14	
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.3	0.42	0.27	
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A	N/A	N/A	
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.3	0.42	0.27	
Reported Uncertainty	mg/m ³	0.3	0.42	0.27	
Expanded uncertainty (95% confidence), without Oxygen Correction	%	6.7	6.1	7.5	
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A	N/A	N/A	
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	6.7	6.1	7.5	
Reported Uncertainty	%	6.7	6.1	7.5	

LEAD: RESULTS SUMMARY

Clark-Drain Ltd , Yaxley
Galvanising Plant

Sample Runs

Parameter	Units	Run 1		Mean
Concentration	mg/m ³	0.0084		0.0084
Uncertainty	±mg/m ³	0.0022		0.0022
Mass Emission	g/hr	0.15		0.15
Uncertainty	±g/hr	0.04		0.04

Parameter	Units	Run 1		Mean
Water Vapour	% v/v	1.5		1.5
Uncertainty	±% v/v	0.07		0.07

Blank Runs

Parameter	Units	Blank 1		Maximum
Concentration	mg/m ³	0.0012		0.0012

General Sampling Information

Parameter	Value
Standard	EN 14385
Technical Procedure	CAT-TP-06
Name of Analytical Laboratory	RPS
Analytical Laboratory's Procedure	M31
ISO 17025 Accredited Analysis?	Yes
Date of Sample Analysis	10/02/2015
Probe Material	Titanium
Filter Housing Material	Borosilicate Glass
Impinger Material	Borosilicate Glass
Absorption Solution	Nitric Peroxide
Positioning of Filter	Out Stack
Filter Size and Material	47mm Quartz Fibre
Number of Sampling Lines Used	1 / 2
Number of Sampling Points Used	4 / 4
Sample Point I.D.'s	B1, B2, B3, B4

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

LEAD: ISOKINETIC SAMPLING CALCULATIONS

Test	Units	Run 1	
Absolute pressure of stack gas, P_s			
Barometric pressure, P_b	mmHg	765	
Stack static pressure, P_{static}	mmH ₂ O	23.5	
$P_s = (P_b + (P_{static} / 13.6))$	mmHg	766.7	
Volume of water vapour collected, V_{wstd}			
Total mass collected in impingers (liquid trap)	g	6	
Total mass collected in impingers (silica trap)	g	10	
Total mass of liquid collected, V_{lc}	g	16	
$V_{wstd} = (0.001246)(V_{lc})$	m ³	0.0199	
Volume of gas metered dry, V_{mstd}			
Volume of gas sample through gas meter, V_m	m ³	1.2865	
Gas meter correction factor, Y_d	-	1.098	
Average dry gas meter temperature, T_m	°C	16.5	
Average pressure drop across orifice, ΔH	mmH ₂ O	52.6	
$V_{mstd} = ((0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)) / (T_m + 273)$	m ³	1.3478	
Moisture content, B_{wo} & R_{wv}			
$B_{wo} = V_{wstd} / (V_{mstd} + V_{wstd})$	m ³	0.0146	
B_{wo} as a percentage	% v/v	1.46	
Reported Water Vapour, checked with Tables in EN 14790, R_{wv}	% v/v	1.46	
Volume of gas metered wet, V_{mstw}			
$V_{mstw} = (V_{mstd})(100/(100 - R_{wv}))$	m ³	1.3677	
Volume of gas metered at Oxygen Reference Conditions, $V_{mstd@X\%O_2}$ & $V_{mstw@X\%O_2}$			
IED & Incinerates Hazardous Material? (Yes = no positive O ₂ correction)	-	No	
% wet oxygen measured in gas stream, ACT%O _{2w}	% v/v	N/A	
% dry oxygen measured in gas stream, ACT%O _{2d}	% v/v	N/A	
% oxygen reference condition, REF%O ₂	% v/v	N/A	
O ₂ Reference Factor wet ($O_{2REFw} = (21 - REF\%O_2) / (21 - ACT\%O_{2w})$)	-	N/A	
O ₂ Reference Factor dry ($O_{2REFd} = (21 - REF\%O_2) / (21 - ACT\%O_{2d})$)	-	N/A	
$V_{mstw@X\%oxygen} = (V_{mstw}) / (O_{2REFw})$	m ³	N/A	
$V_{mstd@X\%oxygen} = (V_{mstd}) / (O_{2REFd})$	m ³	N/A	
Molecular weight of dry gas stream, M_d			
CO ₂ (Estimated)	% v/v	0.06	
O ₂ (Estimated)	% v/v	20.8	
Total	% v/v	20.86	
N ₂	% v/v	79.14	
$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	g/gmol	28.84	
Molecular weight of stack gas (wet), M_s			
$M_s = M_d(1 - (R_{wv}/100)) + 18(R_{wv}/100)$	g/gmol	28.68	
Velocity of stack gas, V_s			
Pitot tube velocity constant, K_p	-	34.97	
Velocity pressure coefficient, C_p	-	0.85	
Average of velocity heads, ΔP_{avg}	mmH ₂ O	14.73	
Average square root of velocity heads, $\sqrt{\Delta P}$	$\sqrt{\text{mmH}_2\text{O}}$	3.84	
Average stack gas temperature, T_s	°C	32.1	
$V_s = ((K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})) / (\sqrt{M_s}(P_s))$	m/s	13.43	
Total flow of stack gas: Actual (Q_a), Wet (Q_{stw}), Dry (Q_{std}), Wet@O_{2REF} (Q_{stwO_2}), Dry@O_{2REF} (Q_{stdO_2})			
Area of stack, A_s	m ²	0.41	
$Q_a = (60)(A_s)(V_s)$	m ³ /min	328.2	
Conversion factor (K/mm.Hg), C_f	-	0.3592	
$Q_{stw} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273)$	m ³ /min	296.3	
$Q_{std} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273)$	m ³ /min	292	
$Q_{stwO_2} = ((Q_a)(P_s)(C_f)) / ((T_s) + 273) / (O_{2REFw})$	m ³ /min	N/A	
$Q_{stdO_2} = ((Q_a)(P_s)(C_f)(1 - (R_{wv}/100))) / ((T_s) + 273) / (O_{2REFd})$	m ³ /min	N/A	
Percent isokinetic, %I			
Nozzle diameter, D_n	mm	6.04	
Nozzle area, A_n	mm ²	28.69	
Total sampling time, q	min	60	
$\%I = (4.6398E^6)(T_s + 273)(V_{mstd}) / (P_s)(V_s)(A_n)(q)(1 - (R_{wv}/100))$	%	109.2	

LEAD: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1	
Sampling Times	-	12:19 - 13:19	
Sampling Dates	-	27/01/2015	
Sampling Device	-	ISO	
Volume Sampled (REF)	m ³	1.3677	
Mass on Filter / in Rinse	µg	9	
Mass in Front Impingers	µg	2.3	
Mass in Back Impinger	µg	0.16	
Total Mass Collected	µg	11.46	
Calculated Concentration	mg/m ³	0.0084	
Reported Concentration	mg/m ³	0.0084	

Where: ISO stands for Manual Isokinetic Sampling Train

Blank Runs

Parameter	Units	Blank 1	
Blank Dates	-	27/01/2015	
Average Volume Sampled (REF)	m ³	1.3677	
Mass on Filter / in Rinse	µg	1	
Mass in Front Impingers	µg	0.4	
Mass in Back Impinger	µg	0.28	
Total Mass Collected	µg	1.67	
Calculated Concentration	mg/m ³	0.0012	
Reported Concentration	mg/m ³	0.0012	

LEAD: QUALITY ASSURANCE

(PAGE 1 OF 2)

Sample Runs

Leak Test Results	Units	Run 1	
Mean Sampling Rate	l/min	23.54	
Pre-Sampling Leak Rate	l/min	0.25	
Post-Sampling Leak Rate	l/min	0.12	
Allowable Leak Rate	l/min	0.47	
Leak Test Acceptable	-	Yes	
Absorption Efficiency	Units	Run 1	
Absorption Efficiency	%	98.6	
Allowable Absorption Efficiency	%	90	
Absorption Efficiency Acceptable	-	Yes	
Detection Limit	Units	Run 1	
Detection Limit	µg/m ³	0.4	
Allowable Detection Limit	µg/m ³	5	
Detection Limit Acceptable	-	Yes	
Water Droplets	Units	Run 1	
Are Water Droplets Present	-	No	
MU (Concurrent Water Vapour)	Units	Run 1	
Measurement Uncertainty (MU)	%	5	
Allowable MU	%	20	
MU Acceptable	%	Yes	
Silica Gel (Concurrent Water Vapour)	Units	Run 1	
Less than 50% Faded	%	Yes	
Isokinetic Criterion Compliance	Units	Run 1	
Isokinetic Variation	%	109.2	
Allowable Isokinetic Range	%	95 - 115	
Isokineticity Acceptable	-	Yes	
Filter Temperatures	Units	Run 1	
Maximum Filter Temperature	°C	190	
Impingers Exit Temperature	Units	Run 1	
Maximum Temperature Recorded	°C	13	
Maximum Allowable Temperature	°C	30	
Exit Temperature Acceptable	-	Yes	
Test Conditions	Units	Run 1	
Ambient Temperature Recorded?	-	Yes	

LEAD: QUALITY ASSURANCE
(PAGE 2 OF 2)

Blank Runs

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	20	
Pre-Sampling Leak Rate	l/min	0.3	
Post-Sampling Leak Rate	l/min	0.28	
Allowable Leak Rate	l/min	0.4	
Leak Test Acceptable	-	Yes	

Validity of Blank vs ELV	Units	Blank 1	
Allowable Blank	mg/m ³	N/A	
Blank Acceptable	-	N/A	

Method Deviations

Nature of Deviation	Run Number	
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1	
One out of two sampling lines was used due to sampling location restrictions, however the number of sample points used on the available line were increased to meet the requirements of the Standard.	x	

LEAD: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value			Symbol	Standard uncertainty		
	Symbol	Run 1			Units	Run 1	
Sampled Volume (Actual)	V_m	1.2865		uV_m	m ³	0.0257	
Sampled Gas Temperature	T_m	289.5		uT_m	K	2	
Sampled Gas Pressure	p_m	102.2		up_m	kPa	0.5	
Sampled Gas Humidity	H_m	0		uH_m	% v/v	1	
Leak	L	0.51		uL	%	-	
Laboratory Result	L_r	13		uL_r	%	-	

Measured Quantities	Uncertainty as a Percentage			Requirement of Standard
	Units	Run 1		
Sampled Volume (Actual)	%	2		≤2%
Sampled Gas Temperature	%	0.69		≤1%
Sampled Gas Pressure	%	0.49		≤1%
Sampled Gas Humidity	%	1		≤1%
Leak	%	0.51		≤2%
Laboratory Result	%	13		No Requirement

Measured Quantities	Uncertainty in Measurement Units				Sensitivity Coefficient	
	Symbol	Units	Run 1		Run 1	
Sampled Volume (STP)	V_m	m ³	1.3478		0.01	
Leak	L	mg/m ³	0.00002		1	
Laboratory Result	L_r	mg/m ³	0.0011		1	

Measured Quantities	Uncertainty in Result		
	Units	Run 1	
Sampled Volume (STP)	mg/m ³	0.0002	
Leak	mg/m ³	0.00002	
Laboratory Result	mg/m ³	0.0011	

Measured Quantities	Oxygen Correction Part of MU Budget		
	Units	Run 1	
O ₂ Correction Factor	-	N/A	
Stack Gas O ₂ Content	% v/v	N/A	
MU for O ₂ Correction	%	N/A	
Overall MU For O ₂ Measurement	%	N/A	

Parameter	Units	Run 1	
Combined uncertainty	mg/m ³	0.0011	
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.0022	
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A	
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.0022	
Reported Uncertainty	mg/m ³	0.0022	
Expanded uncertainty (95% confidence), without Oxygen Correction	%	25.9	
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A	
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	25.9	
Reported Uncertainty	%	25.9	

HYDROGEN CHLORIDE: RESULTS SUMMARY

Clark-Drain Ltd , Yaxley
Galvanising Plant

Sample Runs

Parameter	Units	Run 1		Mean
Concentration	mg/m ³	0.11		0.11
Uncertainty	±mg/m ³	0.02		0.02
Mass Emission	g/hr	2.1		2.1
Uncertainty	±g/hr	0.33		0.33

Parameter	Units	Run 1		Mean
Water Vapour	% v/v	0.91		0.91
Uncertainty	±% v/v	0.05		0.05

Blank Runs

Parameter	Units	Blank 1		Maximum
Concentration	mg/m ³	< 0.01		< 0.01

General Sampling Information

Parameter	Value
Standard	EN 1911
Technical Procedure	CAT-TP-11
Name of Analytical Laboratory	CAT
Analytical Laboratory's Procedure	CAT-AP-01
ISO 17025 Accredited Analysis?	Yes
Date of Sample Analysis	04/02/2015
Probe Material	Titanium
Filter Housing Material	Titanium
Impinger Material	Polyethylene
Absorption Solution	HPLC Grade Water
Positioning of Filter	In Stack
Filter Size and Material	47mm Glass Fibre
Number of Sampling Lines Used	1 / 1
Number of Sampling Points Used	4 / 1
Sample Point I.D.'s	B1, B2, B3, B4

FORMAT: Number Used / Number Required

FORMAT: Number Used / Number Required

Reference Conditions

Reference Conditions are: 273K, 101.3kPa, without correction for water vapour content.

HYDROGEN CHLORIDE: SAMPLING DETAILS

Sample Runs

Parameter	Units	Run 1	
Sampling Times	-	14:41 - 15:41	
Sampling Dates	-	27/01/2015	
Sampling Device	-	DGM	
Duration	mins	60	
DGM Start Volume	m ³	6.74	
DGM End Volume	m ³	7.978	
DGM Start Temperature	°C	16	
DGM End Temperature	°C	20	
Start ΔH	mmH ₂ O	50.2	
End ΔH	mmH ₂ O	50.2	
DGM Y _d	-	1.098	
Barometric Pressure	kPa	102.5	
Volume Sampled (STP, Dry)	m ³	1.2961	
Volume Sampled (STP, Wet)	m ³	1.3079	
Volume Sampled (REF)	m ³	1.3079	
Sample Flow Rate	l/min	22.66	
Laboratory Result for Front Impingers	µg/ml	0.51	
Laboratory Result for Back Impinger	µg/ml	0.05	
Volume in Front Impingers	ml	281.6	
Volume in Back Impinger	ml	125	
Mass in Front Impingers	µg	143.6	
Mass in Back Impinger	µg	< 6.3	
Total Mass Collected	µg	149.9	
Calculated Concentration	mg/m ³	0.11	
Liquid Trap Start Mass	g	1454	
Liquid Trap End Mass	g	1459.8	
Silica Trap Start Mass	g	1510.2	
Silica Trap End Mass	g	1513.9	
Total Mass Of Water Vapour	g	9.5	
Calculated Water Vapour	% v/v	0.91	

Where: DGM stands for Dry Gas Meter

Blank Runs

Parameter	Units	Blank 1	
Blank Dates	-	27/01/2015	
Average Volume Sampled (REF)	m ³	1.3079	
Laboratory Result for Impingers	µg/ml	< 0.05	
Volume in Impingers	ml	303.7	
Total Mass Collected	µg	< 15.2	
Calculated Concentration	mg/m ³	< 0.01	

HYDROGEN CHLORIDE: QUALITY ASSURANCE

Sample Runs

Leak Test Results	Units	Run 1	
Mean Sampling Rate	l/min	22.66	
Pre-Sampling Leak Rate	l/min	0.35	
Post-Sampling Leak Rate	l/min	0.18	
Allowable Leak Rate	l/min	0.45	
Leak Test Acceptable	-	Yes	

Absorption Efficiency	Units	Run 1	
Absorption Efficiency	%	100	
Allowable Absorption Efficiency	%	N/A ¹	
Absorption Efficiency Acceptable	-	N/A ¹	

¹ The concentration in the last absorber was less than 5 times the analytical detection limit.

Water Droplets	Units	Run 1	
Are Water Droplets Present	-	No	

MU (Concurrent Water Vapour)	Units	Run 1	
Measurement Uncertainty (MU)	%	5.7	
Allowable MU	%	20	
MU Acceptable	%	Yes	

Silica Gel (Concurrent Water Vapour)	Units	Run 1	
Less than 50% Faded	%	Yes	

Test Conditions	Units	Run 1	
Ambient Temperature Recorded?	-	Yes	

Blank Runs

Leak Test Results	Units	Blank 1	
Expected Sampling Rate	l/min	20	
Pre-Sampling Leak Rate	l/min	0.1	
Post-Sampling Leak Rate	l/min	0.11	
Allowable Leak Rate	l/min	0.4	
Leak Test Acceptable	-	Yes	

Validity of Blank vs ELV	Units	Blank 1	
Allowable Blank	mg/m ³	N/A	
Blank Acceptable	-	N/A	

Method Deviations

Nature of Deviation	Run Number
(x = deviation applies to the associated run, wx = deviation also applies to the concurrent water vapour run)	1
There are no deviations associated with the sampling employed.	x

HYDROGEN CHLORIDE: MEASUREMENT UNCERTAINTY CALCULATIONS

Measured Quantities	Value			Symbol	Standard uncertainty		
	Symbol	Run 1			Units	Run 1	
Sampled Volume (Actual)	V_m	1.238		uV_m	m ³	0.0248	
Sampled Gas Temperature	T_m	291		uT_m	K	2	
Sampled Gas Pressure	p_m	102.5		up_m	kPa	0.5	
Sampled Gas Humidity	H_m	0.0000		uH_m	% v/v	1.000	
Leak	L	0.79		uL	%	-	
Laboratory Result	L_r	6.8		uL_r	%	-	

Measured Quantities	Uncertainty as a Percentage			Requirement of Standard
	Units	Run 1		
Sampled Volume (Actual)	%	2		≤2%
Sampled Gas Temperature	%	0.69		≤1%
Sampled Gas Pressure	%	0.49		≤1%
Sampled Gas Humidity	%	1.00		≤1%
Leak	%	0.79		≤2%
Laboratory Result	%	6.8		No Requirement

Measured Quantities	Uncertainty in Measurement Units				Sensitivity Coefficient	
	Symbol	Units	Run 1		Run 1	
Sampled Volume (STP)	V_m	m ³	1.2961		0.09	
Leak	L	mg/m ³	0.001		1.000	
Laboratory Result	L_r	mg/m ³	0.008		1.000	

Measured Quantities	Uncertainty in Result		
	Units	Run 1	
Sampled Volume (STP)	mg/m ³	0.003	
Leak	mg/m ³	0.0005	
Laboratory Result	mg/m ³	0.0078	

Measured Quantities	Oxygen Correction Part of MU Budget		
	Units	Run 1	
O ₂ Correction Factor	-	N/A	
Stack Gas O ₂ Content	% v/v	N/A	
MU for O ₂ Correction	-	N/A	
Overall MU For O ₂ Measurement	%	N/A	

Parameter	Units	Run 1	
Combined uncertainty	mg/m ³	0.01	
Expanded uncertainty (95% confidence), without Oxygen Correction	mg/m ³	0.02	
Expanded uncertainty (95% confidence), with Oxygen Correction	mg/m ³	N/A	
Expanded uncertainty (95% confidence), estimated with Method Deviations	mg/m ³	0.02	
Reported Uncertainty	mg/m ³	0.02	
Expanded uncertainty (95% confidence), without Oxygen Correction	%	14.1	
Expanded uncertainty (95% confidence), with Oxygen Correction	%	N/A	
Expanded uncertainty (95% confidence), estimated with Method Deviations	%	14.1	
Reported Uncertainty	%	14.1	

PCME METER

Contract Details	
Test House Job Number	CSW-1625
Company	Clark-Drain Ltd
Site	Yaxley
Stack	Galvanising Plant
Sampling Date	27/01/2015
PCME Job Number	J34A16570

Stack Conditions	Value	Units
Stack Temperature	32.35	°C
Stack Humidity	0.95	% v/v
Stack Oxygen Content	N/A	% v/v
Stack Pressure	102.7	kPa

Current Instrument Settings	Type	Serial Number
Controller Type	IM	34304
Channel Type	DT 373	34303
Channel Number	Stack1 Dust	
Instrument Checks	Pass	
Current Calibration Factor	7.66	
Time on Display	10:32	
Time Difference - Meter v Actual	PCME 29 minutes fast	
GMT / BST?	GMT	
Was Time Changed?	No	

Hardware Status	
Zero	19
Span	10016
S/C	10031
Contamination Ring	N/A
Comms Check	Pass

Summary of Test Data - Results of SRM vs CEM									
Run	Start Time	Finish Time	Instrument Average	Instrument Maximum	TPM Conc. STP WET	TPM Conc. STP DRY	TPM Conc. STP WET, % O ₂	TPM Conc. STP DRY, % O ₂	TPM Conc. ACTUAL
1	11:00	12:00	3.60	36.55	4.42	4.45	N/A	N/A	4.00
2	13:30	14:26	4.51	33.33	6.89	6.97	N/A	N/A	6.24
3	14:41	15:41	1.91	7.56	3.65	3.68	N/A	N/A	3.3
Mean			3.34		4.98	5.03	N/A	N/A	4.52

For all matters relating to the function, performance and calibration of the PCME Meter, please speak directly to PCME on 01480 468 200.

Times listed in the table above relate to the actual time of the tests, and not the times as read by the PCME meter.