

**Tower House
Fishergate
YORK
YO10 4UA
Fax: 01904 658969
Tel: 01904 567300
Email: Rowetech@btinternet.com**

Rowe Technology Ltd


Fax

To:	Aaron Morley, Huntingdonshire Council	From:	Rob Weir
Fax:	01480 388 361	Pages:	6
cc:	Mark Gilbey, Clarksteel Ltd	Date:	17 February 2003
Re:	Stack Emissions Testing Report		Clarksteel Ltd

Further to our telephone conversation, please find attached the missing pages from the Stack Emissions Testing Report, for Clarksteel Ltd, carried out by Scientifics.

Kind regards,

Rob Weir



AIR & EMISSIONS TESTING GROUP

52 Offerton Industrial Estate, Hempshaw Lane, Stockport, SK2 5TJ.

Tel: 0161 477 3004 Fax: 0161 480 4842

Mobile: 07973 310576 (24 Hours)

Email: james.bcating@scientifics.com

Stack Emissions Testing Report

Total Particulate Matter

Clarksteel Limited

Yaxley

Fume Extraction System

Sampling Date

20th January 2003

Report by

Mark Woodruff

Job Number

LAB 04107

Contents

	Page
Title Page	1
Introduction	2
Emissions Summary	3
Written Summary	3
Total Particulate Matter Summary	3
Calculations - Run 1	4
Calculations - Run 2	5
Total Particulate Matter Sampling Methodology	6
On Site Isokinetic Data Sheet	8
Quality Assurance Checklist	9
Environmental Monitoring Team	10
Stack Diagram	11
Plant Layout	11
Deviations from Test Method	12
Conclusion	12
PCME DT 770 Calibration Report	13

Introduction

Clarkssteel Limited operate a Galvanising Process at Yaxley which is subject to Local Air Pollution Control under the Environmental Protection Act 1990, Part 1.

Scientifics Limited were commissioned by PCME Limited to carry out stack emissions testing to determine the release of total particulate matter from the following Plant under normal operating conditions. This test is part of the calibration service offered by PCME Limited in support of their continuous emissions monitor which is installed on the Plant.

Company	Clarkssteel Limited
Site	Yaxley
Stack	Fume Extraction System
Sampling Date	20th January 2003
Time Test Started	15:30
Time Test Ended	17:30
Abatement Plant	Rowe Scrubber
Operating Conditions	General Galvanising
Materials Processed	Miscellaneous Items
Fuel Type (If Applicable)	Natural Gas
Plume Appearance	None Visible
Process	Hot Dip Galvanising
Process Guidance Note	PG 2/2 (96)

Throughout sampling, the operating conditions were maintained as above. Any deviations from BS 3405 : 1983 are noted in the conclusion.

Emissions Summary

Company	Clarksteel Limited
Site	Yaxley
Stack	Fume Extraction System
Sampling Date	20th January 2003

Parameter	Units	Result	Limit	Outcome
Total Particulate Matter	mg/m ³	5.0	15	Passed
Particulate Emission Rate	g/s	0.02	-	-
Stack Gas Temperature	°C	23	-	-
Moisture	%	2.6	-	-
Stack Gas Volumetric Flow Rate (Actual)	m ³ /hr	15346	-	-
Stack Gas Volumetric Flow Rate (STP)	m ³ /hr	14424	-	-
Stack Gas Velocity	m/s	9.6	-	-

All results are mean values, with particulate concentrations expressed at reference conditions.

Reference conditions are 273K, 101.3 kPa, without correction for water vapour content.

Written Summary

Total Particulate Matter	Passed
---------------------------------	---------------

Two particulate tests were performed during continuous operating conditions. The mean sampling time was 16 minutes. The mean particulate concentration was 5 mg/m³ at reference conditions. This value is below the specified emission limit of 15 mg/m³.

The tests were performed following the main procedural requirements of BS 3405 : 1983 using a Ströhlein STE 4 isokinetic particulate sampling train.

Total Particulate Matter Summary

Sample	Sampling Times	Concentration	Limit
Run 1	16:14 - 16:30	5.7 mg/m ³	-
Run 2	16:39 - 16:55	4.9 mg/m ³	-
Mean Particulate Concentration		5.0 mg/m ³	15 mg/m ³

Sample	Sampling Times	Particulate Emission Rate	Ratio of Particulate Emission Rates
Run 1	16:14 - 16:30	0.023 g/s	-
Run 2	16:39 - 16:55	0.017 g/s	-
Mean Particulate Emission Rate		0.020 g/s	1.32 : 1

Calculations - Run 1

1. Stack Gas Velocity (V)

$V = 0.075 \times C_p \times \sqrt{\Delta P} \times \sqrt{T}$
 $V =$ Velocity (m/s)
 $C_p =$ Pitot Tube UKAS Calibration Coefficient = 0.792
 $\Delta P =$ Mean Differential Pressure (Pa)
 $T =$ Mean Temperature (K)

2. Stack Gas Volumetric Flow Rate (Q)

Stack Gas Velocity (V)	9.67 m/s
Stack Diameter (D)	0.75 m
Stack Area (A)	0.44 m ²
Stack Temperature (T)	296.00 K
Atmospheric Pressure (P _A)	103.00 kPa
Static Pressure (P _{st})	0.15 kPa
Standard Barometric Pressure (P _B)	101.30 kPa

$$Q_{(STP)} = \frac{273}{T} \times \frac{(P_A + P_{st})}{P_B} \times V \times A$$

$$Q_{(actual)} = V \times A$$

$$Q_{(STP)} = 4.01 \text{ m}^3/\text{s}$$

$$Q_{(actual)} = 4.27 \text{ m}^3/\text{s}$$

3. Particulate Mass Emission Rate (M)

No. of Sampling Points (n)	4
Duration at each point (s)	240 s
Nozzle area (a)	50.27 mm ²
Particulate mass (m)	0.0025 g
Stack Area (A)	0.44 m ²

$$M = \frac{(A \times m)}{(n \times a \times s)} \times 10^6 = 2.3 \times 10^{-2} \text{ g/s}$$

$$M = 0.023 \text{ g/s}$$

4. Particulate Concentration (C) at 273K, 101.3kPa

$$C = (M / Q_{(STP)}) \times 1000$$

$$C = 5.70 \text{ mg/m}^3$$

Calculations - Run 2

1. Stack Gas Velocity (V)

$V = 0.075 \times C_p \times \sqrt{\Delta P \times T}$
 $V =$ Velocity (m/s)
 $C_p =$ Pitot Tube UKAS Calibration Coefficient = 0.797
 $\Delta P =$ Mean Differential Pressure (Pa)
 $T =$ Mean Temperature (K)

2. Stack Gas Volumetric Flow Rate (Q)

Stack Gas Velocity (V)	9.62 m/s
Stack Diameter (D)	0.75 m
Stack Area (A)	0.44 m ²
Stack Temperature (T)	295.50 K
Atmospheric Pressure (P _A)	103.00 kPa
Static Pressure (P _{st})	0.15 kPa
Standard Barometric Pressure (P _B)	101.30 kPa

$$Q_{(STP)} = \frac{273}{T} \times \frac{(P_A + P_{st})}{P_B} \times V \times A$$

$$Q_{(actual)} = V \times A$$

$$Q_{(STP)} = 4.00 \text{ m}^3/\text{s}$$

$$Q_{(actual)} = 4.25 \text{ m}^3/\text{s}$$

3. Particulate Mass Emission Rate (M)

No. of Sampling Points (n)	4
Duration at each point (s)	240 s
Nozzle area (a)	50.27 mm ²
Particulate mass (m)	0.0019 g
Stack Area (A)	0.44 m ²

$$M = \frac{(A \times m)}{(n \times a \times s)} \times 10^6 = 1.7\text{E-}02 \text{ g/s}$$

$$M = 0.017 \text{ g/s}$$

4. Particulate Concentration (C) at 273K, 101.3 kPa

$$C = (M / Q_{(STP)}) \times 1000$$

$$C = 4.35 \text{ mg/m}^3$$

28/01 '03 WED 16:38 FAX 01480 483400

PCME LTD

004

Total Particulate Matter Sampling Methodology

Job Preparation

A pre-site survey must first be undertaken to obtain the following information. Client details (full address & contact names), description of stack (name & location), sampling platform / access (Permanent - platform of adequate size & load capability, kick boards, hand & middle rails, free from debris, good drainage, fixed ladders with hoops and chain. Temporary - adequate size & load capability, stabilising legs, valid inspection tag, kick boards, hand & middle rails. Both types of platform must have a secure anchorage point to fix pulley system) hazards (dust, noise, temperature, gases/vapours, vibration, light, moving machinery, electricity etc) power supply and location, additional PPE required (high temperature gloves/overalls, PPE).

Two Strömolin STE 4, isokinetic particulate measurement equipment, is fully inspected prior to use and its calibration status observed. This includes:

Pilot Tube - All pilot tubes are physically checked for damage, paying particular attention to the Intel holes. All dirt and blockages are removed.

Micromanometer - Digital differential pressure meters are used capable of measuring pressure in the range 0 Pa to 2250 Pa with a sensitivity of ± 1 Pa. These instruments are checked for obvious physical damage, battery life tested and calibrated status observed.

Thermocouple - Temperature is measured using K type thermocouples. Each thermocouple is inspected for obvious damage and its calibration status observed. Digital temperature meters are used in conjunction with K type thermocouples. These are also checked for obvious physical damage and their battery life tested.

Nozzles - All nozzles used have been constructed in accordance BS 3405 : 1983, section 5.3.2. Each nozzle is physically checked for damage and removed if necessary. The nozzle calibration status is observed.

Flowmeter - The flowmeter is checked for blockages and obvious physical damage. Its calibration status is also observed.

Balance - A Mettler Toledo balance is used to weigh filters. The balance is positioned on a solid base located in a specially built weighing room. The balance is serviced and calibrated routinely each year by the manufacturer and also checked daily with in-house check weights.

Rope Kit All lifting tackle i.e. rope, pulleys, karabiners, brakes and slings are physically checked for cuts and contamination.

Should the calibration certainty of any of the above equipment be in question, that item of equipment must be recalibrated and replaced if necessary.

Filter Selection and Preparation

Stack conditions can vary greatly for temperature, moisture, acidity, low and heavy particulate loading. Following the pre-site survey, the stack gas condition should be known and the appropriate filter can be selected and prepared as described below.

Filter mediums - glass wool, quartz wool, Gelman Bolances A/C Glass Fibre filter papers, Gelman Sciences Low Ash PVC membrane filter papers, Schleicher & Schuell Glass Fibre Thimbles or Schleicher & Schuell Quartz Thimbles.

Filters are prepared by drying in an oven at 180°C for a period of one hour and then placed to cool in a desiccator. The filters are weighed accurately on a 4-figure balance and then placed in clean individual petri dishes and transported to site in a filter storage box. Spare filters are also prepared to allow for accidents and to obtain blank values.

Sampling Procedure

Suitability of Sampling Location

Before sampling can commence, a preliminary velocity and temperature survey must be undertaken along the two sampling lines at ten equally spaced points excluding the region within 5% of the effective flue diameter from the wall. The stack diameter is measured using a steel rod. If the ratio of the highest to lowest dynamic pressures exceeds 0:1 or if the ratio of the highest to lowest gas velocities exceeds 3:1, another sampling plane should be used. Sampling is undertaken from either four or eight sampling points.

20/01 '03 WED 19:30 FAX 01480 463400

PCME LTD

005

Four sampling points are used when the ratio of the highest to lowest dynamic pressures is less than 4:1 and eight sampling points when the ratio of highest to lowest dynamic pressures exceeds 4:1 but less than 9:1 or the stack area exceeds 2.5 m^2 . Temperature is also measured at ten equally spaced points along the sampling lines and an average temperature calculated. Should the temperature at any of the sampling points differ by more than $\pm 10\%$ from that of the average temperature, then that point must not be used.

The required number of sampling points can now be calculated using the following:

4 point sampling, circular stacks: $0.15 \times D$ and $0.85 \times D$.

4 point sampling, square stacks: $0.25 \times D$ and $0.75 \times D$.

8 point sampling, circular stacks: $0.065 \times D$, $0.25 \times D$, $0.76 \times D$ and $0.835 \times D$.

8 point sampling, square stacks: $0.125 \times D$, $0.375 \times D$, $0.625 \times D$ and $0.875 \times D$.

Leak Checks

A leak check should be undertaken before and after the iso-kinetic sampling is carried out. This is to make sure that all suction is taken at the sampling nozzle.

Sampling

Once the iso-kinetic sampling flow rates have been calculated, the probe is inserted into the stack at 90° to the stack gas flow, as not to impinge any particulate matter on to the filter media prior to sampling. Allow the filter head and probe to attain the stack gas temperature. Start the suction device, and set the flowmeter to the correct suction rate for isokinetic sampling. At the same time turn the nozzle into flow and start the timing device.

Duration of Sampling Time

Duration of sampling time depends on:

- (a) ensuring adequate quantities of particulate matter on the filter for weighing ($> 0.3 \%$ of the filter weight).
- (b) whether cumulative or incremental sampling is undertaken.
- (c) the number of sampling points i.e. either 4 or 8 point sampling.
- (d) the continuity of plant operation.

Cumulative Sampling

After the first sample is taken from the first sampling position the control valve is closed simultaneously turning the sampling probe 90° to the stack gas flow, moving the probe to the next sample position. This process should be repeated until all the sample points have been used once.

Repeat Velocity and Temperature Readings

At each of the sampling points repeat the readings for the stack gas flow rate and stack gas temperature. Calculate the new iso-kinetic sampling flow rates. If the stack gas velocity is more than $\pm 5\%$ from the initial readings the test result shall not be regarded as having the required accuracy. The new temperature reading should not exceed the permitted range calculated in the preliminary survey, i.e. it should be within $\pm 10\%$ of the original mean temperature.

N.B. The filter head should be cleaned and the particulate matter added to the particulate matter on the filter.

The Sampling procedure should be repeated to obtain a duplicate sample, the ratio of the two particulate emission rates should not exceed 1.5 : 1.

Weighing of Sample

The used filter should be placed in an oven at 100°C and dried thoroughly, cooled and equilibrated in a desiccator and weighed as quickly as possible so as to avoid any errors due to moisture absorption onto the filter. The gross weight of the filter should be measured to within $\pm 0.1 \text{ mg}$. The filter weight and any residual particulate matter from the filter head can then be used in the final report to calculate the particulate concentration.

20/01/03 WED 16:40 FAX 01480 403400

PCNS LTD

0006

On Site Isokinetic Data Sheet

Preliminary Stack Survey		Sampling Line A		Sampling Line B	
Traverse Point	Distance in Stack (m)	Dynamic Pressure (Pa)	Temperature (°C)	Dynamic Pressure (Pa)	Temperature (°C)
1	0.04	62	23	-	-
2	0.11	51	23	-	-
3	0.19	88	23	-	-
4	0.26	87	23	-	-
5	0.34	84	23	-	-
6	0.41	74	23	-	-
7	0.49	82	23	-	-
8	0.56	85	23	-	-
9	0.64	98	23	-	-
10	0.71	106	23	-	-
Mean	-	85	23	-	-

Lowest Dynamic Pressure (any line) 64 Pascals

Ratio of Highest to Lowest Dynamic Pressures = 1.66:1

Highest Dynamic Pressure (any line) 106 Pascals

(Highest permitted ratio 9:1)

Temperature Range permitted for any point is between -7 and 63 °C

Run 1		Sampling Time (min) 18				Nozzle size used (mm) 8.00.		
Sampling Point	Dynamic Pressure (Pa)		Temperature (°C)		Velocity (m/s)		Flowmeter set at (m³/hr)	
	Initial	Final	Initial	Final	Initial	Final		
1	82	88	23	23	8.28	8.59	1.78	
2	86	92	23	23	9.48	9.80	1.80	
3	85	81	23	23	8.42	9.20	1.79	
4	106	88	23	23	10.52	10.12	2.00	
Mean	90	90	23	23	9.67	9.88	1.84	

Difference between Initial Velocity and Final Velocity = 0.07 %

(Limit permitted is ± 5%)

Start Filter Weight = 0.1212 g

Sample Weight = 0.0025 g

End Filter Weight = 0.1237 g

Sample as a % of Filter Weight = 2.06 %

Run 2		Sampling Time (mins) 18				Nozzle size used (mm) 8.00	
Sampling Point	Dynamic Pressure (Pa)		Temperature (°C)		Velocity (m/s)		Flowmeter set at (m³/hr)
	Initial	Final	Initial	Final	Initial	Final	
1	88	84	23	22	9.59	9.35	1.82
2	92	86	23	22	9.80	9.46	1.86
3	81	90	23	22	9.20	9.68	1.75
4	98	82	23	22	10.12	8.78	1.92
Mean	90	88	23	22	9.88	9.57	1.84

Difference between Initial Velocity and Final Velocity = -1.12 %

(Limit permitted is ± 5%)

Start Filter Weight = 0.1205 g

Sample Weight = 0.0019 g

End Filter Weight = 0.1224 g

Sample as a % of Filter Weight = 1.58 %

SCIENTIFICS REPORT STARTS HERE

29/01 '03 WED 16:43 FAX 01480 403400

PCME LTD

0007

Quality Assurance Checklist

Velocity Measurements:

Were water droplets present?	No
Direction of gas flow within $\pm 20^\circ$ of stack axis.	Yes
Dynamic pressures > 5 Pa at all sampling points.	Yes
Ratio of highest to lowest dynamic pressures $< 8 : 1$.	Yes

Sampling:

Sampling plane was correctly positioned.	Yes
Area of sampling apparatus was $< 10\%$ of stack area.	Yes
Sampling was from centres of equal areas.	Yes
Sampling at each point not less than 3 minutes.	Yes
Nozzle was facing directly upstream to within $\pm 10^\circ$.	Yes
Leak check performed before and after each run and passed.	Yes

Sample Handling:

Minimum weight of samples collected $> 0.3\%$ of filter weights.	Yes
Samples achieved stable weights.	Yes
Particulate samples stored for 3 months.	Yes

QA Procedures:

Isokinetic data sheet completed and signed off by Team Leader.	Yes
Report saved electronically onto Scientifics server.	Yes
Raw data and hard copy of report filed together.	Yes

29/01 '03 WED 16:42 FAX 01460 483400

PCME LTD

2008

Environmental Monitoring Team

Environmental Team Leader

Tim Heaton
BSc (Hons) Environmental Resource Science
MSc Sustainable Energy Technology

Environmental Technician

Mark Woodruff
BSc (Hons) Environmental Studies

Report by

Mark Woodruff
Environmental Technician

Checked and Authorised By

Andrew Palliser

Name

23rd January 2003

Dated

Team Leader


Business Title

20/01 '03 WED 18:42 FAX 01480 483400

PCML LTD

2009

Stack Diagram





Sampling
Line A

Stack Diameter (D) = 0.75 m
Stack Area (A) = 0.44 m²

Sampling Point	Distance as % of (D)	Distance in m
1	8.5	0.05
2	25.0	0.19
3	75.0	0.56
4	83.5	0.70

Plant Layout



29/01 '03 WED 16:43 FAX 01480 400400

PCME LTD

0010

Deviations from Test Method

Testing was performed in accordance with BS 3405 : 1983, apart from the fact that only 1 sampling line could be used, as only 1 port cap could physically be removed. However, 4 sampling points were used on the 1 available line, instead of just 2.

Conclusion

The results of this test demonstrate that under normal operating conditions, this Plant is being operated in compliance with the total particulate matter emission limit specified in PG 2/2 (96).

Good housekeeping and maintenance of the ducting and associated Plant should be continued in order to maintain this level of Plant performance.

A regular programme of stack emissions testing in accordance with the Plant's Local Air Pollution Control Authorisation will be required to demonstrate continued compliance.

What is
the
Maintenance
Schedule?