



# Guardian Laboratories (Midlands) Limited

Assayers and Consulting Scientist

Unit 1, Rocky Lane Trading Estate, Aston, Birmingham B7 5ER

Tel: 0121 359 8233 Fax: 0121 359 7281

East Anglian Galvanising Ltd  
Old North Road  
Sawtry  
Cambridgeshire  
PE28 5XN

## EMAILED TEST REPORT

CERTIFICATE No. L 26089

DATE RECEIVED 04/10/2010

ORDER No.

Page 1 of 1

### Clients Reference:

**Material Description:** 4 Water Samples Reference 1/10/10

We hereby certify that we have analysed your material referenced above and obtained the following results :-

Sample Reference	pH	Zinc	Ammonia
Units	-----	µg/litre	mg/litre
1 Outlet From Site	7.92	<20	0.7
2 Up Stream Side Of Factory	7.96	26	0.3
3 Up Stream Rear Of Factory	8.16	21	0.2
4 Down Stream Rear Of Facto	8.19	<20	0.3

TESTED BY AT/JM

DATE OF ISSUE 04/10/2010