

EMISSIONS MONITORING SURVEY

Prepared for:

Linx Printing Technologies Ltd.
Burrell Road
St Ives
Huntingdon
Cambridgeshire
PE27 3LA


Permit Number	: PG6/44(04)
Variation Number	: 2004
Installation	: Manufacturing Main Vent
Visit Details	: Annual Compliance 2012
Job Number	: P1583
Report Number	: R001
Report Issue Date	: 28 th November 2012
Survey Dates	: 14 th November 2012

Prepared by:

Environmental Compliance Limited
 Unit G1
 Main Avenue
 Treforest Industrial Estate
 Pontypridd
 CF37 5BF.

Tel: 01443 841760

Fax: 01443 841761

Report Issue:		FINAL	
Report Prepared by:		Report Reviewed & Approved by MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
Name:	Jon Litterick	Name:	Andy Barnes
		MCERTS No:	MM 03 235
		Signature:	
Date:	27/11/12	Date:	28/11/12

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".



Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECLs duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Clients' release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.

TABLE OF CONTENTS

Section	Description	Page Number
	Document Control Sheet	
PART 1	EXECUTIVE SUMMARY	4
1	MONITORING OBJECTIVES	4
1.1	Monitoring Results	5
1.2	Operating Information	6
2	MONITORING DEVIATIONS	7
PART 2	SUPPORTING INFORMATION	8
3	SAMPLING STAFF DETAILS	8
4	SAMPLING PROTOCOLS / METHODOLOGIES	9
5	SAMPLE POINT DESCRIPTIONS	11
	EQUIPMENT IDs	12
	FIGURES	14
	TABLES	16
	VELOCITY TRAVERSE PROFILE	21
	FIELD CALIBRATION AND SAMPLING DATA	23
	LABORATORY ANALYSIS RESULTS	28
	UNCERTAINTY CALCULATIONS	31

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

PART 1 - EXECUTIVE SUMMARY

1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **Linx Printing Technologies Ltd** to undertake an emission monitoring survey at their **Ink Manufacturing site in St Ives**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **PC/P1583/Q001**, for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification
Particulates	● U
Total Organic Carbon (TOC)	● U

Special Requirements: *“Test TOC for full 8 hours”*

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status
Ink Manufacture – Main Vent	Particulates §	20	5.84	mg/m ³	4	& Wet Gas	14/11/12	09:00 – 11:00	BS EN 13284-1	UKAS / MCERTS	✓	Normal – see notes in section 1.2
	Particulates §	20	0.57	mg/m ³	28	& Wet Gas	14/11/12	11:15 – 13:15	BS EN 13284-1	UKAS / MCERTS	✓	
	Particulates §	20	0.53	mg/m ³	30	& Wet Gas	14/11/12	13:25 – 15:25	BS EN 13284-1	UKAS / MCERTS	✓	
	TOCs as Carbon	150	138.1	mg/m ³	5	& Wet Gas	14/11/12	08:05 – 16:04	BS EN 13526	UKAS / MCERTS	✓	

Notes

The uncertainty figure presented in Table 1.1 for TOC is the “measurement uncertainty” figure, which does not take into account the variability of the measured sample values. The “uncertainty of measurement results” figure, which does include this contribution, is also presented in the appendices of the report.

Emission Limit Value	The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.
Periodic Monitoring Result	The result given is expressed in the same terms and units as the emission limit value.
Uncertainty	The uncertainty associated with the quoted result is at the 95% confidence interval. The Uncertainty results DO NOT take into account the effect of the sample location limitations.
Reference Conditions	All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.
Monitoring Method Reference	The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.
Accreditation for use of Method	The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTS, UKAS. If use of the method is not accredited " NA" is stated.
Operating Status	The details indicate the feedstock and the loading rate of the plant during monitoring.
§	Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4
NU	UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5
NA	Method is NOT UKAS Accredited.

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

1.2 Operating Information

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
Main Vent	Batch	08:00 – 16:30	n/a	n/a	None	Normal*	n/a

Notes:

Process Type State whether the process is a continuous or batch process.
 Process Duration If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
 Fuel If applicable, state the fuel type If not applicable state "NA"
 Feedstock State the feedstock type
 Abatement State the type and whether operational during monitoring. If not applicable state "NA"
 Load State the normal load, throughput or rating of the plant
 CEMS Data Enter this data for each CEM installed if it has been provided by operator otherwise state "NP" (NOT PROVIDED).

The following details regarding process operation were recorded by site personnel for inclusion in this report.

Main-line & mini-line operating from circa 08:00.

Significant powder additions took place during particulate test 1 (09:00 – 11:00).

An accidental spillage occurred (open bottle of solvent) near to one of the floor extraction points at 10:30 (shown by large spike in TOC concentration graph) – clean up was complete within 10 minutes.

Main-line was noted to have ceased production by 15:00, but the mini-line was still operating to the end of the sample period at 16:04.

2 Monitoring Deviations

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1. This survey meets the requirements of the site's **PPC Permit Number: PG6/44(04)** where UKAS and MCERTS accreditation has and could be claimed for the testing in the monitoring results table.

There were no modifications to the sampling procedures (TPDs) listed in section 4.

There were no substance deviations from the original and agreed emissions monitoring schedule.

Non-conforming tests are as follows.

Particulate samples were made from centre point only, whereas BS EN 13284 stipulates 5 sample points for a duct with this diameter (500mm). This deviation was made for safety reasons, as there are no internally threaded sample ports available so securing the probe at all the sample points was not possible. **This non-conformity does not alter the accreditation status of the tests.**

TOC sampling was made on the 1000ppm range of the FID, this was to cover possible very high spikes of data as had been recorded historically. The span gas chosen was at 200ppm, (close to 1.5 x ELV), but this is not within the 50 – 90% of analyser range as stipulated in BS EN 13526. **This non-conformity does not alter the accreditation status of the tests.**

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.

Homogeneity tests have/ have not been completed and are not applicable to this location as the duct area is <1m².

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

PART 2 – SUPPORTING INFORMATION

3 SAMPLING STAFF DETAILS

Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
Andy Barnes	14/11/2012	MM03 235	2	TE1, TE2, TE3, TE4

Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Andy Barnes	MM 03 235	2	TE1, TE2, TE3, TE4

Technical Endorsement Key:-

TE1 – Isokinetic Particulates, Temperature & Velocity Profiles, Oxygen.

TE2 – Isokinetic Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCL, HF.

TE3 – Non-Isokinetic Extractive Pollutants:- Speciated VOCs, HF, HCL, Cyanide.

TE4 – Continuous Analysers (Combustion Gases):- TOCs, CO, NOx, SO2.

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

4 SAMPLING PROTOCOLS / METHODOLOGIES

Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.

TOCs as Carbon

Testing was carried out using an MCERTS Certified Signal 3030PM FID and heated gas sample line, with reference to the manufacturer's operation handbook, **BS EN 13526** and in-house technical procedure **ECL/TPD/032**.

The analyser was calibrated on site using certified propane span gases which are traceable to ISO 17025 standard. (with uncertainty <2%). Zero measurements were performed using Nitrogen. The analyser was calibrated directly into the sample inlet and then checked through the entire sampling system (including sampling probe and heated gas transport lines). Data was corrected by molecular weight to TOCs as total carbon.

Data was recorded as minute averages over each test period. The data is presented in the Figures Section and the minute averaged data is detailed in the Tables Section.

The date of the last control gas mixture test on the FID was April 2012.

Pressure, Temperature and Velocity

Testing was carried out using a sampling system in accordance with **BS EN 13284-1 & MID** and In-house technical procedure **ECL/TPD/022**.

Temperature was recorded using a thermocouple and digital temperature reader.

Velocity and pressure were recorded using an "L" type pitot and digital manometer, data being recorded in Pascals.

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

Particulates

Testing was carried out using a Manual Stack Sampling system in accordance with **BS EN 13284-1 & MID** and In-house technical procedure **ECL/TPD/027a**.

Isokinetic particulate sampling is achieved when the velocity of gas entering the sampling nozzle is exactly equal to the velocity of the approaching gas stream within the stack.

A measured volume of sample gas is withdrawn from the stack isokinetically through a sampling nozzle and through 37mm pre-weighed and pre-blown GFA filter positioned in an unheated housing inserted into the stack.

Particulate matter is collected on the filter. Following testing the front half of the filter housing and the sample nozzle are rinsed to remove any particulate matter which, may have impacted on the surfaces during testing. The dry residue of the Acetone used for rinses is <5mg/l. The filters and rinses are subsequently analysed to determine the amount of particulate matter captured.

The standard pre-sample conditioning temperature of the filters is 180°C and the standard post-sample conditioning temperature is 160°C. (Any modifications to this are noted in section 2 of this report).

Scientific Analysis Laboratories Ltd (SAL) who are situated in Manchester carried out the analysis of the samples. **SAL** are UKAS accredited for this analysis. In addition to the survey samples, appropriate field blanks are submitted as part of the technical procedure.

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

5 SAMPLE POINT DESCRIPTIONS

The homogeneity test is applicable to combustion processes. This includes but is not restricted to, those regulated under the Waste Incineration Directive (**WID**) and the Large Combustion Plant Directive (**LCPD**).

Homogeneity testing has not been completed at this location. The test is not usually required for stacks with sampling plane areas of $<1\text{m}^2$ (below 1.13m in diameter for circular ducts).

The sample location that was monitored is detailed below:-

Ink Manufacture – Main Vent

The sampling plane is in long straight vertical section of the emissions stack.

The diameter at the sample plane is 0.5m.

The flow characteristics meet the **requirements** of the standard.

2 x 2" ports are available and are located as per the requirements of BS EN 13284.

The equipment is set up at ground level, with probes raised to the sample plane (<5m) via temporary access.

Samples for Particulates are non-conforming tests, due to the fact that not all the designated sample points on the sample plane could be used. Whilst it was possible to safely reach both ports for the purposes of the pitot traverse, there was no safe way to support the probe in Port B for particulate sampling, and in port A, the probe was fixed at a single (centre) point in the duct. This non-conformity does not alter the accreditation status of the tests.

The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.

Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

EQUIPMENT IDs
(Pre site checklist from SSP)

Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012


FIGURES

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

Figure 1

**TOC Emissions Data - Linx Printing - Main Vent.
Data Recorded on 14/11/12 - 08:05 to 16:04.
Data Presented at 273K, 101.3kPa & Wet Gas**



Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

TABLES

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

Table 1

TOC Data Recorded from Manufacturing - Main Vent
Sample Period: 08:05 – 16:04 on the 14th November 2012

Volumetric Flowrate (Reference Conditions) = 0.79 m³/sec *

	Average	Emission Rate
	mg/m³	Kg/hr
TOCs (as carbon)*	138.06	0.393

* Reference Conditions (273K, 101.3 kPa & Wet Gas)

Table 2 – Particulates
Data Recorded from Production - Main Vent

Emission Parameter	Units	TPM 1	Blank
Stack Diameter	metres	0.50	...
			...
Area of Sample Plane	m ²	0.196	...
Moisture Content	%	0.12	...
Oxygen Content	%	20.90	...
Stack Temperature	°C	18	...
Gas Velocity (at Stack Conditions)	m/sec	4.24	...
Gas Velocity (Reference Conditions)	m/sec*	4.03	...
Volumetric Flowrate (Stack Conditions)	m ³ /sec	0.83	...
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	0.79	...
Sample Date	...	14/11/2012	...
Sample Period	...	09:00 - 11:00	...
Sample Volume (at Stack)	m ³	2.18	...
Sample Volume (reference Conditions)	m ³ *	2.07	2.07
Isokinetic Sampling Rate	%	109.4	...
Sample Reference (ECL ID)	ECL/12/	6448 & 6449	6450 & 6451
Mass of Particulate Matter Collected	mg	12.10	0.15
Concentration of Particulate Matter	mg/m ³ *	5.84	0.07
Emission Rate of Particulate Matter	g/hr	16.62	...
Expanded Uncertainty (% Relative)	%	4	...
Emission Limit Value (ELV)	mg/m ³ *	20	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Table 3 – Particulates
Data Recorded from Production - Main Vent

Emission Parameter	Units	TPM 2	Blank
Stack Diameter	metres	0.50	...
			...
Area of Sample Plane	m ²	0.196	...
Moisture Content	%	0.13	...
Oxygen Content	%	20.90	...
Stack Temperature	°C	18	...
Gas Velocity (at Stack Conditions)	m/sec	4.24	...
Gas Velocity (Reference Conditions)	m/sec*	4.03	...
Volumetric Flowrate (Stack Conditions)	m ³ /sec	0.83	...
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	0.79	...
Sample Date	...	14/11/2012	...
Sample Period	...	11:15 - 13:15	...
Sample Volume (at Stack)	m ³	2.03	...
Sample Volume (reference Conditions)	m ³ *	1.93	1.93
Isokinetic Sampling Rate	%	101.8	...
Sample Reference (ECL ID)	ECL/12/	6452 & 6453	6450 & 6451
Mass of Particulate Matter Collected	mg	1.10	0.15
Concentration of Particulate Matter	mg/m ³ *	0.57	0.08
Emission Rate of Particulate Matter	g/hr	1.62	...
Expanded Uncertainty (% Relative)	%	28	...
Emission Limit Value (ELV)	mg/m ³ *	20	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

Table 4 – Particulates
Data Recorded from Production - Main Vent

Emission Parameter	Units	TPM 3	Blank
Stack Diameter	metres	0.50	...
			...
Area of Sample Plane	m ²	0.196	...
Moisture Content	%	0.13	...
Oxygen Content	%	20.90	...
Stack Temperature	°C	18	...
Gas Velocity (at Stack Conditions)	m/sec	4.24	...
Gas Velocity (Reference Conditions)	m/sec*	4.03	...
Volumetric Flowrate (Stack Conditions)	m ³ /sec	0.83	...
Volumetric Flowrate (Reference Conditions)	m ³ /sec*	0.79	...
Sample Date	...	14/11/2012	...
Sample Period	...	13:25 - 15:25	...
Sample Volume (at Stack)	m ³	2.01	...
Sample Volume (reference Conditions)	m ³ *	1.90	1.90
Isokinetic Sampling Rate	%	100.5	...
Sample Reference (ECL ID)	ECL/12/	6454 & 6455	6450 & 6451
Mass of Particulate Matter Collected	mg	1.01	0.15
Concentration of Particulate Matter	mg/m ³ *	0.53	0.08
Emission Rate of Particulate Matter	g/hr	1.51	...
Expanded Uncertainty (% Relative)	%	30	...
Emission Limit Value (ELV)	mg/m ³ *	20	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

*Reference Conditions (273K, 101.3kPa, Wet Gas)

Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

VELOCITY TRAVERSE PROFILE

Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

FIELD CALIBRATION AND SAMPLING DATA

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

FID CALIBRATION

		TOC	
		ppm	
Analyser Range		1000	
Repeatability at Zero		10	
Span Gas Concentration Applied		199.9	
Zero Gas Concentration Applied		0	
Direct Cal	Zero	0.00	
	Span	200.34	
	Zero	3.03	
Difference (Zero)		3.028787879	
<2*Repeatability @ Zero?		YES	
Pre Test	Zero	3.03	
	Span	199.58	
	Difference (Zero)	0	
<5% (2% for O₂) Relative to Direct Span		YES	If Red CONTACT QM
Difference (Span)		0.757196977	
<5% (2% for O₂) Relative to Direct Span		YES	If Red CONTACT QM
Post Test	Zero	0.00	
	Span	209.74	
	Difference (Zero)	3.029	
<2% of Analyser Range		YES	If Red apply Drift
Difference (Span)		10.159	
<2% of Analyser Range		YES	If Red apply Drift
Drift <5% of Analyser Range?		YES	If Red CONTACT QM

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

Environmental Compliance Limited		PARTICULATE DATA SAMPLING PROFORMA			Date of Measurement		14/11/2012		
ECL/TPD/	27a	Time taken to change Ports	0	Start Time	09:00	End Time	11:00	Duration (mins)	120
Client	Linx Printing	Stack Profile	Circular	Pitot ID	489	Stack Thermocouple ID	464	Impingers	n/a
Site	St Ives	Stack Area (m ²)	0.20	Manometer ID	506	Stack Temp Reader ID	414	SOL/	n/a
Location	Production	Barometric Pressure (mb)	1025	Barometer ID	352	Meter Thermocouple ID	367	Start Weight (g)	0.00
Stack ID	Main Vent	Stat Pres. (mmH ² O) (Pa/9.81)	0.5	DGM Yd	1.0202	Meter Temp Reader ID	367	End Weight (g)	2.00
Test No.	TPM 1	Pitot coefficient	1	Nozzle ID	800	Dry Gas Meter ID	367	Total weight (g)	2.00
Job No	P1583	Balance ID	n/a	Nozzle Size (mm)	9.12	Timer ID	367		
ECL Site Staff	AB	Console ID	367	Filter ID	799	Rotameter ID	367		

	Sample	Leak 1	Leak 2	Leak 3	Leak 4
Start Volume	1268770.0				
Final Volume	1270935.0				
Total Volume	2165.0	0.0	0.0	0.0	0.0

Total	Volume (litres) @STP Dry
	Expected Sample Volume
	Actual Sample Volume
2165.0	Isokinetic Percentage

Leak Check	First	Second	Third	Final	Maximum allowed leak rate is 2% of the set rate	Measured O ₂	20.90	Moisture	0.12
Leak Rate l/min	0.1			0.1		Measured CO ₂ %		Ref O ₂	20.9
Set Rate (l/min)	20			20		Measured CO ppm		Dry Gas Molecular Weight	28.84
Time Of Leak Check	08:55			11:02					
Leak % of set rate	0.5			0.5					

Traverse Point	CP	CP	CP	CP	CP	CP	CP	CP	CP	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point (mins)	0 - 5	5 - 10	10 - 15	15 - 20	20 - 25	25 - 30	30 - 35	35 - 40		
ΔP (Pa)	11	11	11	11	11	11	11	11	11	11.0
Velocity at Stack (m/s)	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	16.3	16.3	16.3	16.5	16.6	16.7	16.8	16.9	16.5	16.5
Meter (Tm)	9	10	10	12	14	16	17	19	13.4	13.4
Stack Temp (Ts)	18	18	18	18	18	18	18	18	18.0	18.0

Traverse Point	CP	CP	Total							
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point (mins)	40 - 45	45 - 50	50 - 55	55 - 60	60 - 65	65 - 70	70 - 75	75 - 80		
ΔP (Pa)	11	11	11	11	11	11	11	11	11	11.0
Velocity at Stack (m/s)	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	16.9	16.9	17.0	17.0	17.2	17.2	17.2	17.3	17.1	17.1
Meter (Tm)	20	20	21	22	24	25	25	26	22.9	22.9
Stack Temp (Ts)	18	18	18	18	18	18	18	18	18.0	18.0

Traverse Point	CP	CP	CP	CP	CP	CP	CP	CP	CP	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point (mins)	80 - 85	85 - 90	90 - 95	95 - 100	100 - 105	105 - 110	110 - 115	115 - 120		
ΔP (Pa)	11	11	11	11	11	11	11	11	11	11.0
Velocity at Stack (m/s)	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	17.3	17.4	17.4	17.4	17.5	17.5	17.5	17.5	17.4	17.4
Meter (Tm)	27	28	28	29	30	30	30	30	29.0	29.0
Stack Temp (Ts)	18	18	18	18	18	18	18	18	18.0	18.0

If moisture was not measured and gas was dried before entering the gas meter, impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.

Acetone SOL/	1994
DI Rinse SOL/	2000

Original Flowrate Settings	
Tm	30
Ts	18
%moisture	0.1

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

Environmental Compliance Limited		PARTICULATE DATA SAMPLING PROFORMA			Date of Measurement		14/11/2012		
ECL/TPD/	27a	Time taken to change Ports	0	Start Time	11:15	End Time	13:15	Duration (mins)	120
Client	Linx Printing	Stack Profile	Circular	Pitot ID	489	Stack Thermocouple ID	464	Impingers	n/a
Site	St Ives	Stack Area (m ²)	0.20	Manometer ID	506	Stack Temp Reader ID	414	SOL/	n/a
Location	Production	Barometric Pressure (mb)	1025	Barometer ID	352	Meter Thermocouple ID	367	Start Weight (g)	0.00
Stack ID	Main Vent	Stat Pres. (mmH ² 0) (Pa/9.81)	0.5	DGM Yd	1.0202	Meter Temp Reader ID	367	End Weight (g)	2.00
Test No.	TPM 2	Pitot coefficient	1	Nozzle ID	800	Dry Gas Meter ID	367	Total weight (g)	2.00
Job No	P1583	Balance ID	n/a	Nozzle Size (mm)	9.12	Timer ID	367		
ECL Site Staff	AB	Console ID	367	Filter ID	800	Rotameter ID	367		

	Sample	Leak 1	Leak 2	Leak 3	Leak 4
Start Volume	1271000.0				
Final Volume	1273085.0				
Total Volume	2085.0	0.0	0.0	0.0	0.0

Total	Volume (litres) @STP Dry
	Expected Sample Volume
	Actual Sample Volume
2085.0	Isokinetic Percentage

Leak Check	First	Second	Third	Final	Maximum allowed leak rate is 2% of the set rate	Measured O ₂	20.90	Moisture	0.13
Leak Rate l/min	0.1			0.1		Measured CO ₂ %		Ref O ₂	20.9
Set Rate (l/min)	20			20		Measured CO ppm		Dry Gas Molecular Weight	28.84
Time Of Leak Check	11:10			13:20					
Leak % of set rate	0.5			0.5					

Traverse Point	CP	CP	CP	CP	CP	CP	CP	CP	CP	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point (mins)	0 - 5	5 - 10	10 - 15	15 - 20	20 - 25	25 - 30	30 - 35	35 - 40		
ΔP (Pa)	11	11	11	11	11	11	11	11	11	11.0
Velocity at Stack (m/s)	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	17.3	17.4	17.5	17.5	17.6	17.6	17.6	17.6	17.6	17.5
Meter (Tm)	26	28	30	30	31	31	32	32	32	30.0
Stack Temp (Ts)	18	18	18	18	18	18	18	18	18	18.0

Traverse Point	CP	CP	Total							
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point (mins)	40 - 45	45 - 50	50 - 55	55 - 60	60 - 65	65 - 70	70 - 75	75 - 80		
ΔP (Pa)	11	11	11	11	11	11	11	11	11	11.0
Velocity at Stack (m/s)	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	17.6	17.6	17.6	17.7	17.7	17.7	17.7	17.7	17.7	17.7
Meter (Tm)	32	32	32	33	33	33	33	33	33	32.6
Stack Temp (Ts)	18	18	18	18	18	18	18	18	18	18.0

Traverse Point	CP	CP	CP	CP	CP	CP	CP	CP	CP	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point (mins)	80 - 85	85 - 90	90 - 95	95 - 100	100 - 105	105 - 110	110 - 115	115 - 120		
ΔP (Pa)	11	11	11	11	11	11	11	11	11	11.0
Velocity at Stack (m/s)	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7
Meter (Tm)	33	34	34	34	34	34	34	34	34	33.9
Stack Temp (Ts)	18	18	18	18	18	18	18	18	18	18.0

If moisture was not measured and gas was dried before entering the gas meter, impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.

Acetone SOL/	1994
DI Rinse SOL/	2000

Original Flowrate Settings	
Tm	30
Ts	18
%moisture	0.1

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

Environmental Compliance Limited		PARTICULATE DATA SAMPLING PROFORMA			Date of Measurement		14/11/2012		
ECL/TPD/	27a	Time taken to change Ports	0	Start Time	13:25	End Time	15:25	Duration (mins)	120
Client	Linx Printing	Stack Profile	Circular	Pitot ID	489	Stack Thermocouple ID	464	Impingers	n/a
Site	St Ives	Stack Area (m ²)	0.20	Manometer ID	506	Stack Temp Reader ID	414	SOL/	n/a
Location	Production	Barometric Pressure (mb)	1025	Barometer ID	352	Meter Thermocouple ID	367	Start Weight (g)	0.00
Stack ID	Main Vent	Stat Pres. (mmH ² O) (Pa/9.81)	0.5	DGM Yd	1.0202	Meter Temp Reader ID	367	End Weight (g)	2.00
Test No.	TPM 3	Pitot coefficient	1	Nozzle ID	800	Dry Gas Meter ID	367	Total weight (g)	2.00
Job No	P1583	Balance ID	n/a	Nozzle Size (mm)	9.12	Timer ID	367		
ECL Site Staff	AB	Console ID	367	Filter ID	794	Rotameter ID	367		

	Sample	Leak 1	Leak 2	Leak 3	Leak 4
Start Volume	1273100.0				
Final Volume	1275165.0				
Total Volume	2065.0	0.0	0.0	0.0	0.0

Total	Volume (litres) @STP Dry
	Expected Sample Volume
	Actual Sample Volume
2065.0	Isokinetic Percentage

Leak Check	First	Second	Third	Final	Maximum allowed leak rate is 2% of the set rate	Measured O ₂	20.90	Moisture	0.13
Leak Rate l/min	0.1			0.1		Measured CO ₂ %		Ref O ₂	20.9
Set Rate (l/min)	20			20		Measured CO ppm		Dry Gas Molecular Weight	28.84
Time Of Leak Check	13:22			15:30					
Leak % of set rate	0.5			0.5					

Traverse Point	CP	CP	CP	CP	CP	CP	CP	CP	CP	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point (mins)	0 - 5	5 - 10	10 - 15	15 - 20	20 - 25	25 - 30	30 - 35	35 - 40		
ΔP (Pa)	11	11	11	11	11	11	11	11	11	11.0
Velocity at Stack (m/s)	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	17.6	17.6	17.6	17.6	17.6	17.6	17.7	17.7	17.7	17.6
Meter (Tm)	31	31	31	32	32	32	33	33	33	31.9
Stack Temp (Ts)	18	18	18	18	18	18	18	18	18	18.0

Traverse Point	CP	CP	Total							
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point (mins)	40 - 45	45 - 50	50 - 55	55 - 60	60 - 65	65 - 70	70 - 75	75 - 80		
ΔP (Pa)	11	11	11	11	11	11	11	11	11	11.0
Velocity at Stack (m/s)	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7
Meter (Tm)	33	33	33	33	34	33	33	33	33	33.1
Stack Temp (Ts)	18	18	18	18	18	18	18	18	18	18.0

Traverse Point	CP	CP	CP	CP	CP	CP	CP	CP	CP	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point (mins)	80 - 85	85 - 90	90 - 95	95 - 100	100 - 105	105 - 110	110 - 115	115 - 120		
ΔP (Pa)	11	11	11	11	11	11	11	11	11	11.0
Velocity at Stack (m/s)	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	4.24	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7	17.7
Meter (Tm)	33	34	34	34	34	34	34	34	34	33.9
Stack Temp (Ts)	18	18	18	18	18	18	18	18	18	18.0

If moisture was not measured and gas was dried before entering the gas meter, impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.

Acetone SOL/	1994
DI Rinse SOL/	2000

Original Flowrate Settings	
Tm	30
Ts	18
%moisture	0.1

Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

LABORATORY ANALYSIS RESULTS

Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012



Scientific Analysis Laboratories is a limited company registered in England and Wales (No 2514788) whose address is at Hadfield House, Hadfield Street, Manchester M16 9FE

Scientific Analysis Laboratories Ltd
Certificate of Analysis

Hadfield House
Hadfield Street
Cornbrook
Manchester
M16 9FE
Tel : 0161 874 2400
Fax : 0161 874 2404

Report Number: Supplement to 304813-1

Date of Report: 27-Nov-2012

Customer: Environmental Compliance Ltd
Unit G1
Main Avenue
Treforest Industrial Estate
Pontypridd
CF37 5YL.

Customer Contact: Mr Andrew Barnes

Customer Job Reference: P1583

Customer Purchase Order: E0815

Date Job Received at SAL: 20-Nov-2012

Date Analysis Started: 21-Nov-2012

Date Analysis Completed: 23-Nov-2012

The results reported relate to samples received in the laboratory
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation
This report should not be reproduced except in full without the written approval of the laboratory
Tests covered by this certificate were conducted in accordance with SAL SOPs
All results have been reviewed in accordance with QP22



Report checked and authorised by :
Jennifer Wraith
Sales Support Manager

Issued by :
Kayleigh McCann
Project Manager

Validity unknown
Digitally signed by Kayleigh McCann
Date: 2012.11.27 10:47:10 GMT
Reason: ISSUED
Location: SAL

Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

SAL Reference: 304813 Customer Reference: P1583										
Filter Quartz 37mm Analysed as Filter Quartz 37mm Miscellaneous										
SAL Reference					304813 001	304813 003	304813 005	304813 007		
Customer Sample Reference					ECL/12/6448	ECL/12/6450	ECL/12/6452	ECL/12/6454		
Test Sample					AR	AR	AR	AR		
Determinand	Method	LOD	Units	Symbol						
Particulates (Total)	Grav (5 Dec)	0.05	mg	U	12	<0.05	1.0	0.91		

SAL Reference: 304813 Customer Reference: P1583										
Wash(Acetone) Analysed as Wash(Acetone) Miscellaneous										
SAL Reference					304813 002	304813 004	304813 006	304813 008		
Customer Sample Reference					ECL/12/6449	ECL/12/6451	ECL/12/6453	ECL/12/6455		
Test Sample					AR	AR	AR	AR		
Determinand	Method	LOD	Units	Symbol						
Particulates (Total)	Grav	0.1	mg	U	<0.1	<0.1	<0.1	<0.1		

Index to symbols used in Supplement to 304813-1

Value	Description
AR	As Received
U	Analysis is UKAS accredited

Notes

Supplement issued to amend the customer reference as requested by the customer.

Environmental Compliance Limited

Linx Printing Technologies Ltd
Permit No : PG6/44(04)
Variation No : 2004
Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
Visit Details : Annual Compliance 2012
Survey Dates : 14th November 2012
Report Issue Date : 28th November 2012

UNCERTAINTY CALCULATIONS

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

TOC Measurement Uncertainty

Signal 3030 FID Performance Characteristics	Standard Uncertainty	Distribution	Minimum Certified Range (R _i) *TOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular (Divisor = $\sqrt{3}$)	0.40
Span drift ⁽²⁾	$u_{d,s}$	Rectangular (Divisor = $\sqrt{3}$)	0.35
Repeatability Standard Deviation (span)	u_r	Normal (Divisor = 1)	7.56
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}	Rectangular (Divisor = $\sqrt{3}$)	0.01
Temperature dependant span drift ⁽⁵⁾	u_t	Rectangular (Divisor = $\sqrt{3}$)	0.30
Interferents ⁽¹⁾	u_i	Rectangular (Divisor = $\sqrt{3}$)	4.39
Uncertainty of Reference Gas ⁽⁶⁾	u_{ref}	Rectangular (Divisor = $\sqrt{3}$)	2.89
Effect of Voltage Fluctuation ⁽⁷⁾	u_v	Rectangular (Divisor = $\sqrt{3}$)	1.80
Effect of Oxygen Synergism ⁽⁷⁾	u_{syn}	Rectangular (Divisor = $\sqrt{3}$)	4.60

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- 1 Expressed as a percentage of the analyser range
- 2 Expressed as maximum drift per 24hr period
- 3 Expressed in units of final measurement, dry gas
- 4 Expressed as a percentage of the final measured value
- 5 Per one degree centigrade
- 6 Expressed as standard uncertainty in units of measurement i.e. mg/m³ / %Vol
- 7 Applies to TOC analyser (*Signal 3030 FID) only

Signal 3030 FID Performance Characteristics	Uncertainty	Value of Standard Uncertainty	*TOC 0 - 45 mgC/m ³
Lack of fit	u_{lof}	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.03
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.031
Repeatability Standard Deviation (span)	u_r	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	7.56
Losses / leakage in the sample system	u_{loss}	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	0.01
Temperature dependant span drift	u_t	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{adj})^2 + (x_{i,min} - x_{adj})(x_{i,max} - x_{adj}) + (x_{i,min} - x_{adj})^2}{3}} =$	0.137
Interferents	u_i	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.38
Uncertainty of Reference Gas	u_{ref}	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	1.67
Effect of Voltage Fluctuation (See Note 7)	u_v	$u(x_i) = \frac{u_v \times R_i}{\sqrt{3}} =$	0.16
Effect of Oxygen Synergism (See Note 7)	u_{syn}	$u(x_i) = \frac{u_{syn} \times R_i}{\sqrt{3}} =$	0.40
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	7.77
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	15.53
Applied Span Concentration			321.27
Measured Span Concentration, STP Dry Gas			325.96
Expanded measurement uncertainty as % of Applied Span			4.8%

* Signal 3030 FID

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583 : R001

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

TOC Uncertainty of Measurements

Uncertainty Calculations Part 1

Signal 3030 FID Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Im Certified Rat
				TOC 0 - 15 mgC/m ³
Lack of fit ⁽¹⁾	u_{lof}	Rectangular	$\sqrt{3}$	4.00E-01
Span drift ⁽²⁾	u_{ds}			3.54E-01
Losses / leakage in the sample system ⁽⁴⁾	u_{loss}			6.32E-03
Temperature dependant span drift ⁽⁵⁾	u_t			3.00E-01
Effect of Voltage Fluctuation ⁽⁷⁾	u_v			1.80E+00

Notes:

For rectangular distributions, $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,avg})^2 + (x_{i,min} - x_{i,avg})^2 + (x_{i,max} - x_{i,min})^2}{3}}$, when $|x_{i,max} - x_{i,avg}| = |x_{i,min} - x_{i,avg}|$, then $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where $u(x_i) = \frac{\sigma}{\sqrt{n}}$ (See note 6 below), $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Signal 3030 FID Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	TOC 0 - 15 mgC/m ³
Lack of fit	u_{lof}	Rectangular	$\sqrt{3}$	3.46E-02
Span drift	u_{ds}			3.07E-02
Temperature dependant span drift	u_t			1.37E-01
Interferents	u_i			3.80E-01
Effect of Voltage Fluctuation (See Note)	u_v			1.56E-01

Uncertainty Calculations Part 2

Signal 3030 FID Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	TOC 0 - 15 mgC/m ³
Losses / leakage in the sample system	u_{loss}	14/11/12 08:05 - 16:04	8.73E-03
Standard Error of Measured Value	u_{SE}	14/11/12 08:05 - 16:04	7.40E+00

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

Uncertainty Calculations Part 3

Signal 3030 FID Uncertainty	Date & Time	TOC 0 - 15 mgC/m ³
Measured Concentration	14/11/12 08:05 - 16:04	138.06
Expanded Uncertainty as Percentage of Measured Concentration		10.7%

Combined Standard Uncertainty $u_c = \sqrt{u_{lof}^2 + u_{ds}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{vdf}^2 + u_v^2 + u_{sym}^2}$

Expanded uncertainty (at 95% confidence) $U_{95\%} = 2 \times u_c$

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

Site: Linx Printing, St Ives
 Location: Production , Stack ID: Main Vent

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Uncertainty mg
				Filter mg	Solution mg	Filter mg	Solution mg	
TPM 1								
Particulates	12.00	0.10	12.10	0.14	0.27	0.0700	0.14	0.15

	TPM 1		Standard Uncertainty @ 95%	
	Value	Unit	uV _m	m ²
Sampled Volume (V _m)	2.17	m ³	0.001	m ²
Meter Correction Factor (Y _d)	1.02
Meter Temperature (T _m)	294.90	k	uT _m 1.5	k
Static Pressure of Stack P _{static}	0.50	mmH ₂ O	uP _{static} 0.25	mmH ₂ O
Absolute Stack Pressure p _s	768.81	mmHg	uP _s 0.8	mmHg
Barometric Pressure p _b	769.00	mmHg	uP _b 3.8	mmHg
Average Differential Pressure (ΔH)	102.65	mmH ₂ O	uΔH 0.25	mmH ₂ O
Oxygen content (O _{2,m})	20.90	%by volume	uO _{2,m} = σ/√n 0.00	%by volume
Moisture Content (H ₂ O)	0.12	%by volume	uH ₂ O 0.07	%by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP _b), measured static pressure uncertainty component (uP _{static}) & measured temperature of dry gas					Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV _{std}) & volume uncertainty component (uV _m)				
$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.966$					$V_{std} = V_{measured} \times f_s = 2.0917$				
	Maximum	Minimum	Sensitivity	u _{f_s}		Maximum	Minimum	Sensitivity	Standard Uncertainty (m ²)
uΔH	0.50	0.50	0.0000475	0.0000119	Effect of uP _s	2.10	2.09	2.16	0.00567
uP _b	0.50	0.50	0.000646	0.00242	Effect of uV _m	2.09	2.09	0.97	0.000966
uT _m	0.50	0.50	0.000883	0.00133					
H ₂ O	0.50	0.50	0.00502	0.000370					
$\frac{u_{f_s}}{f_s} = \sqrt{\left(\frac{u(\Delta H)}{P_m/101.3}\right)^2 + \left(\frac{uT_m}{T_m/273.15}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.00262$					$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0123$				

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO ₂) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)					Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO ₂) and STP volume uncertainty component (uV _{stp})				
$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$					$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 5.78$				
	Maximum	Minimum	Sensitivity	Standard Uncertainty		Maximum	Minimum	Sensitivity	u
uO ₂	uM	5.86	5.71	0.48	0.0727
					uO ₂
					uV _{stp}	5.82	5.75	2.77	0.0341
$uL = \frac{Conc \times \frac{2}{100}}{\sqrt{3}} = 0.0668$									

Combined Uncertainty

$$u_{combined} = \sqrt{(u_M)^2 + (u_L)^2 + (u_{O_2})^2 + (u_{V_{stp}})^2}$$

Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured Concentration
mg/Nm ³	mg/Nm ³	mg/Nm ³	Concentration
0.10	0.21	5.78	3.6%

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

Site: Linx Printing, St Ives
 Location: Production , Stack ID: Main Vent

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Uncertainty mg
				Filter mg	Solution mg	Filter mg	Solution mg	
TPM 2								
Particulates	1.00	0.10	1.10	0.14	0.27	0.0700	0.14	0.15

	TPM 2		Standard Uncertainty @ 95%	
			uV _m	m ³
Sampled Volume (V _m)	2.09	m ³	0.001	m ³
Meter Correction Factor (Y _d)	1.02
Meter Temperature (T _m)	305.32	k	uT _m	1.5 k
Static Pressure of Stack P _{static}	0.50	mmH ₂ O	uP _{static}	0.25 mmH ₂ O
Absolute Stack Pressure p _s	768.81	mmHg	uP _s	0.8 mmHg
Barometric Pressure p _b	769.00	mmHg	uP _b	3.8 mmHg
Average Differential Pressure (ΔH)	100.09	mmH ₂ O	uΔH	0.25 mmH ₂ O
Oxygen content (O _{2,m})	20.90	%by volume	uO _{2,m} = σ/√n	0.00 %by volume
Moisture Content (H ₂ O)	0.13	%by volume	uH ₂ O	0.08 %by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP _b), measured static pressure uncertainty component (uP _{static}) & measured temperature of dry gas					Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV _{std}) & volume uncertainty component (uV _m)				
$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.933$					$V_{std} = V_{measured} \times f_s = 1.9454$				
	Maximum	Minimum	Sensitivity	u _{f_s}		Maximum	Minimum	Sensitivity	Standard Uncertainty (m ³)
uΔH	0.49	0.49	0.0000467	0.0000117	Effect of u _{f_s}	1.95	1.94	2.08	0.00524
uP _b	0.49	0.49	0.000634	0.00238	Effect of uV _m	1.95	1.94	0.93	0.000933
uT _m	0.49	0.49	0.000852	0.00128					
H ₂ O	0.49	0.49	0.00493	0.000390					
$\frac{u_{f_s}}{f_s} = \sqrt{\left(\frac{u(\Delta H)}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{(100/(100-H_2O))}\right)^2} = 0.00251$					$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0110$				

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (u _{f_{O₂}}) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (u _L)					Uncertainty in final measurement @ reference conditions due to mass uncertainty component (u _M), oxygen correction uncertainty component (u _{f_{O₂}}) and STP volume uncertainty component (u _{V_{stp}})				
$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$					$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 0.57$				
	Maximum	Minimum	Sensitivity	Standard Uncertainty		Maximum	Minimum	Sensitivity	u
u _{f_{O₂}}	u _M	0.64	0.49	0.51	0.0782
					u _{O₂}
					u _{V_{stp}}	0.57	0.56	0.29	0.00319
$u_L = \frac{Conc \times \frac{2}{100}}{\sqrt{3}} = \text{mg/Nm}^3 = 0.00653$									

Combined Uncertainty

$$u_{combined} = \sqrt{\sum (u_M)^2 + (u_L)^2 + (u_{f_{O_2}})^2 + (u_{V_{stp}})^2}$$

Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured
mg/Nm ³	mg/Nm ³	mg/Nm ³	Concentration
0.08	0.16	0.57	27.8%

Environmental Compliance Limited

Linx Printing Technologies Ltd
 Permit No : PG6/44(04)
 Variation No : 2004
 Report Ref : P1583

Installation Name : Manufacturing Main Vent
 Visit Details : Annual Compliance 2012
 Survey Dates : 14th November 2012
 Report Issue Date : 28th November 2012

Site: Linx Printing, St Ives
 Location: Production , Stack ID: Main Vent

$$u_{mass} = \sqrt{\sum (u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Uncertainty mg
				Filter mg	Solution mg	Filter mg	Solution mg	
TPM 3								
Particulates	0.91	0.10	1.01	0.14	0.27	0.0700	0.14	0.15

Parameter	Value	Units	Standard Uncertainty @ 95%		
			uV _m	uP _{static}	uΔH
Sampled Volume (V _m)	2.07	m ³	0.001	0.001	m ³
Meter Correction Factor (Y _d)	1.02
Meter Temperature (T _m)	306.11	k	uT _m	1.5	k
Static Pressure of Stack (P _{static})	0.50	mmH ₂ O	uP _{static}	0.25	mmH ₂ O
Absolute Stack Pressure (p _s)	768.81	mmHg	uP _s	0.8	mmHg
Barometric Pressure (p _b)	769.00	mmHg	uP _b	3.8	mmHg
Average Differential Pressure (ΔH)	102.65	mmH ₂ O	uΔH	0.25	mmH ₂ O
Oxygen content (O _{2,m})	20.90	%by volume	uO _{2,m} = σ/√n	0.00	%by volume
Moisture Content (H ₂ O)	0.13	%by volume	uH ₂ O	0.08	%by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using: $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C_iu_i where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV_m, uT_m etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP _b), measured static pressure uncertainty component (uP _{static}) & measured temperature of dry gas					Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV _{std}) & volume uncertainty component (uV _m)				
$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.931$					$V_{std} = V_{measured} \times f_s = 1.9223$				
	Maximum	Minimum	Sensitivity	u _{f_s}		Maximum	Minimum	Sensitivity	Standard Uncertainty (m ³)
uΔH	0.49	0.49	0.0000466	0.0000116	Effect of u _{f_s}	1.93	1.92	2.07	0.00507
uP _b	0.49	0.49	0.000634	0.00238	Effect of uV _m	1.92	1.92	0.93	0.000931
uT _m	0.49	0.49	0.000850	0.00127					
H ₂ O	0.49	0.49	0.00493	0.000395					
$\frac{u_{f_s}}{f_s} = \sqrt{\left(\frac{u(\Delta H)}{P_m/101.3}\right)^2 + \left(\frac{uT_m}{T_m/273.15}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.00245$					$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.0105$				

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (u _{f_{O₂}}) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (u _L)					Uncertainty in final measurement @ reference conditions due to mass uncertainty component (u _M), oxygen correction uncertainty component (u _{f_{O₂}}) and STP volume uncertainty component (u _{V_{stp}})				
$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$					$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 0.53$				
	Maximum	Minimum	Sensitivity	Standard Uncertainty		Maximum	Minimum	Sensitivity	u
u _{f_{O₂}}	u _M	0.60	0.45	0.52	0.0791
					u _{f_{O₂}}
					u _{V_{stp}}	0.53	0.52	0.27	0.00287
$u_L = \frac{Conc \times \frac{2}{100}}{\sqrt{3}} = \text{mg/Nm}^3 = 0.00607$									

Combined Uncertainty

$$u_{combined} = \sqrt{(u_M)^2 + (u_L)^2 + (u_{f_{O_2}})^2 + (u_{V_{stp}})^2}$$

Combined Uncertainty	Expanded Uncertainty	Measured Concentration	Percent of Measured
mg/Nm ³	mg/Nm ³	mg/Nm ³	Concentration
0.08	0.16	0.53	30.2%