

# EMISSIONS MONITORING SURVEY

Prepared for:

**Linx Printing Technologies Ltd.**  
**Burrell Road**  
**St Ives**  
**Huntingdon**  
**Cambridgeshire**  
**PE27 3LA**

<b>Permit Number</b>	: PG6/44(04)
<b>Variation Number</b>	: 2004
<b>Installation</b>	: Manufacturing Main Vent
<b>Visit Details</b>	: Annual Compliance – 2013
<b>Job Number</b>	: P1869
<b>Report Number</b>	: R001
<b>Report Issue Date</b>	: 15 <sup>th</sup> November 2013
<b>Survey Dates</b>	: 5 <sup>th</sup> November 2013

Prepared by:

**Environmental Compliance Limited**  
 Unit G1  
 Main Avenue  
 Treforest Industrial Estate  
 Pontypridd  
 CF37 5BF.

Tel: 01443 841760  
 Fax: 01443 841761

<b>Report Issue:</b>		<b>FINAL</b>	
<b>Report Prepared by:</b>		<b>Report Reviewed &amp; Approved by</b> MCERTS Level Two Technical Endorsements TE1, TE2, TE3 & TE4	
<b>Name:</b>	Jon Litterick	<b>Name:</b>	Andy Barnes
		<b>MCERTS No:</b>	MM 03 235
		<b>Signature:</b>	
<b>Date:</b>	14/11/13	<b>Date:</b>	15/11/13

This report is not to be used for contractual or engineering purposes unless this approval sheet is signed where indicated by the approver and the report is designated "FINAL".



## Environmental Compliance Limited

Linx Printing Technologies Ltd  
Permit No : PG6/44(04)  
Variation No : 2004  
Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
Visit Details : Annual Compliance – 2013  
Survey Dates : 5th November 2013  
Report Issue Date. : 15th November 2013

This report has been prepared by Environmental Compliance Limited (ECL) in their professional capacity as Environmental Consultants. The contents of the report reflect the conditions that prevailed and the information available or supplied at the time of its preparation. The report, and the information contained therein, is provided by ECL solely for use and reliance by the Client in performance of ECLs duties and liabilities under its contract with the Client. Until ECL has received payment in full as detailed in the quotation or contract the contents of this report remain the legal property of ECL. The contents of the report do not, in any way, purport to include any manner of legal advice or opinion.

Should the Client wish to release this report to a Third Party for the party's reliance, Environmental Compliance Ltd may, at its discretion, agree to such release provided that:

- Environmental Compliance Ltd gives written agreement prior to such release and ECL has received payment in full for all works/services undertaken;
- By release of the report to the Third Party, that Third Party does not acquire any rights, contractual or otherwise, whatsoever against Environmental Compliance Ltd and, accordingly, Environmental Compliance Ltd assume no duties, liabilities or obligations to that Third Party;
- Environmental Compliance Ltd accepts no responsibility for any loss or damage incurred by the Client or for any conflict of Environmental Compliance Ltd interests arising out of the Clients' release of this report to the Third Party.

In the event that a report is revised and re-issued, the client shall ensure that any earlier versions of the report, and any copies thereof, are void and such copies should be marked with the words "superseded and revised".

Opinions and Interpretation expressed within this report are outside the scope of the UKAS accreditation.

**MCERTS requirements mean that comparison of results with emissions limit values is not permitted within this report.**

## TABLE OF CONTENTS

Section	Description	Page Number
	<b>Document Control Sheet</b>	
<b>PART 1</b>	<b>EXECUTIVE SUMMARY</b>	<b>4</b>
<b>1</b>	<b>MONITORING OBJECTIVES</b>	<b>4</b>
<b>1.1</b>	<b>Monitoring Results</b>	<b>5</b>
<b>1.2</b>	<b>Operating Information</b>	<b>6</b>
<b>2</b>	<b>MONITORING DEVIATIONS</b>	<b>7</b>
<b>PART 2</b>	<b>SUPPORTING INFORMATION</b>	<b>8</b>
<b>3</b>	<b>SAMPLING STAFF DETAILS</b>	<b>8</b>
<b>4</b>	<b>SAMPLING PROTOCOLS / METHODOLOGIES</b>	<b>9</b>
<b>5</b>	<b>SAMPLE POINT DESCRIPTIONS</b>	<b>11</b>
	<b>EQUIPMENT IDs</b>	<b>12</b>
	<b>FIGURES</b>	<b>14</b>
	<b>TABLES</b>	<b>16</b>
	<b>VELOCITY TRAVERSE PROFILES</b>	<b>20</b>
	<b>FIELD CALIBRATION AND SAMPLING DATA</b>	<b>22</b>
	<b>LABORATORY ANALYSIS RESULTS</b>	<b>27</b>
	<b>UNCERTAINTY CALCULATIONS</b>	<b>30</b>

## PART 1 - EXECUTIVE SUMMARY

### 1 Monitoring Objectives

Environmental Compliance Ltd (ECL) was commissioned by **Linx Printing Technologies Ltd** to undertake an emission monitoring survey at their **Ink Manufacturing site in St Ives**. This report presents the findings of the study.

The monitoring at this installation was carried out in accordance with our quotation reference **PC/P1869/Q001**, for compliance check monitoring of emissions to air. The substances requested for monitoring at each emissions point are listed below:

Substances to be monitored	Emission Point Identification
	Ink Manufacture – Main Vent
Particulates	• U
Total Organic Carbon (TVOC)	• U

- Denotes the substances to be monitored.
- U Denotes **UKAS accreditation is held for monitoring that substance, but does not mean that it has been claimed which will depend on whether the testing could be completed in accordance with the Standard Reference Method.**

Special Requirements: *“Test TVOC for full 8 hours”*

**Environmental Compliance Limited**

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

## 1.1 Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty %	Reference Conditions 273 K, 101.3 kPa	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Tick if non-conforming test (see Sections 2 & 5)	Operating Status
Ink Manufacture – Main Vent	Particulates \$	20	0.64	mg/m <sup>3</sup>	27	& Wet Gas	05/11/13	08:05 – 10:05	BS EN 13284-1	UKAS / MCERTS	✓	Normal
	Particulates \$	20	0.20	mg/m <sup>3</sup>	100	& Wet Gas	05/11/13	10:30 – 12:30	BS EN 13284-1	UKAS / MCERTS	✓	
	TVOC as Carbon	150	84.24	mg/m <sup>3</sup>	2	& Wet Gas	05/11/13	08:02 – 16:02	BS EN 12619:2013	UKAS / MCERTS		

### Notes

The uncertainty figure presented in Table 1.1 for TVOC is the “measurement uncertainty” figure, which does not take into account the variability of the measured sample values. The “uncertainty of measurement results” figure, which does include this contribution, is also presented in the appendices of the report.

### Notes

Emission Limit Value	The emission limit value is that stated in the permit and will be expressed as a concentration or a mass emission.
Periodic Monitoring Result	The result given is expressed in the same terms and units as the emission limit value.
Uncertainty	The uncertainty associated with the quoted result is at the 95% confidence interval. The Uncertainty results <b>DO NOT</b> take into account the effect of the sample location limitations.
Reference Conditions	All results are expressed at 273 K and 101.3kPa. The oxygen and moisture corrections are stated.
Monitoring Method Reference	The method stated is in accordance with the Environment Agency Technical Guidance Note M2, or other method approved by the Environment Agency.
<b>Accreditation for use of Method</b>	<b>The details indicate the accreditation for the use of the complete monitoring method, e.g. MCERTs, UKAS. If use of the method is not accredited " NA" is stated.</b>
Operating Status	The details indicate the feedstock and the loading rate of the plant during monitoring.
\$	Chemical Analysis on sample reagents was performed by an External Laboratory as detailed in Section 4
NU	UKAS Accreditation Held but UKAS Accreditation cannot be claimed for the test as sampling did not comply with the Standard Reference Method (SRM), see section 2 & 5
<b>NA</b>	<b>Method is NOT UKAS Accredited.</b>

**Environmental Compliance Limited**

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

## 1.2 Operating Information

Emission Point Reference	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results					
							Parameter	Date	Time	CEMS Results	Periodic Monitoring Results	Units
Main Vent	Batch	08:00 – 16:30	n/a	n/a	None	Normal	...	...	...	n/a	...	...

**Notes:**

Process Type	State whether the process is a continuous or batch process.
Process Duration	If a batch process, state the duration, frequency and details of the portion of the batch sampled. If continuous state "NA"
Fuel	If applicable, state the fuel type If not applicable state "NA"
Feedstock	State the feedstock type
Abatement	State the type and whether operational during monitoring. If not applicable state "NA"
Load	State the normal load, throughput or rating of the plant
CEMS Data	Enter this data for each CEM installed if it is has been provided by operator otherwise state "NP" (NOT PROVIDED)

Linx Printing Technologies Ltd  
Permit No : PG6/44(04)  
Variation No : 2004  
Report Ref : P1869

: R001

Installation Name : Manufacturing Main Vent  
Visit Details : Annual Compliance – 2013  
Survey Dates : 5th November 2013  
Report Issue Date. : 15th November 2013

---

## 2 Monitoring Deviations

---

The objective of the survey was to measure the concentrations of pollutants from the processes / locations as detailed in Section 1. This survey meets the requirements of the site's **PPC Permit Number: PG6/44(04)** where UKAS and MCERTS accreditation has and could be claimed for the testing in the monitoring results table.

**There were no modifications** to the sampling procedures (TPDs) listed in section 4.

**There were no substance deviations** from the original and agreed emissions monitoring schedule.

**Non-conforming tests** are as follows:-

Particulate samples were made from centre point only, whereas BS EN 13284 stipulates 5 sample points for a duct with this diameter (500mm). This deviation was made for safety reasons, as there are no internally threaded sample ports available so securing the probe at all the sample points was not possible. **This non-conformity does not alter the accreditation status of the tests.**

**The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.**

**Homogeneity tests** have/ have not been completed and are not applicable to this location as the duct area is <1m<sup>2</sup>.

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869

: R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

## PART 2 – SUPPORTING INFORMATION

### 3 SAMPLING STAFF DETAILS

#### Site Sampling Team

Names of Site Team	Dates on Site	MCERTS No.	LEVEL	Technical Endorsements
Andy Barnes	05/11/13	MM 03 235	2	TE1, TE2, TE3, TE4

#### Report Reviewer

Name	MCERTS No.	LEVEL	Technical Endorsements
Andy Barnes	MM 03 235	2	TE1, TE2, TE3, TE4

#### Technical Endorsement Key:-

- TE1** – **Isokinetic** Particulates, Temperature & Velocity Profiles, Oxygen.  
**TE2** – **Isokinetic** Extractive Pollutants:- Metals, Dioxin & Furans, PAHs, PCBs, HCl, HF.  
**TE3** – **Non-Isokinetic** Extractive Pollutants:- Speciated VOCs, HF, HCl, Cyanide.  
**TE4** – **Continuous Analysers** (Combustion Gases):- TVOC, CO, NOx, SO2.

---

## 4 SAMPLING PROTOCOLS / METHODOLOGIES

---

**Any required modifications to the Technical Procedure Documents (TPDs) specified below will be detailed in section 2 of this report.**

---

### TVOC as Carbon

---

Testing was carried out using an MCERTS Certified Signal 3030PM FID and heated gas sample line, with reference to the manufacturer's operation handbook, **BS EN 12619:2013** and in-house technical procedure **ECL/TPD/032**.

The analyser was calibrated on site using certified propane span gases, (made up in synthetic air) which are traceable to ISO 17025 standard. (with uncertainty <2%).

Zero measurements were performed using synthetic air zero gas, with TVOC content less than 0.2 mg/m<sup>3</sup> (or purity greater than 99.998%).

The analyser was calibrated directly into the sample inlet and then checked through the entire sampling system (including sampling probe, heated filter and heated gas transport lines). Data was corrected by molecular weight to TVOCs as total carbon.

Data was recorded as minute averages over each test period. The data is presented in the Figures Section and the minute averaged data is detailed in the Tables Section.

---

### Pressure, Temperature and Velocity

---

Testing was carried out using a sampling system in accordance with **BS EN 13284-1 & MID** and In-house technical procedure **ECL/TPD/022**.

Temperature was recorded using a thermocouple and digital temperature reader.

Velocity and pressure were recorded using an "L" type pitot and digital manometer, data being recorded in Pascals.

Linx Printing Technologies Ltd  
Permit No : PG6/44(04)  
Variation No : 2004  
Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
Visit Details : Annual Compliance – 2013  
Survey Dates : 5th November 2013  
Report Issue Date. : 15th November 2013

---

## Particulates

---

Testing was carried out using a Manual Stack Sampling system in accordance with **BS EN 13284-1 & MID** and In-house technical procedure **ECL/TPD/027A**

Isokinetic particulate sampling is achieved when the velocity of gas entering the sampling nozzle is exactly equal to the velocity of the approaching gas stream within the stack.

A measured volume of sample gas is withdrawn from the stack isokinetically through a sampling nozzle and through 37mm pre-weighed and pre-blown GFA filter positioned in an unheated housing inserted into the stack.

Particulate matter is collected on the filter. Following testing the front half of the filter housing, probe (out-stack sampling only) and the sample nozzle are rinsed to remove any particulate matter which, may have impacted on the surfaces during testing. The dry residue of the Acetone used for rinses is <5mg/l. The filters and rinses are subsequently analysed to determine the amount of particulate matter captured.

The standard pre-sample conditioning temperature of the filters is 180°C and the standard post-sample conditioning temperature is 160°C. (Any modifications to this are noted in section 2 of this report). Apparent weights are corrected, if required, based on the weights of three control filters and evaporating basins which are weighed (pre and post sampling) with each batch of filters & rinses.

**Scientific Analysis Laboratories Ltd (SAL)** who are situated in Manchester carried out the analysis of the samples. **SAL** are UKAS accredited for this analysis. In addition to the survey samples, appropriate field blanks are submitted as part of the technical procedure.

Linx Printing Technologies Ltd  
Permit No : PG6/44(04)  
Variation No : 2004  
Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
Visit Details : Annual Compliance – 2013  
Survey Dates : 5th November 2013  
Report Issue Date. : 15th November 2013

---

## 5 SAMPLE POINT DESCRIPTIONS

---

The homogeneity test is applicable to combustion processes. This includes but is not restricted to, those regulated under the Waste Incineration Directive (**WID**) and the Large Combustion Plant Directive (**LCPD**).

Homogeneity testing has not been completed at this location. The test is not usually required for stacks with sampling plane areas of <math><1\text{m}^2</math> (below 1.13m in diameter for circular ducts).

---

The sample location that was monitored is detailed below:-

---

### **Ink Manufacture – Main Vent**

---

The sampling plane is in long straight vertical section of the emissions stack.

The diameter at the sample plane is 0.5m.

The flow characteristics meet the **requirements** of the standard.

2 x 2" ports are available and are located as per the requirements of BS EN 13284.

The equipment is set up at ground level, with probes raised to the sample plane (<math><5\text{m}</math>) via temporary access.

**Samples for Particulates are non-conforming tests, due to the fact that not all the designated sample points on the sample plane could be used. Whilst it was possible to safely reach both ports for the purposes of the pitot traverse, there was no safe way to support the probe in Port B for particulate sampling, and in port A, the probe was fixed at a single (centre) point in the duct. This non-conformity does not alter the accreditation status of the tests.**

**The Uncertainty of the reported concentrations for these pollutant results DOES NOT take into account the effect of these non-conformities or sample location limitations.**

**Environmental Compliance Limited**

**Linx Printing Technologies Ltd**  
**Permit No** : PG6/44(04)  
**Variation No** : 2004  
**Report Ref** : P1869 : R001

**Installation Name** : Manufacturing Main Vent  
**Visit Details** : Annual Compliance – 2013  
**Survey Dates** : 5th November 2013  
**Report Issue Date.** : 15th November 2013

**EQUIPMENT IDs**  
**(Pre site checklist from SSP)**

Environmental Compliance Limited

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

## PRE SITE EQUIPMENT CHECKLIST/ EQUIPMENT USED

(Completed before departure to site and when on site in full)

Equipment	Equip. Type	ID No:							
MST console/pump	E001								
MST Nozzle set									
MST "S" Type Pitot									
MST Probe									
MST Hot Box									
MST Impinger Arm									
Barometer		629							
Site Balance									
Site Check weights									
Horiba		E002							
Heated Probe / Filter									
Chiller									
Sonimix									
Heated Line									
FID	E003	304							
Heated Line		354	355						
Heated Probe / Filter		806							
Testo	E004								
FTIR	E005								
Heated Probe / Filter									
Heated Line									
Stackmite	E006	366							
"L" Type Pitot		487							
Digital Manometer		506							
Stack Thermocouple		464							
Thermocouple Reader		414							
Nozzle Set		801							
Workhorse Pumps	E007								
Low Flow Pumps									

Quantity of Ice Required / Used for Survey	ZERO	Bags (2kg bags)
--	------	-----------------

**Environmental Compliance Limited**


**Linx Printing Technologies Ltd**  
**Permit No** : PG6/44(04)  
**Variation No** : 2004  
**Report Ref** : P1869 : R001

**Installation Name** : Manufacturing Main Vent  
**Visit Details** : Annual Compliance – 2013  
**Survey Dates** : 5th November 2013  
**Report Issue Date.** : 15th November 2013

## **FIGURES**

# Figure 1

TVOC Data Recorded From Linx Printing, Main Vent - Manufacturing,  
on 05/11/2013, Between 08:02 and 16:02.  
Reference Conditions 273K, 101.3kPa & Wet Gas.



**Environmental Compliance Limited**

**Linx Printing Technologies Ltd**  
**Permit No** : PG6/44(04)  
**Variation No** : 2004  
**Report Ref** : P1869 : R001

**Installation Name** : Manufacturing Main Vent  
**Visit Details** : Annual Compliance – 2013  
**Survey Dates** : 5th November 2013  
**Report Issue Date.** : 15th November 2013

**TABLES**

Environmental Compliance Limited

Linx Printing Technologies Ltd  
Permit No : PG6/44(04)  
Variation No : 2004  
Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
Visit Details : Annual Compliance – 2013  
Survey Dates : 5th November 2013  
Report Issue Date. : 15th November 2013

### Table 1

#### TOC Data Recorded from Manufacturing - Main Vent

Sample Period: 08:02 – 16:02 on the 5<sup>th</sup> November 2013

Volumetric Flowrate (Reference Conditions) = 0.84 m<sup>3</sup>/sec \*

	Average	Emission Rate
	mg/m <sup>3</sup>	Kg/hr
TVOCs (as carbon)*	84.24	0.255

\* Reference Conditions (273K, 101.3 kPa & Wet Gas)

**Table 2 – Particulates**  
**Data Recorded from Manufacturing - Main Vent**

Emission Parameter	Units	TPM 1	Blank
Stack Diameter	metres	0.50	...
			...
Area of Sample Plane	m <sup>2</sup>	0.196	...
Moisture Content	%	0.10	...
Oxygen Content	%	20.90	...
Stack Temperature	°C	19	...
Gas Velocity (at Stack Conditions)	m/sec	4.70	...
Gas Velocity (Reference Conditions)	m/sec*	4.29	...
Volumetric Flowrate (Stack Conditions)	m <sup>3</sup> /sec	0.92	...
Volumetric Flowrate (Reference Conditions)	m <sup>3</sup> /sec*	0.84	...
Sample Date	...	05/11/2013	...
Sample Period	...	08:05 - 10:05	...
Sample Volume (at Stack)	m <sup>3</sup>	1.91	...
Sample Volume (reference Conditions)	m <sup>3</sup> *	1.74	1.74
Isokinetic Sampling Rate	%	108.4	...
Sample Reference (ECL ID)	ECL/13/	5478 & 5479	5482 & 5483
Mass of Particulate Matter Collected	mg	1.12	0.35
Concentration of Particulate Matter	mg/m <sup>3</sup> *	<b>0.64</b>	0.20
Emission Rate of Particulate Matter	g/hr	1.95	...
Expanded Uncertainty (% Relative)	%	27	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	20	...
Blank Concentration as Percentage of ELV	%	...	1.00

\*Reference Conditions ( 273K, 101.3kPa, Wet Gas )

**Table 3 – Particulates**  
**Data Recorded from Manufacturing - Main Vent**

Emission Parameter	Units	TPM 2	Blank
Stack Diameter	metres	0.50	...
			...
Area of Sample Plane	m <sup>2</sup>	0.196	...
Moisture Content	%	0.11	...
Oxygen Content	%	20.90	...
Stack Temperature	°C	19	...
Gas Velocity (at Stack Conditions)	m/sec	4.70	...
Gas Velocity (Reference Conditions)	m/sec*	4.29	...
Volumetric Flowrate (Stack Conditions)	m <sup>3</sup> /sec	0.92	...
Volumetric Flowrate (Reference Conditions)	m <sup>3</sup> /sec*	0.84	...
Sample Date	...	05/11/2013	...
Sample Period	...	10:30 - 12:30	...
Sample Volume (at Stack)	m <sup>3</sup>	1.92	...
Sample Volume (reference Conditions)	m <sup>3</sup> *	1.75	1.75
Isokinetic Sampling Rate	%	108.9	...
Sample Reference (ECL ID)	ECL/13/	5480 & 5481	5482 & 5483
Mass of Particulate Matter Collected	mg	0.35	0.35
Concentration of Particulate Matter	mg/m <sup>3</sup> *	<b>0.20</b>	0.20
Emission Rate of Particulate Matter	g/hr	0.61	...
Expanded Uncertainty (% Relative)	%	>100%	...
Emission Limit Value (ELV)	mg/m <sup>3</sup> *	20	...
Blank Concentration as Percentage of ELV	%	...	<1.00%

\*Reference Conditions ( 273K, 101.3kPa, Wet Gas )

**Environmental Compliance Limited**

**Linx Printing Technologies Ltd**  
Permit No : PG6/44(04)  
Variation No : 2004  
Report Ref : P1869 : R001

**Installation Name : Manufacturing Main Vent**  
**Visit Details : Annual Compliance – 2013**  
**Survey Dates : 5th November 2013**  
**Report Issue Date. : 15th November 2013**

## **VELOCITY TRAVERSE PROFILES**



**Environmental Compliance Limited**

**Linx Printing Technologies Ltd**  
Permit No : PG6/44(04)  
Variation No : 2004  
Report Ref : P1869 : R001

**Installation Name** : Manufacturing Main Vent  
**Visit Details** : Annual Compliance – 2013  
**Survey Dates** : 5th November 2013  
**Report Issue Date.** : 15th November 2013

## **FIELD CALIBRATION AND SAMPLING DATA**

Environmental Compliance Limited

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

**TVOC - FIELD DATA SHEET**

Client	Linx
Site	St Ives
Date	05/11/2013
Location	Manufacturing
Stack ID	Main Vent
Stack Temp °C	19
Ambient Temp	During Pre-test Calibration 12
Ambient Temp (sampling)	1= 12    2= 13    3= 14
Job No	P1869
Operators	AB

Barometric Pressure mb	989
Barometer ID	ECL/ID/ 629
Analyser ID	ECL/ID/ 304
Sonimix/ MFC ID	ECL/ID/ n/a
Heated Line/ Controller ID	ECL/ID/ 354 & 355
Heated Line Set Temp °C	180
Heated Line Length	10 m
Heated Filter ID	ECL/ID/ 806
Heated Filter Set Temp °C	180
Logger ID	217

**Calibration Gas Details**

Calibration Gas	Gas Bottle ID	Gas Value	Uncertainty of Gas (k=2)
Zero Gas (Synthetic Air)	Gas/ 1220	...	...
Hydrogen / Helium	Gas/ 1199	...	...
Propane (In Air)	Gas/ 1176	907.2 ppm	9.07 ppm

	Analyser Range	Span Gas value used
Propane	1000 ppm	907.2 ppm

Analysers Range should be not less than the expected peak emissions.  
 Span Gas Values should be either approximately the half-hourly ELV **OR** 50% to 90% of the Selected Analyser Range.

Direct Calibration (Rear of Analyser)						
	Zero Cal		Span Gas Cal		Zero Check	
	Start Time	End Time	Start Time	End Time	Start Time	End Time
ZERO / SPAN / ZERO	07:28	07:33	07:34	07:39	07:40	07:45

**NOTE: RESPONSE TIME**  
 Response Time to be carried out at the same time as "Span Check" on system verification (via the sample probe)  
 Start Time = when gas turned on. 90% Time = when analyser displays 90% of span gas value used. Response must be within 200 seconds.

	PRE System Verification Check (Down Line)			
	Zero Check		Span Check	
	Start Time	End Time	Start Time	End Time
ZERO / SPAN	07:46	07:51	07:53	07:58

Response Time SYSTEM Span Gas Cal		
Start Time	90% Time	less than 200s (Y/N)
07:52	07:53	Y

	Start Time	End Time	Location
Sample Period	08:00	16:03	Main Vent
Sample Period			

Production Details	
Varied - Normal	

	POST System Verification Check (Down Line)			
	Zero Check		Span Check	
	Start Time	End Time	Start Time	End Time
ZERO / SPAN	16:05	16:10	16:10	16:16

Process Details/ Comments

Environmental Compliance Limited

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

		TVOC ppm
<b>Analyser Range</b>		<b>1000</b>
<b>Repeatability at Zero</b>		<b>2</b>
<b>Span Gas Concentration Applied</b>		<b>907.2</b>
<b>Zero Gas Concentration Applied</b>		<b>0</b>
Direct Cal	Zero	0.00
	Span	907.2
	Zero	3.30
<b>Difference (Zero)</b>		3.2982
<b>&lt;2×Repeatability @ Zero?</b>		YES
Pre Test	Zero	3.30
	Span	904.0
<b>Difference (Zero)</b>		0.0000
<b>&lt;2% Relative to Direct Span</b>		YES
<b>Difference (Span)</b>		3.1900
<b>&lt;2% Relative to Direct Span</b>		YES
Post Test	Zero	3.30
	Span	909.7
<b>Difference (Zero)</b>		0.0000
<b>Zero Drift &lt;2% of Applied Span?</b>		YES
<b>Difference (Span)</b>		5.6485
<b>Span Drift &lt;2% of Applied Span?</b>		YES
<b>Zero and Span Drift &lt;5% of Applied Span?</b>		YES

Environmental Compliance Limited

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date : 15th November 2013

Environmental Compliance Limited		PARTICULATE DATA SAMPLING PROFORMA			Date of Measurement	05/11/2013			
ECL/TPD/	27a	Time taken to change Ports?	Start Time	08:05	End Time	10:05	Duration (mins)	120	
Client	Linx Printing	Stack Profile	Circular	Pitot ID	487	Stack Thermocouple ID	464	Impingers	n/a
Site	St Ives	Stack Area (m <sup>2</sup> )	0.20	Manometer ID	506	Stack Temp Reader ID	414	SOL/	n/a
Location	Manufacturing	Barometric Pressure (mb)	989	Barometer ID	629	Meter Thermocouple ID	366	Start Weight (g)	0.00
Stack ID	Main Vent	Stat Pres. (mmH <sup>2</sup> O) (Pa/9.81)	0.5	DGM Yd	1.0277	Meter Temp Reader ID	366	End Weight (g)	1.40
Test No.	TPM 1	Pitot coefficient	1	Nozzle ID	801	Dry Gas Meter ID	366	Total weight (g)	1.40
Job No	P1869	Balance ID	n/a	Nozzle Size (mm)	8.14	Timer ID	366		
ECL Site Staff	AB	Console ID	366	Filter ID	883	Rotameter ID	366		

	Sample	Leak 1	Leak 2	Leak 3	Leak 4
Start Volume	1377844.0				
Final Volume	1379732.0				
Total Volume	1888.0	0.0	0.0	0.0	0.0

Total	Volume (litres) @STP Dry	
	Expected Sample Volume	1607.41
	Actual Sample Volume	1741.97
	Isokinetic Percentage	108.37

Leak Check	First	Second	Third	Final	Maximum allowed leak rate is 2% of the set rate	Measured O <sub>2</sub>	20.90	Moisture	0.10
Leak Rate l/min	0.1			0.1		Measured CO <sub>2</sub> %		Ref O <sub>2</sub>	11
Set Rate (l/min)	20			20		Measured CO ppm		Dry Gas Molecular Weight	28.84
Time Of Leak Check	08:00			10:08					
Leak % of set rate	0.5			0.5					

TPD/27A is carried out with an unheated sampling system only.

Traverse Point	A2	A2	A2	A2	A2	A2	A2	A2	A2	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point ( mins )	0 - 5	5 - 10	10 - 15	15 - 20	20 - 25	25 - 30	30 - 35	35 - 40		
ΔP (Pa)	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.0
Velocity at Stack (m/s)	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	13.7	13.8	13.9	14.0	14.0	14.1	14.1	14.2		14.0
Meter (Tm)	7.00	9.00	11.00	12.00	13.00	14.00	15.00	16.00		12.1
Stack Temp (Ts)	19.00	19.00	19.00	19.00	19.00	19.00	19.00	19.00		19.0

Traverse Point	A2	A2	Total							
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point ( mins )	40 - 45	45 - 50	50 - 55	55 - 60	60 - 65	65 - 70	70 - 75	75 - 80		
ΔP (Pa)	13.00	13.00	13.00	13.00	13.00	13	13	13		13.0
Velocity at Stack (m/s)	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70		
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	14.3	14.4	14.5	14.6	14.7	14.8	14.8	14.9		14.6
Meter (Tm)	18.00	21.00	22.00	24.00	26.00	28	29	30		24.8
Stack Temp (Ts)	19.00	19.00	19.00	19.00	19.00	19	19	19		19.0

Traverse Point	A2	A2	A2	A2	A2	A2	A2	A2	A2	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point ( mins )	80 - 85	85 - 90	90 - 95	95 - 100	100 - 105	105 - 110	110 - 115	115 - 120		
ΔP (Pa)	13	13	13	13	13	13	13	13		13.0
Velocity at Stack (m/s)	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70		
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	14.9	15.0	15.1	15.1	15.2	15.2	15.2	15.2		15.1
Meter (Tm)	31	33	34	35	36	36	37	37		34.9
Stack Temp (Ts)	19	19	19	19	19	19	19	19		19.0

If moisture was not measured and gas was dried before entering the gas meter, impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.

Acetone SOL/	2345
DI Rinse SOL/	2341

Original Flowrate Settings	
Tm	40
Ts	19
%moisture	

Environmental Compliance Limited

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date : 15th November 2013

Environmental Compliance Limited		PARTICULATE DATA SAMPLING PROFORMA			Date of Measurement	05/11/2013			
ECL/TPD/	27a	Time taken to change Ports?	Start Time	10:30	End Time	12:30	Duration (mins)	120	
Client	Linx Printing	Stack Profile	Circular	Pitot ID	487	Stack Thermocouple ID	464	Impingers	n/a
Site	St Ives	Stack Area (m <sup>2</sup> )	0.20	Manometer ID	506	Stack Temp Reader ID	414	SOL/	n/a
Location	Manufacturing	Barometric Pressure (mb)	989	Barometer ID	629	Meter Thermocouple ID	366	Start Weight (g)	0.00
Stack ID	Main Vent	Stat Pres. (mmH <sup>2</sup> O) (Pa/9.81)	0.5	DGM Yd	1.0277	Meter Temp Reader ID	366	End Weight (g)	1.50
Test No.	TPM 2	Pitot coefficient	1	Nozzle ID	801	Dry Gas Meter ID	366	Total weight (g)	1.50
Job No	P1869	Balance ID	n/a	Nozzle Size (mm)	8.14	Timer ID	366		
ECL Site Staff	AB	Console ID	366	Filter ID	884	Rotameter ID	366		

	Sample	Leak 1	Leak 2	Leak 3	Leak 4
Start Volume	1379780.0				
Final Volume	1381760.0				
Total Volume	1980.0	0.0	0.0	0.0	0.0

Total	Volume (litres) @STP Dry	
	Expected Sample Volume	1607.33
	Actual Sample Volume	1750.46
	Isokinetic Percentage	108.90
1980.0		

Leak Check	First	Second	Third	Final	Maximum allowed leak rate is 2% of the set rate	Measured O <sub>2</sub>	20.90	Moisture	0.11
Leak Rate l/min	0.1			0.1		Measured CO <sub>2</sub> %		Ref O <sub>2</sub>	11
Set Rate (l/min)	20			20		Measured CO ppm		Dry Gas Molecular Weight	28.84
Time Of Leak Check	10:25			12:35					
Leak % of set rate	0.5			0.5					

TPD/27A is carried out with an unheated sampling system only.

Traverse Point	A2	A2	A2	A2	A2	A2	A2	A2	A2	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point ( mins )	0 - 5	5 - 10	10 - 15	15 - 20	20 - 25	25 - 30	30 - 35	35 - 40		
ΔP (Pa)	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.00	13.0
Velocity at Stack (m/s)	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	14.8	14.8	14.9	15.0	15.0	15.0	15.0	15.1	14.9	14.9
Meter (Tm)	28.00	29.00	30.00	32.00	32.00	33.00	33.00	34.00	31.4	31.4
Stack Temp (Ts)	19.00	19.00	19.00	19.00	19.00	19.00	19.00	19.00	19.0	19.0

Traverse Point	A2	A2	Total							
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point ( mins )	40 - 45	45 - 50	50 - 55	55 - 60	60 - 65	65 - 70	70 - 75	75 - 80		
ΔP (Pa)	13.00	13.00	13.00	13.00	13.00	13	13	13	13.0	13.0
Velocity at Stack (m/s)	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	15.1	15.1	15.2	15.3	15.3	15.3	15.4	15.4	15.2	15.2
Meter (Tm)	34.00	35.00	37.00	38.00	39.00	39	40	40	37.8	37.8
Stack Temp (Ts)	19.00	19.00	19.00	19.00	19.00	19	19	19	19.0	19.0

Traverse Point	A2	A2	A2	A2	A2	A2	A2	A2	A2	Total
Time Interval (mins)	5	5	5	5	5	5	5	5	5	
Time/Point ( mins )	80 - 85	85 - 90	90 - 95	95 - 100	100 - 105	105 - 110	110 - 115	115 - 120		
ΔP (Pa)	13	13	13	13	13	13	13	13	13.0	13.0
Velocity at Stack (m/s)	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70	4.70	
Sample Rate (l/min) 101.3 mbar, Tm, Dry Gas	15.4	15.4	15.4	15.4	15.5	15.5	15.5	15.5	15.4	15.4
Meter (Tm)	41	41	41	41	42	42	42	42	41.5	41.5
Stack Temp (Ts)	19	19	19	19	19	19	19	19	19.0	19.0

If moisture was not measured and gas was dried before entering the gas meter, impinger weights must be included to produce the moisture concentration used in the isokinetic calculations. If the gas was not dried before it entered the gas meter then impinger weights may be included to produce a nominal 0.1% moisture value.

Acetone SOL/	2345
DI Rinse SOL/	2341

Original Flowrate Settings	
Tm	40
Ts	19
%moisture	

**Environmental Compliance Limited**

**Linx Printing Technologies Ltd**  
**Permit No** : PG6/44(04)  
**Variation No** : 2004  
**Report Ref** : P1869 : R001

**Installation Name** : Manufacturing Main Vent  
**Visit Details** : Annual Compliance – 2013  
**Survey Dates** : 5th November 2013  
**Report Issue Date.** : 15th November 2013

## **LABORATORY ANALYSIS RESULTS**

Environmental Compliance Limited

Linx Printing Technologies Ltd  
Permit No : PG6/44(04)  
Variation No : 2004  
Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
Visit Details : Annual Compliance – 2013  
Survey Dates : 5th November 2013  
Report Issue Date. : 15th November 2013



Scientific Analysis Laboratories is a limited company registered in England and Wales (No 2514789) whose address is at Hadfield House, Hadfield Street, Manchester M16 9FE

Scientific Analysis Laboratories Ltd  
Certificate of Analysis

Hadfield House  
Hadfield Street  
Combrook  
Manchester  
M16 9FE  
Tel : 0161 874 2400  
Fax : 0161 874 2404

Report Number: 360093-1

Date of Report: 14-Nov-2013

Customer: Environmental Compliance Ltd  
Unit G1  
Main Avenue  
Treforest Industrial Estate  
Pontypridd  
CF37 5BF

Customer Contact: Mr Andrew Barnes

Customer Job Reference: P1869  
Customer Purchase Order: E2178  
Date Job Received at SAL: 09-Nov-2013  
Date Analysis Started: 11-Nov-2013  
Date Analysis Completed: 14-Nov-2013

The results reported relate to samples received in the laboratory  
Opinions and interpretations expressed herein are outside the scope of UKAS accreditation  
This report should not be reproduced except in full without the written approval of the laboratory  
Tests covered by this certificate were conducted in accordance with SAL SOPs  
All results have been reviewed in accordance with QP22



Report checked and authorised by :  
Kayleigh McCann  
Project Manager

Issued by :  
Kayleigh McCann  
Project Manager

Validity unknown  
Digitally signed by Kayleigh McCann  
Date: 2013.11.14 15:55:49 GMT  
Reason: Issued  
Location: SAL



**Environmental Compliance Limited**

**Linx Printing Technologies Ltd**  
Permit No : PG6/44(04)  
Variation No : 2004  
Report Ref : P1869 : R001

**Installation Name** : Manufacturing Main Vent  
**Visit Details** : Annual Compliance – 2013  
**Survey Dates** : 5th November 2013  
**Report Issue Date.** : 15th November 2013

## **UNCERTAINTY CALCULATIONS**

Environmental Compliance Limited

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

**TVOC Measurement Uncertainty**

Performance Characteristics	Standard Uncertainty	Distributioun	Min Certified Ranges
			TVOC 0 - 15 mgC/m <sup>3</sup>
Lack of fit <sup>(1)</sup>	$u_{lof}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.40
Span drift <sup>(2)</sup>	$u_{d,s}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.35
Repeatability Standard Deviation (span)	$u_r$	Normal ( Divisor = 1 )	4.69
Losses / leakage in the sample system <sup>(4)</sup>	$u_{loss}$	Rectangular ( Divisor = $\sqrt{3}$ )	0.35
Temperature dependant span drift <sup>(5)</sup>	$u_t$	Rectangular ( Divisor = $\sqrt{3}$ )	0.30
Interferents <sup>(1)</sup>	$u_i$	Rectangular ( Divisor = $\sqrt{3}$ )	4.39
Uncertainty of Reference Gas <sup>(6)</sup>	$u_{ref}$	Rectangular ( Divisor = $\sqrt{3}$ )	14.58

Note:

$$\text{when } |(x_{i,max} - x_{i,adj})| = |(x_{i,min} - x_{i,adj})|, \text{ then } u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$$

- 1 Expressed as a percentage of the analyser range
- 2 Expressed as maximum drift per 24hr period
- 3 Expressed in units of final measurement, dry gas
- 4 Expressed as a percentage of the final measured value
- 5 Per one degree centigrade
- 6 Expressed as standard uncertainty in units of measurement i.e. mg/m<sup>3</sup> / %Vol
- 7 Applies to TOC analyser (\*Signal 3030 FID) only

Performance Characteristics	Uncertainty	Value of Standard Uncertainty	*TVOC 0 - 15 mgC/m <sup>3</sup>
Lack of fit	$u_{lof}$	$u(x_i) = \frac{u_{lof} \times R_i}{\sqrt{3}} =$	0.035
Span drift	$u_{d,s}$	$u(x_i) = \frac{u_{d,s} \times R_i}{\sqrt{3}} =$	0.031
Repeatability Standard Deviation (span)	$u_r$	$\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}} =$	4.69
Losses / leakage in the sample system	$u_{loss}$	$u(x_i) = \frac{u_{loss} \times R_i}{\sqrt{3}} =$	2.75
Temperature dependant span drift	$u_t$	$u(x_i) = \frac{u_t}{100} \times R_i \times \sqrt{\frac{(x_{i,max} - x_{adj})^2 + (x_{i,min} - x_{adj})(x_{i,max} - x_{adj}) + (x_{i,min} - x_{adj})^2}{3}}$	0.052
Interferents	$u_i$	$u(x_i) = \frac{u_i \times R_i}{\sqrt{3}} =$	0.38
Uncertainty of Reference Gas	$u_{ref}$	$u(x_i) = \frac{u_{ref}}{\sqrt{3}} =$	14.58
Combined Standard Uncertainty		$u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_r^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_{ref}^2}$	15.57
Expanded measurement uncertainty (at 95% confidence)		$U_{EXP} = 2 \times u_c$	31.14
Applied Span Concentration			1457.87
Measured Span Concentration, STP Dry Gas			1457.51
Expanded measurement uncertainty as % of Applied Span			2 %

\* Signal 3030 FID

**Environmental Compliance Limited**

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

**TVOC Uncertainty of Measurement Results**

**Uncertainty Calculations Part 1**

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Min Certified Range
				TVOC 0 - 15 mgC/m <sup>3</sup>
Lack of fit <sup>(1)</sup>	$u_{lof}$	Rectangular	$\sqrt{3}$	0.40
Span drift <sup>(2)</sup>	$u_{d,s}$			0.35
Losses / leakage in the sample system <sup>(4)</sup>	$u_{loss}$			0.35
Temperature dependant span drift <sup>(5)</sup>	$u_t$			0.30
Interferents <sup>(4)</sup>	$u_i$			4.39
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$			1.80
Effect of Oxygen Synergism <sup>(7)</sup>	$u_{svs}$			

**Notes:**

For rectangular distributions,  $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For  $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,ref})^2 + (x_{i,min} - x_{i,ref})^2 + (x_{i,max} - x_{i,min})^2}{3}}$ , when  $(x_{i,max} - x_{i,ref}) = (x_{i,min} - x_{i,ref})$ , then  $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where  $u(x_i) = \frac{\sigma}{\sqrt{n}}$  (See note 6 below),  $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	TVOC 0 - 15 mgC/m <sup>3</sup>
Lack of fit	$u_{lof}$	Rectangular	$\sqrt{3}$	0.035
Span drift	$u_{d,s}$			0.031
Temperature dependant span drift	$u_t$			0.05
Interferents	$u_i$			0.38
Effect of Voltage Fluctuation (See Note)	$u_v$			0.16

**Uncertainty Calculations Part 2**

Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	TVOC 0 - 15 mgC/m <sup>3</sup>
Losses / leakage in the sample system	$u_{loss}$	05/11/13 08:02 - 12:02	0.348
Standard Error of Measured Value	$u_{SE}$	05/11/13 08:02 - 12:02	7.49

**Effect on Uncertainty Caused by Oxygen**

$$u_{Cor_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times (20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Meas}$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.0000$$

$$u_{f_{O_2}} = \frac{u_{Cor_{O_2}}}{f_{O_2}} \times 100 = 0.00 \%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

**Uncertainty Calculations Part 3**

Uncertainty	Date & Time	TVOC 0 - 15 mgC/m <sup>3</sup>
Measured Concentration		99.00
Expanded Uncertainty as Percentage of Measured Concentration	05/11/13 08:02 - 12:02	15 %

Combined Standard Uncertainty  $u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_t^2 + u_{loss}^2 + u_i^2 + u_{ref}^2 + u_v^2 + u_{svs}^2}$

Expanded uncertainty (at 95% confidence)  $U_{95\%} = 2 \times u_c$

- Expressed as a percentage of the analyser range
- Expressed as maximum drift per 24hr period
- Expressed in units of final measurement
- Expressed as a percentage of the final measured value
- Per one degree centigrade
- Where the uncertainty of Oxygen is taken as the standard error of the time averaged value used to correct to Reference Oxygen
- Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- Where no uncertainty is presented above, the uncertainty is >100%

**Environmental Compliance Limited**

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869 : R001

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

**Uncertainty Calculations Part 1**

Performance Characteristics	Standard Uncertainty (% of Range)	Distribution	Divisor	Min Certified Range
				TVOC 0 - 15 mgC/m <sup>3</sup>
Lack of fit <sup>(1)</sup>	$u_{lof}$	Rectangular	$\sqrt{3}$	0.40
Span drift <sup>(2)</sup>	$u_{d,s}$			0.35
Losses / leakage in the sample system <sup>(4)</sup>	$u_{loss}$			0.35
Temperature dependant span drift <sup>(5)</sup>	$u_t$			0.30
Interferents <sup>(1)</sup>	$u_i$			4.39
Effect of Voltage Fluctuation <sup>(7)</sup>	$u_v$			1.80
Effect of Oxygen Synergism <sup>(7)</sup>	$u_{syng}$			

**Notes:**

For rectangular distributions,  $u(x_i) = \frac{u \times R_i}{\sqrt{3}}$

For  $u(x_i) = \Delta x_i \sqrt{\frac{(x_{i,max} - x_{i,avg})^2 + (x_{i,min} - x_{i,avg})^2 + (x_{i,max} - x_{i,min})^2}{3}}$ , when  $|x_{i,max} - x_{i,avg}| = |x_{i,min} - x_{i,avg}|$ , then  $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$

Where  $u(x_i) = \frac{\sigma}{\sqrt{n}}$  (See note 6 below),  $\sigma = \sqrt{\frac{\sum_{i=1}^n (x_i - \bar{x})^2}{n-1}}$

Performance Characteristics	Uncertainty (Units of final measurement)	Distribution	Divisor	TVOC 0 - 15 mgC/m <sup>3</sup>
Lack of fit	$u_{lof}$	Rectangular	$\sqrt{3}$	0.035
Span drift	$u_{d,s}$			0.031
Temperature dependant span drift	$u_t$			0.05
Interferents	$u_i$			0.38
Effect of Voltage Fluctuation (See Note)	$u_v$			0.16

**Uncertainty Calculations Part 2**

Performance Characteristics	Uncertainty (Units of final measurement)	Date & Time	TVOC 0 - 15 mgC/m <sup>3</sup>
Losses / leakage in the sample system	$u_{loss}$	05/11/13 12:02 - 16:02	0.244
Standard Error of Measured Value	$u_{SE}$	05/11/13 12:02 - 16:02	5.43

**Effect on Uncertainty Caused by Oxygen**

$$u_{Corr_{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured})(20.9\% - O_{2,measured})} \times \text{Uncertainty of } O_2 \text{ Meas}$$

$$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.0000$$

$$u_{f_{O_2}} = \frac{u_{Corr_{O_2}}}{f_{O_2}} \times 100 = 0.00 \%$$

The effect of oxygen on the overall uncertainties (below) is incorporated using the following equation:-

$$u_{combined} = \sqrt{\sum (u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Where oxygen or moisture correction is required, uncertainty based on the standard error of the measured peripheral value is converted to units of final measurement using a sensitivity coefficient C,

$$\therefore u(x_i) = C_i u_i \text{ where } C_i = \frac{\partial f}{\partial x_i}$$

**Uncertainty Calculations Part 3**

Uncertainty	Date & Time	TVOC 0 - 15 mgC/m <sup>3</sup>
Measured Concentration		69.33
Expanded Uncertainty as Percentage of Measured Concentration	05/11/13 12:02 - 16:02	16 %

**Combined Standard Uncertainty**  $u_c = \sqrt{u_{lof}^2 + u_{d,s}^2 + u_{loss}^2 + u_t^2 + u_i^2 + u_v^2 + u_{syng}^2}$

**Expanded uncertainty (at 95% confidence)**  $U_{95} = 2 \times u_c$

- 1 Expressed as a percentage of the analyser range
- 2 Expressed as maximum drift per 24hr period
- 3 Expressed in units of final measurement
- 4 Expressed as a percentage of the final measured value
- 5 Per one degree centigrade
- 6 Where the uncertainty of Oxygen is taken as the standard error of the time averaged value used to correct to Reference Oxygen
- 7 Where the uncertainty of Moisture is taken as the standard error of the time averaged value used to correct to Dry Conditions
- 8 Where no uncertainty is presented above, the uncertainty is >100%

**Environmental Compliance Limited**

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

Site: Linx Printing, St Ives  
 Location: Manufacturing, Stack ID: Main Vent

$$u_{mass} = \sqrt{\sum(u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Uncertainty mg
				Filter mg	Solution mg	Filter mg	Solution mg	
<b>TPM 1</b>								
Particulates	0.62	0.50	1.12	0.14	0.27	0.0700	0.14	0.15

TPM 1			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	1.89	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Yd)	1.03	...	...	...	...
Meter Temperature (T <sub>m</sub> )	297.07	k	uT <sub>m</sub>	1.5	k
Static Pressure of Stack P <sub>static</sub>	0.50	mmH <sub>2</sub> O	uP <sub>static</sub>	0.25	mmH <sub>2</sub> O
Absolute Stack Pressure p <sub>s</sub>	741.81	mmHg	uP <sub>s</sub>	0.8	mmHg
Barometric Pressure p <sub>b</sub>	741.99	mmHg	uP <sub>b</sub>	3.8	mmHg
Average Differential Pressure (ΔP) + p <sub>s</sub>	99.08	mmH <sub>2</sub> O	uΔH	0.25	mmH <sub>2</sub> O
Oxygen content (O <sub>2,m</sub> )	20.90	%by volume	uO <sub>2,m</sub> = σ/√n	0.00	%by volume
Moisture Content (H <sub>2</sub> O)	0.0996	%by volume	uH <sub>2</sub> O	0.09	%by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:  $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C<sub>i</sub>u<sub>i</sub> where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=uV<sub>m</sub> uT<sub>m</sub> etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP <sub>b</sub> ), measured static pressure uncertainty component (uP <sub>static</sub> ) & measured temperature of dry gas uncertainty component (uT <sub>m</sub> )					Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV <sub>std</sub> ) & volume uncertainty component (uV <sub>m</sub> )				
$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.932$					$V_{std} = V_{measured} \times f_s = 1.7597$				
	Maximum	Minimum	Sensitivity	ufstp		Maximum	Minimum	Sensitivity	Standard Uncertainty (m <sup>3</sup> )
uΔH	0.49	0.49	0.0000477	0.0000119	Effect of uV <sub>std</sub>	1.76	1.75	1.89	0.00490
uP <sub>b</sub>	0.49	0.48	0.000648	0.00243	Effect of uV <sub>m</sub>	1.76	1.76	0.93	0.000932
uT <sub>m</sub>	0.49	0.48	0.000852	0.00128					
H <sub>2</sub> O	0.49	0.49	0.00486	0.000425					
$\frac{u_{f_s}}{f_s} = \sqrt{\left(\frac{u_{\Delta H}}{(P_m/101.3)}\right)^2 + \left(\frac{u_{T_m}}{(T_m/273.15)}\right)^2 + \left(\frac{u_{H_2O}}{100/(100-H_2O)}\right)^2} = 0.00259$					$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00928$				

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO <sub>2</sub> ) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)					Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO <sub>2</sub> ) and STP volume uncertainty component (uV <sub>stp</sub> )																			
$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$					$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 0.64$																			
$u_{Corr^{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times \text{Uncertainty of } O_2 \text{ Measurement}} = 1.00$					<table border="1"> <thead> <tr> <th></th> <th>Maximum mg/Nm<sup>3</sup></th> <th>Minimum mg/Nm<sup>3</sup></th> <th>Sensitivity</th> <th>u mg/Nm<sup>3</sup></th> </tr> </thead> <tbody> <tr> <td>uM</td> <td>0.72</td> <td>0.55</td> <td>0.57</td> <td>0.0864</td> </tr> <tr> <td>uV<sub>stp</sub></td> <td>0.64</td> <td>0.63</td> <td>0.36</td> <td>0.00336</td> </tr> </tbody> </table>						Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	u mg/Nm <sup>3</sup>	uM	0.72	0.55	0.57	0.0864	uV <sub>stp</sub>	0.64	0.63	0.36	0.00336
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	u mg/Nm <sup>3</sup>																				
uM	0.72	0.55	0.57	0.0864																				
uV <sub>stp</sub>	0.64	0.63	0.36	0.00336																				
$u_{f_{O_2}} = \frac{u_{Corr^{O_2}} \times O_2}{f_{O_2}} \times 100 = 0.00$																								

Measurement Uncertainty of Determinand (excluding correction for oxygen)

$$u_{combined} = \sqrt{\sum(u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Combined Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration
0.09	0.17	0.64	27.2%

Measurement Uncertainty of Determinand (including correction for oxygen)

$$u_{combined} = \sqrt{\sum(u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr <sup>n</sup> Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (u <sub>combined</sub> ) %
Particulates	27.2	0.0	27.2

Environmental Compliance Limited

Linx Printing Technologies Ltd  
 Permit No : PG6/44(04)  
 Variation No : 2004  
 Report Ref : P1869

Installation Name : Manufacturing Main Vent  
 Visit Details : Annual Compliance – 2013  
 Survey Dates : 5th November 2013  
 Report Issue Date. : 15th November 2013

Site: Linx Printing, St Ives  
 Location: Manufacturing, Stack ID: Main Vent

$$u_{mass} = \sqrt{\sum(u_{filter})^2 + (u_{solution})^2}$$

Determinand	Filter mg	Solution mg	Recovered Mass mg	LAB Method Uncert (%) K=2		Standard Uncertainty		Combined Uncertainty mg
				Filter mg	Solution mg	Filter mg	Solution mg	
<b>TPM 2</b>								
Particulates	0.0500	0.30	0.35	0.14	0.27	0.0700	0.14	0.15

TPM 2			Standard Uncertainty @ 95%		
Sampled Volume (V <sub>m</sub> )	1.98	m <sup>3</sup>	uV <sub>m</sub>	0.001	m <sup>3</sup>
Meter Correction Factor (Yd)	1.03	...	...	...	...
Meter Temperature (T <sub>m</sub> )	310.03	k	uT <sub>m</sub>	1.5	k
Static Pressure of Stack P <sub>static</sub>	0.50	mmH <sub>2</sub> O	uP <sub>static</sub>	0.25	mmH <sub>2</sub> O
Absolute Stack Pressure p <sub>s</sub>	741.81	mmHg	uP <sub>s</sub>	0.8	mmHg
Barometric Pressure p <sub>b</sub>	741.99	mmHg	uP <sub>b</sub>	3.8	mmHg
Average Differential Pressure (ΔP) + ps	99.08	mmH <sub>2</sub> O	uΔH	0.25	mmH <sub>2</sub> O
Oxygen content (O <sub>2,m</sub> )	20.90	%by volume	uO <sub>2,m</sub> = σ/√n	0.00	%by volume
Moisture Content (H <sub>2</sub> O)	0.11	%by volume	uH <sub>2</sub> O	0.09	%by volume

Note: In the following calculations, the sensitivity coefficient (C) is estimated using:  $C_i = \frac{\partial f}{\partial x_i}$

For each factor, uncertainty is then calculated by C<sub>i</sub>u<sub>i</sub> where C is the sensitivity coefficient, u is the standard uncertainty and i is the index identifying the contributing factor e.g. i=V<sub>m</sub>, uT<sub>m</sub> etc.

Where results are required at wet conditions, the following correction factor is used to convert the data from the dry gas meter:

$$f_{s,wet} = \frac{100}{(100 - H_2O)} = 1.00$$

Uncertainty in correction factor to STP due to measured barometric pressure uncertainty component (uP <sub>b</sub> ), measured static pressure uncertainty component (uP <sub>static</sub> ) & measured temperature of dry gas uncertainty component (uT <sub>m</sub> )					Uncertainty in volume @ STP due to volume correction factor uncertainty component (uV <sub>std</sub> ) & volume uncertainty component (uV <sub>m</sub> )				
$f_s = \frac{273}{760} \times \frac{P_b + \frac{\Delta H}{13.6}}{T_m} \times Y_d = 0.893$					$V_{std} = V_{measured} \times f_s = 1.7684$				
	Maximum	Minimum	Sensitivity	ufstp		Maximum	Minimum	Sensitivity	Standard Uncertainty (m <sup>3</sup> )
uΔH	0.47	0.47	0.0000466	0.0000117	Effect of uV <sub>std</sub>	1.77	1.76	1.98	0.00476
uP <sub>b</sub>	0.48	0.47	0.000634	0.00238	Effect of uV <sub>m</sub>	1.77	1.77	0.89	0.000893
uT <sub>m</sub>	0.48	0.47	0.000815	0.00122					
H <sub>2</sub> O	0.48	0.47	0.00475	0.000413					
$\frac{u_{f_s}}{f_s} = \sqrt{\left(\frac{u(\Delta H)^2 + (uP_s)^2}{(P_m/101.3)}\right)^2 + \left(\frac{uT_m}{(T_m/273.15)}\right)^2 + \left(\frac{uH_2O}{100/(100-H_2O)}\right)^2} = 0.00240$					$\frac{uV_{std}}{V_{std}} = \sqrt{\left(\frac{uV_{std}}{f_s}\right)^2 + \left(\frac{uV_m}{V_m}\right)^2} = 0.00945$				

Uncertainty of correction factor to reference oxygen due to measured oxygen uncertainty component (uO <sub>2</sub> ) & Uncertainty in final measurement @ reference conditions due to uncertainty component arising from leak and/or loss (assumed 2% max) in the sample system (uL)					Uncertainty in final measurement @ reference conditions due to mass uncertainty component (uM), oxygen correction uncertainty component (uO <sub>2</sub> ) and STP volume uncertainty component (uV <sub>stp</sub> )																			
$f_{O_2} = \frac{20.9\% - O_{2,ref}}{20.9\% - O_{2,measured}} = 1.00$					$Conc = \frac{M_{Recovered}}{V_m \times f_s \times f_{O_2}} = 0.20$																			
$u_{Corr^{O_2}} = \frac{20.9\% - O_{2,ref}}{(20.9\% - O_{2,measured}) \times \text{Uncertainty of } O_2 \text{ Measurement}} = 1.00$					<table border="1"> <thead> <tr> <th></th> <th>Maximum mg/Nm<sup>3</sup></th> <th>Minimum mg/Nm<sup>3</sup></th> <th>Sensitivity</th> <th>u mg/Nm<sup>3</sup></th> </tr> </thead> <tbody> <tr> <td>uM</td> <td>0.28</td> <td>0.11</td> <td>0.57</td> <td>0.0860</td> </tr> <tr> <td>uV<sub>stp</sub></td> <td>0.20</td> <td>0.20</td> <td>0.11</td> <td>0.00106</td> </tr> </tbody> </table>						Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	u mg/Nm <sup>3</sup>	uM	0.28	0.11	0.57	0.0860	uV <sub>stp</sub>	0.20	0.20	0.11	0.00106
	Maximum mg/Nm <sup>3</sup>	Minimum mg/Nm <sup>3</sup>	Sensitivity	u mg/Nm <sup>3</sup>																				
uM	0.28	0.11	0.57	0.0860																				
uV <sub>stp</sub>	0.20	0.20	0.11	0.00106																				
$u_{f_{O_2}} = \frac{u_{Corr^{O_2}} \times O_2}{f_{O_2}} \times 100 = 0.00$																								

Measurement Uncertainty of Determinand (excluding correction for oxygen)

$$u_{combined} = \sqrt{\sum(u_M)^2 + (u_L)^2 + (uV_{stp})^2}$$

Combined Uncertainty mg/Nm <sup>3</sup>	Expanded Uncertainty mg/Nm <sup>3</sup>	Measured Concentration mg/Nm <sup>3</sup>	Percent of Measured Concentration
0.09	0.17	0.20	86.9%

Measurement Uncertainty of Determinand (including correction for oxygen)

$$u_{combined} = \sqrt{\sum(u_{f_{O_2}})^2 + (\text{Uncertainty of Measurement of Determinand})^2}$$

Determinand	Measurement Uncertainty of Determinand	Measurement Uncertainty of Oxygen Corr <sup>n</sup> Factor	Overall Measurement Uncertainty inc O <sub>2</sub> Corr <sup>n</sup> factor (U <sub>combined</sub> ) %
Particulates	86.9	0.0	86.9