

AIR & EMISSIONS TESTING GROUP

52 Offerton Industrial Estate
Hempshaw Lane
Stockport
SK2 5TJ
Tel: 0161 477 3004
Fax: 0161 480 4642

Your contact at Scientifics:

Andrew Palliser
Business Manager
Tel: 0161 477 3004
Fax: 0161 480 4642
Email: andrew.palliser@scientifics.com

Stack Emissions Testing Report

Site:

Hanson Aggregates Ltd

Location:

St Ives

Site:

Coating Plant

Sampling Date/s:

15th September 2009

Job Number:

LAB 08760

Report Date:	29th October 2009
Version:	1
Report By:	Ibai Castezubi
MCERTS Number:	MM 05 674
MCERTS Level:	Level 2, Team Leader
Technical Endorsements:	TE1, TE2, TE3 & TE4
Report Approved By:	Andrew Hegarty
MCERTS Number:	MM 03 397
Business Title:	Level 2, Technical Manager
Technical Endorsements:	TE1, TE2, TE3 & TE4
Signature:	

CONTENTS

TITLE PAGE

CONTENTS

EXECUTIVE SUMMARY

Monitoring Times

Process Details

Monitoring Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

Sampling and Analytical Method Deviation

APPENDICES

EXECUTIVE SUMMARY (Page 1 of 12)

Stack Emissions Monitoring Objectives

Hanson Aggregates Ltd operates a Roadstone coating process at St Ives which is subject to PPC Permit PG 3/15b (04), under the Pollution Prevention & Control Regulations 2000.

Scientifics Limited were commissioned by Hanson Aggregates Ltd to carry out stack emissions monitoring to determine the release of prescribed pollutants from the following Plant under 20 mm gravel operating conditions.

The results of these tests shall be used to demonstrate compliance with a set of emission limit values for prescribed pollutants as specified in the Plant's PPC Permit, PG 3/15b (04).

Plant

Coating Plant

Operator

PPC Permit: PG 3/15b (04)

Hanson Aggregates Ltd
Meadow Lane
St Ives
Cambridgeshire
PE27 4 LG

Stack Emissions Monitoring

Scientifics Limited - Stockport Laboratory
52 Offerton Industrial Estate
Hempshaw Lane
Stockport
SK2 5TJ

UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.

This test report shall not be reproduced, except in full, without written approval of Scientifics Limited.

EXECUTIVE SUMMARY

Emissions Summary

Parameter	Units	Result	Uncertainty +/-	Limit
Total Particulate Matter	mg/m ³	35	1.5	50
Particulate Emission Rate	g/hr	2182	92	-
Cadmium	mg/m ³	0.02	0.005	0.5
Cadmium Emission Rates	g/hr	1.5	0.3	-
Nickel	mg/m ³	0.57	0.1	1
Nickel Emission Rates	g/hr	39	8.3	-
Lead	mg/m ³	0.1	0.02	5
Lead Emission Rates	g/hr	5.4	1.1	-
Combined Chromium, Copper and Vanadium	mg/m ³	0.47	0.1	1.5
Combined Cr,Cu & V Emission Rates	g/hr	32	6.8	-
Hydrogen Chloride	mg/m ³	0.57	0.04	100
Hydrogen Chloride Emission Rate	g/hr	36	2.4	-
Hydrogen Fluoride	mg/m ³	0.41	0.05	5
Hydrogen Fluoride Emission Rate	g/hr	25	3.0	-
Moisture	%	0.9	0.05	-
Stack Gas Temperature	°C	82.0	-	-
Stack Gas Velocity	m/s	14.6	-	-
Gas Volumetric Flow Rate (Actual)	m ³ /hr	80648	-	-
Gas Volumetric Flow Rate (STP, Wet)	m ³ /hr	62130	-	-
Gas Volumetric Flow Rate (STP, Dry)	m ³ /hr	61584	-	-
Gas Volumetric Flow Rate (@ref conditions)	m ³ /hr	62130	-	-

where ND = None Detected

Reference conditions are 273K, 101.3Pa, without correction for water vapour content

EXECUTIVE SUMMARY

Monitoring Times

Parameter	Sampling Date	Sampling Times	Sampling Duration
Total Particulate Matter Run 1	15th September 2009	10:23 - 10:55	32 minutes
Heavy Metals Run 1	15th September 2009	07:52 - 08:27	32 minutes
Hydrogen Chloride Run 1	15th September 2009	10:23 - 10:55	32 minutes
Hydrogen Fluoride Run 1	15th September 2009	11:31 - 12:01	30 minutes

EXECUTIVE SUMMARY

Process Details

Parameter	Process Details
Process Status	20 mm gravel
Capacity (of 100%) and Tonnes / Hour	110 T/h
Continuous or Batch Process	Batch Process
Feedstock (if applicable)	Gravel
Abatement System	Bag Filter
Abatement System Running Status	On
Fuel	CFO
Plume Appearance	None visible from sampling location

EXECUTIVE SUMMARY

Monitoring Methods

The selection of standard methods employed by Scientifics is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Document (Monitoring) M2. i.e. CEN, ISO, BS, US EPA etc.

The tables below summarise the monitoring methods, techniques and technical procedures employed, and details any deviations from the aforementioned hierarchy:

Sampling Methods with Subsequent Analysis

Species	Standard Method	Scientifics Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	MU of Method +/- %	MU +/- %
TPM	BS EN 13284-1	AE 006	1015	Yes	0.48 mg/m ³	30%	4.2 %
Heavy Metals	BS EN 14385	AE 028	1015	Yes	0.038 mg/m ³	30%	21.1 %
Hydrogen Chloride	BS EN 1911	AE 019	1015	Yes	0.0018 mg/m ³	30%	6.8 %
Hydrogen Fluoride	BS ISO 15713	AE 055	1015	Yes	0.17 mg/m ³	30%	12 %

On-Site Testing

Species	Standard Method	Scientifics Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	MU of Method +/- %	MU +/- %
H ₂ O	BS EN 14790	AE 004	1015	Yes	0.0002 %	10	6.3%

EXECUTIVE SUMMARY

Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

Sampling Methods with Subsequent Analysis

Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	UKAS Accredited Analysis	Laboratory	Sample Archive Location	Archive Period
TPM	Gravimetric	AE 006	1015	Yes	Stockport	Stockport	3 months
Heavy Metals	Inductively Coupled Plasma, Mass Spectrometry	HS/GWI/1002/15	1015	Yes	Harwell	Harwell	3 months
Hydrogen Chloride	IC	HS/WII/1087	1015	Yes	Harwell	Harwell	3 months
Hydrogen Fluoride	Ion Chromatography	HS/WII/1087	1015	Yes	Harwell	Harwell	3 months

On-Site Testing

Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	MCERTS Accredited Analysis	Laboratory	Archive Location	Gas
H ₂ O	Gravimetric	AE 004	1015	Yes	Stockport	N/A	N/A

BS EN 14790 has been validated over a range of 4 - 40%. It is however the preferred method of the Environment Agency for concentrations below 4%

EXECUTIVE SUMMARY

Sampling Location

Sampling Plane Validation Criteria	Value	Units	Requirement	Compliance	Method
Lowest Differential Pressure	170	Pa	$\geq 5 \text{ Pa}$	Yes	All
Lowest Gas Velocity	14.39	m/s	-	-	-
Highest Gas Velocity	14.72	m/s	-	-	-
Ratio of Above	1.02	: 1	$< 3 : 1$	Yes	All
Mean Velocity	14.55	m/s	-	-	-
Angle of flow with regard to duct axis	0	°	$< 15^\circ$	Yes	All
No local negative flow	-	-	-	Yes	All
Highly homogeneous flow stream / gas velocity	-	-	-	Yes	ISO 10396

Duct Characteristics

	Value	Units
Type	Circular	-
Depth	1.40	m
Width	-	m
Area	1.54	m ²
Port Depth	90	mm

Sampling Lines & Sample Points

	Isokinetic (CEN Methods)	Isokinetic (ISO Methods)	Non-Iso & Gases
Sample Port Size	4 inch BSP	-	4 inch BSP
Number Used	2	-	1
Orientation	Horizontal	-	Horizontal
Number Points / Line	4	-	1
Filtration	Out Stack	-	Out Stack
Filtration for TPM	Out Stack	-	-

Sampling Platform

General Platform Information	
Permanent / Temporary Platform	Permanent
Inside / Outside	Outside

M1 Platform requirements	
Minimum Platform Area 5 m ²	Yes
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	Yes
Platform has vertical base boards (approximately 0.25 m high)	Yes
Platform has removable chains / self closing gates at the top of ladders	Yes
Handrail / obstructions do not hamper insertion of sampling equipment	Yes
Depth of Platform = Minimum of 2m or Probe Length + 1m	Yes

Sampling Location / Platform Improvement Recommendations

The sampling location meets all the requirements as specified in EA Guidance Note M1.

EXECUTIVE SUMMARY

Sampling & Analytical Method Deviations

Heavy Metals Absorbtion efficiency

Several of the metals didn't meet the required absorbtion requirement. However, this was due to the levels being very low so this is not thought to have had a significant effect on the result.

APPENDICES

CONTENTS

CONTENTS

APPENDIX 1 - Stack Emissions Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Calibrateable Equipment Checklist and Calibration Gases

APPENDIX 4 - Measurement Uncertainty Budget Calculations

APPENDIX 5 - Waste Oil Analysis

APPENDICES

STACK EMISSIONS MONITORING TEAM

Team Leader	Ibai Castezubi Level 2, TE1, TE2, TE3 & TE4 MM 05 674
-------------	---

Technician	Craig Whittingham Level 1 MM 05 669
------------	---

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

TOTAL PARTICULATE MATTER SUMMARY

Test	Sampling Times	Concentration mg/m ³	LOD mg/m ³	Limit mg/m ³	Emission Rate g/hr
Run 1	10:23 - 10:55 15th September 2009	35	0.48	50	2182
Blank	-	1.4	-	-	-

Reference conditions are 273K, 101.3Pa, without correction for water vapour content

Acetone Blank Value mg/l	Acceptable Value mg/l
5.00	10

TPM

Absolute pressure of stack gas, P_s			Molecular weight of dry gas, M_d		
Barometric pressure, P _b	mm Hg	757.51	CO ₂	%	15.80
Stack static pressure, P _{static}	mm H ₂ O	48.95	O ₂	%	20.9
P _s = $\frac{P_b + (P_{static})}{13.6}$	mm Hg	761.11	Total	%	36.70
			N ₂ (100 -Total)	%	63.30
Vol. of water vapour collected, V_{wstd}			M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂)		31.36
Moisture trap weight increase, V _{lc}	g	4.3	Molecular weight of wet gas, M_s		
V _{wstd} = (0.001246)(V _{lc})	m ³	0.0053578	M _s = M _d (1 - B _{wo}) + 18(B _{wo})	g/gmol	31.25
Volume of gas metered dry, V_{mstd}			Actual flow of stack gas, Q_a		
Volume of gas sample through gas meter, V _m		0.745	Area of stack, A _s	m ²	1.54
Gas meter correction factor, Y _d		0.860	Q _a = (60)(A _s)(V _s)	m ³ /min	1362.9
Mean dry gas meter temperature, T _m		17.000	Total flow of stack gas, Q		
Mean pressure drop across orifice, ΔH	mmH	57.707	Conversion factor (K/mm.Hg)		0.3592
V _{mstd} = $\frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		0.605	Q _{std} = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$	Dry	1040.4
Volume of gas metered wet, V_{mstw}			Q _{stdO2} = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2I)}{(T_s) + 273}$	@O2ref	No O2 Ref
V _{mstw} = V _{mstd} + V _{wstd}	m ³	0.6101	Q _{stw} = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	Wet	1049.58
Vol. of gas metered at O₂ Ref. Cond., V_{mstd@X%O2}			Percent isokinetic, %I		
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Nozzle diameter, D _n	mm	5.90
% oxygen measured in gas stream, act%O ₂		20.9	Nozzle area, A _n	mm ²	27.34
% oxygen reference condition		21	Total sampling time, θ	min	32
O ₂ Reference O2 Ref = 21.0 - act%O ₂		No O2 Ref	%I = $\frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$	%	102.3
Factor 21.0 - ref%O ₂			Acceptable isokinetic range 95% to 115%		Yes
V _{mstd@X%oxygen} = (V _{mstd}) (O ₂ Ref)	m ³	No O2 Ref	Particulate Concentration, C		
Moisture content, B_{wo}			Mass collected on filter, M _f	g	0.01444
B _{wo} = $\frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0088	Mass collected in probe, M _p	g	0.0067
		0.88	Total mass collected, M _n	g	0.0211
Moisture by FTIR	%	-	C _{wet} = $\frac{M_n}{V_{mstw}}$	mg/m ³	34.651
Velocity of stack gas, V_s			C _{dry} = $\frac{M_n}{V_{mstd}}$	mg/m ³	34.958
Pitot tube velocity constant, K _p		34.97	C _{dry@X%O2} = $\frac{M_n}{V_{mstd@X\%oxygen}}$	mg/m ³	No O2 Ref
Velocity pressure coefficient, C _p		0.81	Particulate Emission Rates, E		
Mean of velocity heads, ΔP _{avg}	mm H ₂ O	18.18	E = [(C _{wet})(Q _{stw})(60)] / 1000		2182.14
Mean square root of velocity heads, √ΔP		4.26			
Mean stack gas temperature, T _s	°C	82			
V _s = $\frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{\sqrt{(M_s)(P_s)}}$	m/s	14.75			

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

TOTAL PARTICULATE MATTER QUALITY ASSURANCE CHECKLIST

Leak Rate

Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	20.03	0.12	0.11	-508	0.40	Yes

Isokineticity

Run	Isokinetic Variation %	Acceptable Isokineticity
Run 1	102.27	Yes

Acceptable Isokinetic rate 90 -110%

Blank Value

Run	Overall Blank Value mg/m ³	Daily Emission Limit Value mg/m ³	Acceptable Blank Value mg/m ³	Overall Blank Acceptable mg/m ³
Blank 1	1.44	50	5	No

Filters

Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-conditioning Filter Temperature °C	Post conditioning Filtration Temperature °C
Run 1	GF	47	82	180	160

GF = Glass Fibre

QF = Quartz Fibre

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

HEAVY METALS - PARTICULATE & VAPOUR PHASES COMBINED

Total Other Heavy Metals Combined

Test	Sampling Times	Concentration mg/m ³	LOD mg/m ³	Limit mg/m ³	Emission Rate g/hr
Run 1	07:52 - 08:27 15th September 2009	1.1	0.04	-	78
Field Blank	-	0.05	-	-	-

Reference conditions are 273K, 101.3Pa, without correction for water vapour content

INDIVIDUAL METALS SUMMARY - PARTICULATE & VAPOUR PHASES COMBINED

Reference conditions are 273K, 101.3Pa, without correction for water vapour content

Metals	LOD mg/m ³	Concentration mg/m ³	Emission Rate g/hr	Limit mg/m ³
Lead	0.0191	0.079	5.41	5
Nickel	0.0008	0.570	39.17	1
Cadmium	0.0001	0.022	1.53	0.5
Chromium	0.0116	0.044	3.03	-
Vanadium	0.0001	0.004	0.28	-
Copper	0.0061	0.418	28.70	-
Combined Cr, Cu & V	0.0178	0.466	32.01	1.5
Total Other Heavy Metals	0.0378	1.137	78.13	

Reference conditions are 273K, 101.3Pa, without correction for water vapour content

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

HEAVY METALS - SUMMARY RUN 1

Metals	Particulate Phase			Vapour Phase		
	Stack LOD mg/m ³	Laboratory Result ug	Concentration mg/m ³	Stack LOD mg/m ³	Laboratory Result ug	Concentration mg/m ³
Lead	0.00003	9.600	0.014	0.019	46.20	0.065
Nickel	0.00004	8.000	0.011	0.001	395.76	0.559
Cadmium	0.00001	0.260	0.000	0.000	15.55	0.022
Chromium	0.00014	3.500	0.005	0.011	27.72	0.039
Vanadium	0.00003	2.700	0.004	0.000	0.23	0.000
Copper	0.00042	3.600	0.005	0.006	292.26	0.412
Total Other Heavy Metals	0.00068	27.660	0.039	0.037	777.72	1.098
Volume Sampled m ³	0.7086					

Reference conditions are 273K, 101.3Pa, without correction for water vapour content

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

HEAVY METALS - SUMMARY BLANK

Metals	Particulate Phase			Vapour Phase		
	Stack LOD mg/m ³	Laboratory Result ug	Concentration mg/m ³	Stack LOD mg/m ³	Laboratory Result ug	Concentration mg/m ³
Lead	0.00003	0.20000	0.00028	0.01905	13.80000	0.01948
Nickel	0.00004	0.49000	0.00069	0.00076	0.55200	0.00078
Cadmium	0.00001	0.01000	0.00001	0.00008	4.55400	0.00643
Chromium	0.00014	0.70000	0.00099	0.01143	8.28000	0.01169
Vanadium	0.00003	0.66000	0.00093	0.00010	0.06900	0.00010
Copper	0.00042	0.30000	0.00042	0.00572	4.14000	0.00584
Total Other Heavy Metals	0.00068	2.36000	0.00333	0.03713	31.39500	0.04431
Volume Sampled m ³	0.7086					

Reference conditions are 273K, 101.3Pa, without correction for water vapour content

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 1

Heavy Metals

Absolute pressure of stack gas, P_s			Molecular weight of dry gas, M_d		
Barometric pressure, P _b	mm Hg	757.5	CO ₂	%	15.80
Stack static pressure, P _{static}	mm H ₂ O	48.9	O ₂	%	20.9
P _s = $\frac{P_b + (P_{static})}{13.6}$	mm Hg	761.1	Total	%	36.70
			N ₂ (100 -Total)	%	63.30
			M _d = 0.44(%CO ₂)+0.32(%O ₂)+0.28(%N ₂)		31.36
Vol. of water vapour collected, V_{wstd}			Molecular weight of wet gas, M_s		
Moisture trap weight increase, V _l c	g	4.3	M _s = M _d (1 - B _{wo}) + 18(B _{wo})	g/gmol	31.26
V _{wstd} = (0.001246)(V _l c)	m ³	0.005	Velocity of stack gas, V_s		
Volume of gas metered dry, V_{mstd}			Pitot tube velocity constant, K _p		
Volume of gas sample through gas meter, V _m	m ³	0.876	Velocity pressure coefficient, C _p		34.97
Gas meter correction factor, Y _d		0.8603	Mean of velocity heads, ΔP _{avg}	mm H ₂ O	0.81
Mean dry gas meter temperature, T _m	°C	20.56	Mean square root of velocity heads, √ΔP		21.75
Mean pressure drop across orifice, ΔH	mmH ₂ O	69.64	Mean stack gas temperature, T _s	°C	4.66
			V _s = $\frac{(K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})}{\sqrt{(M_s)(P_s)}}$	m/s	83
V _{mstd} = $\frac{(0.3592)(V_m)(P_b + (\Delta H/13.6))(Y_d)}{T_m + 273}$		0.7032	Actual flow of stack gas, Q_a		
Volume of gas metered wet, V_{mstw}			Area of stack, A _s		
V _{mstw} = V _{mstd} + V _{wstd}	m ³	0.7086	Q _a = (60)(A _s)(V _s)	m ² m ³ /min	1.54 1493.4
Vol. of gas metered at O₂ Ref. Cond., V_{mstd}@X%O₂			Total flow of stack gas, Q		
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)	No		Conversion factor (K/mm.Hg)		0.3592
% oxygen measured in gas stream, act%O ₂	20.9		Q _{std} = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$	Dry	1137.0
% oxygen reference condition	21		Q _{stdO2} = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2 Ref)}{(T_s) + 273}$	@O2ref	No O2 Ref
O ₂ Reference Factor = $\frac{O_2 Ref - act\%O_2}{21.0 - ref\%O_2}$	No O2 Ref		Q _{stw} = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	Wet	1145.6
V _{mstd} @X%oxygen = (V _{mstd}) (O ₂ Ref)	m ³	No O2 Ref	Percent isokinetic, %I		
Moisture content, B_{wo}			Nozzle diameter, D _n		
B _{wo} = $\frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0075	Nozzle area, A _n	mm mm ²	5.90 27.34
		0.75	Total sampling time, θ	min	32
Moisture by FTIR			%I = $\frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(\theta)(1-B_{wo})}$		
		-	Acceptable isokinetic range 95% to 115%		
			Yes		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

HEAVY METALS QUALITY ASSURANCE CHECKLIST

Leak Test Results	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests litre/min
Run 1	23.6	0.09	0.09	-304.8	0.47	Yes

Isokinetic Criterion Compliance	Isokinetic Variation %	Acceptable Isokineticity
Run 1	108.8	Yes

Filtration	Filter Material	Filter Size mm	Maximum Filtration Temperature °C
Run 1	QF	47	0

GF = Glass Fibre

QF = Quartz Fibre

Metals	Type of Absorbers - Metals	Absorption Solutions - Metals
Run 1	PTFE	3.3% Nitric Acid, 1.5% Hydrogen Peroxide

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

HEAVY METALS - ABSORPTION EFFICIENCIES

Parameter		Total ug	3rd Absorber ug	Absorption Efficiency (%)	Required %	Pass / Fail
Lead	Run 1	55.8	7.80	86	90	Failed
Nickel	Run 1	403.76	15.60	96	90	Passed
Cadmium	Run 1	15.81	2.50	84	90	Failed
Chromium	Run 1	31.2	4.68	85	90	Failed
Vanadium	Run 1	2.93	0.04	99	90	Passed
Copper	Run 1	295.9	2.34	99	90	Passed

HYDROGEN CHLORIDE SUMMARY

Test	Sampling Times	Concentration mg/m ³	LOD mg/m ³	Limit mg/m ³	Emission Rate g/hr
Run 1	10:23 - 10:55 15th September 2009	0.57	0.002	100	35.7
Field Blank	-	0.006	-	-	-

Reference conditions are 273K, 101.3Pa, without correction for water vapour content

HYDROGEN CHLORIDE QUALITY ASSURANCE CHECKLIST

Leak Test Results	Mean Sampling Rate	Pre sampling leak rate	Post sampling leak rate	Acceptable leak rate	Leak Tests Acceptable?
	l/min	l/min	l/min	l/min	
Run 1	20.0	0.12	0.11	0.40	Yes

Filtration	Filter Material	Filter Size mm	Max. Filtration Temp. °C	Type of Absorbers	Absorption Solutions
Run 1	QF	47	82	Glass	HPLC Water

GF = Glass Fibre

QF = Quartz Fibre

HYDROGEN CHLORIDE ABSORPTION EFFICIENCY

Parameter	Total ug	IMP 2 ug	Absorption Efficiency %	Acceptable Absorption Efficiency %	Absorption Efficiency Acceptable ?
Run 1	346	1.4	N/A	95	N/A

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS 1

Hydrogen Chloride

Absolute pressure of stack gas, P_s			Velocity of stack gas, V_s		
Barometric pressure, P _b	mm Hg	758	Pitot tube velocity constant, K _p		34.97
Stack static pressure, P _{static}	mm H ₂ O	49	Velocity pressure coefficient, C _p		0.81
P _s = P _b + (P _{static})	mm Hg	761	Average of velocity heads, Δp _{avg}		18.18
13.6			Average square root of velocity heads, √ΔP		4.26
Vol. of water vapour collected, V_{wstd}			Average stack gas temperature, T _s		82
Moisture trap weight increase, V _{lc}	g	4.3	$V_s = (K_p)(C_p)(\sqrt{\Delta P})(\sqrt{T_s + 273})$ $\sqrt{(M_s)(P_s)}$		
V _{wstd} = (0.001246)(V _{lc})	m ³	0.005332			
Volume of gas metered dry, V_{mstd}			Actual flow of stack gas, Q_a		
Volume of gas sample through gas meter, V _m	m ³	0.7450	Area of stack, A _s		1.54
Gas meter correction factor, Y _d		0.8603	Q _a = (60)(A _s)(V _s)		1363
Mean dry gas meter temperature, T _m	°C	17.00	Dry total flow of stack gas, Q_{std}		
Mean pressure drop across orifice, ΔH	mm Hg	57.71	Conversion factor (K/mm.Hg)		0.3592
V _{mstd} = (0.3592)(V _m)(P _b + (ΔH/13.6))(Y _d)		0.60	Q _{std} = (Q _a)P _s (0.3592)(1 - B _{wo})		1040
T _m + 273			(T _s) + 273		
Volume of gas metered wet, V_{mstw}			Wet total flow of stack gas, Q_{stw}		
V _{mstw} = V _{mstd} + V _{wstd}	m ³	0.6101	Q _{stw} = (Q _a)P _s (0.3592)		1050
Vol. of gas metered at O₂ Ref. Cond., V_{mstd@X%O2}			(T _s) + 273		
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)	No		Dry total flow of stack gas at X% O₂, Q_{stdO2}		
% oxygen measured in gas stream, act%O ₂	20.9		Q _{stdO2} = (Q _a)P _s (0.3592)(1 - B _{wo})(O ₂ REF)	m ³ /min	No O2 Ref
% oxygen reference condition	21		(T _s) + 273		
O ₂ Reference O2 Ref = 21.0 - act%O ₂	No O2 Ref		Percent isokinetic, %I		
Factor 21.0 - ref%O ₂	No O2 Ref		Nozzle diameter, D _n		5.90
V _{mstd@X%oxygen} = (V _{mstd}) (O ₂ Ref)	m ³	No O2 Ref	Nozzle area, A _n		27.34
Moisture content, B_{wo}			Total sampling time, θ	min	32
B _{wo} = V _{wstd}		0.0087	%I = (4.6398E6)(T _s + 273)(V _{mstd})		102
V _{mstd} + V _{wstd}	%	0.87	(P _s)(V _s)(A _n)(θ)(1 - B _{wo})		
Moisture by FTIR			Acceptable isokinetic range 95% to 115%		Yes
Molecular weight of dry gas, M_d			Hydrogen Chloride Concentration, C		
CO ₂	15.80		Mass collected, M	ug	346
O ₂	20.9		C _{wet} = M	mg/m ³	0.567
Total	36.70		V _{mstw}		
N ₂ (100 - Total)	63.30		C _{dry} = M	mg/m ³	0.572
M _d = 0.44(%CO ₂) + 0.32(%O ₂) + 0.28(%N ₂)	31.36		V _{mstd}		
Molecular weight of wet gas, M_s			C _{dry@X%O2} = M	mg/m ³	No O2 Ref
M _s = M _d (1 - B _{wo}) + 18(B _{wo})	g/gmol	31.2	V _{mstd@X%oxygen}		
Hydrogen Chloride Emission Rates, E			Hydrogen Chloride Concentration, C		
			E = [(C _{wet})(Q _{stw})(60)] / 1000	g/hr	35.73

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

HYDROGEN FLUORIDE SUMMARY

Test	Sampling Times	Concentration mg/m ³	LOD mg/m ³	Limit mg/m ³	Emission Rate g/hr
Run 1	11:31 - 12:01 15th September 2009	0.41	0.17	5	25.3
Field Blank	-	0.21	-	-	-

Reference conditions are 273K, 101.3Pa, without correction for water vapour content

HYDROGEN FLUORIDE QUALITY ASSURANCE CHECKLIST

Leak Test Results	Mean Sampling Rate l/min	Pre sampling leak rate l/min	Post sampling leak rate l/min	Acceptable leak rate l/min	Leak Tests Acceptable?
Run 1	2.0	0.02	0.02	0.04	Yes

Filtration	Filter Material	Filter Size mm	Max. Filtration Temp. °C	Type of Absorbers	Absorption Solutions
Run 1	QF	47	150	Quartz	NaOH

GF = Glass Fibre

QF = Quartz Fibre

HYDROGEN FLUORIDE ABSORPTION EFFICIENCY

Parameter	Total ug	IMP 2 ug	Absorption Efficiency %	Acceptable Absorption Efficiency %	Absorption Efficiency Acceptable ?
Run 1	24.4	ND	Not Determined	95	Not Determined

ND: Non Detected

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PRELIMINARY STACK SURVEY

Stack Diameter / Depth, D	1.40	m
Stack Width, W	-	m
Stack Area, A	1.54	m ²
Average stack gas temperature	82	°C
Pitot static pressure	0.48	kPa
Barometric Pressure	101	kPa
Pitot tube calibration coefficient, K_{pt}	0.81	-

Stack Gas Composition & Molecular Weights

Component	Molar Mass M	Density kg/m ³ p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m ³ pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m ³ pi
CO ₂	44	1.9631	15.80	0.158	0.31	15.66	0.16	0.31
O ₂	32	1.4277	20.95	0.210	0.30	20.77	0.21	0.30
N ₂	28	1.2492	63.25	0.633	0.79	62.69	0.63	0.78
H ₂ O	18	0.8031	-	-	-	0.88	0.01	0.01

Where:

$$p = M / 22.41$$

$$pi = r \times p$$

Calculation of Stack Gas Densities

Determinand	Result	Units
Dry Density (STP), P_{STD}	1.3994	kg/m ³
Wet Density (STP), P_{STW}	1.3942	kg/m ³
Dry Density (Actual), P_{Actual}	1.0781	kg/m ³
Average Wet Density (Actual), $P_{ActualW}$	1.074	kg/m ³

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PRELIMINARY STACK SURVEY

TRAVERSE 1

Date of Survey	15th September 2009
Time of Survey	10:01
Velocity Measurement Device:	S-Type

Sampling Line A							
Traverse Point	Distance into duct (m)	ΔP_{pt} mmH ₂ O	ΔP_{pt} Pa	Temp °C	Velocity m/s	O ₂ % Vol	Angle of Swirl °
1	0.07	17.6	172	82	14.52	-	0
2	0.21	17.6	172	82	14.52	-	0
3	0.35	17.8	174	82	14.60	-	0
4	0.49	17.8	174	82	14.60	-	0
5	0.63	17.7	173	82	14.56	-	0
6	0.77	17.4	171	82	14.44	-	0
7	0.91	17.5	172	82	14.48	-	0
8	1.05	17.6	172	82	14.52	-	0
9	1.19	17.6	172	82	14.52	-	0
10	1.33	17.3	170	82	14.39	-	0
Mean	-	17.59	172	82	14.51	-	
Sampling Line B							
Traverse Point	Distance into duct (m)	ΔP_{pt} mmH ₂ O	ΔP_{pt} Pa	Temp °C	Velocity m/s	O ₂ % Vol	Angle of Swirl °
1	0.07	17.7	173	82	14.56	-	0
2	0.21	17.8	174	82	14.60	-	0
3	0.35	17.8	174	82	14.60	-	0
4	0.49	18.1	177	82	14.72	-	0
5	0.63	18.0	176	82	14.68	-	0
6	0.77	17.9	175	82	14.64	-	0
7	0.91	17.9	175	82	14.64	-	0
8	1.05	17.6	172	82	14.52	-	0
9	1.19	17.4	171	82	14.44	-	0
10	1.33	17.5	172	82	14.48	-	0
Mean	-	17.77	174	82	14.59	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PRELIMINARY STACK SURVEY (CONTINUED)

TRAVERSE 1 CONTINUED

Sampling Line C							
Traverse Point	Distance into duct (m)	ΔP_{pt} mmH ₂ O	ΔP_{pt} Pa	Temp °C	Velocity m/s	O ₃ % Vol	Angle of Swirl °
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	
Sampling Line D							
Traverse Point	Distance into duct (m)	ΔP_{pt} mmH ₂ O	ΔP_{pt} Pa	Temp °C	Velocity m/s	O ₃ % Vol	Angle of Swirl °
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	-	-	-	-	-
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-
Mean	-	-	-	-	-	-	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PRELIMINARY STACK SURVEY (CONTINUED)

Sampling Plane Validation Criteria

EA Technical Guidance Document (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	169.54	Pa	$\geq 5 \text{ Pa}$	Yes
Lowest Gas Velocity	14.39	m/s	-	-
Highest Gas Velocity	14.72	m/s	-	-
Ratio of Above	1.02	-	$< 3 : 1$	Yes
Angle of flow with regard to duct axis	0	°	$< 15^\circ$	Yes
No local negative flow	-	-	-	Yes

Other Sampling Method Criteria	Result	Units	Requirement	Compliant
Mean Velocity	14.55	m/s	-	-
Standard Deviation of Velocity from Mean	0.59	%	$< 10\%$	Yes
Mean Oxygen	20.95	%	-	-
Standard Deviation of Oxygen from Mean	-	%	$< 15\%$	-
Homogeneous flow stream / gas velocity	-	-	-	Yes

Where:

P_{STD} = sum of component concentrations, kg/m^3 (not including water vapour)

$P_{STW} = (P_{STD} + p_i \text{ of } \text{H}_2\text{O}) / (1 + (p_i \text{ of } \text{H}_2\text{O} / 0.8036))$

$P_{Actual} = P_{STD} \times (T_s / P_s) \times (P_a / T_a)$

$P_{ActualW}$ (at each sampling point) = $P_{STW} \times (T_s / P_s) \times (P_a / T_a)$

Calculation of Stack Gas Velocity, V

Velocity at Traverse Point, $V = K_{pt} \times (1-\epsilon) \times \sqrt{(2 \times \Delta P_{pt} / P_{ActualW})}$

Calculation based on BS 1042:Section 2.1:1983 (Section 7 - Velocity Computation)

Where:

K_{pt} = Pitot tube calibration coefficient

$(1-\epsilon)$ = Compressibility correction factor, assumed at a constant 0.998

Average Stack Gas Velocity, V_a 14.55 m/s

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

PRELIMINARY STACK SURVEY (CONTINUED)

Calculation of Stack Gas Volumetric Flowrate, Q

Sampling plane reference conditions

Duct gas flow conditions	Actual	Reference	Units
Temperature	82	0	°C
Total Pressure	101.5	101.3	kPa
Oxygen	21.0	21	%
Moisture	0.88	0.88	%

Gas Volumetric Flowrate	Result	Units
Gas Volumetric Flowrate (Actual), Q_{Actual}	80648	m ³ /hr
Gas Volumetric Flowrate (STP, Wet), Q_{STP}	62130	m ³ /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$	61584	m ³ /hr
Gas Volumetric Flowrate (REF), Q_{Ref}	62130	m ³ /hr

Where:

$$Q_{Actual} = V_a \times A \times 3600$$

$$Q_{STP} = Q (Actual) \times (T_s / T_a) \times (P_a / P_s) \times 3600$$

$$Q_{STP,Dry} = Q (STP) / (100 - (100 / Ma)) \times 3600$$

$$Q_{Ref} = Q (STP) \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$$

Nomenclature:

T_s = Absolute Temperature, Standard Conditions, 273 K

P_s = Absolute Pressure, Standard Conditions, 101.3 kPa

T_a = Absolute Temperature, Actual Conditions, K

P_a = Absolute Pressure, Actual Conditions, kPa

Ma = Water vapour, Actual Conditions, % Vol

Ms = Water vapour, Reference Conditions, % Vol


O_{2a} = Oxygen, Actual Conditions, % Vol

O_{2s} = Oxygen, Reference Conditions, % Vol

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

STACK DIAGRAM

	Value	Units
Stack Depth	1.40	m
Stack Width	-	m
Area	1.54	m ²



Non-Isokinetic Sampling

Sampling Point	Distance (% of Depth)	Distance into Stack	Units
A	40	0.56	m

Isokinetic Sampling CEN Methods

Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	6.7	0.09	2
2	25.0	0.35	3
3	75.0	1.05	2
4	93.3	1.31	4
5	6.7	0.09	2
6	25.0	0.35	3
7	75.0	1.05	1
8	93.3	1.31	1
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-

APPENDIX 3 - Calibrateable Equipment Checklist & Calibration Gases

CALIBRATEABLE EQUIPMENT CHECKLIST

Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	LAB 13-12	Horiba PG-250 Analyser	-	Laboratory Balance	LAB 0001
Box Thermocouples	LAB 03-12	Horiba PG-200 Cooler	-	Tapemeasure	LAB 24-06
Meter In Thermocouple	-	JCT JCC P-1 Cooler	-	Stopwatch	-
Meter Out Thermocouple	-	Testo 350 Analyser	-	Protractor	LAB 08-01
Control Box Timer	LAB 17-12	Testo 339 Cooler	-	Barometer	LAB 08-01
Umbilical	LAB 03-29	FT-IR	-	Digital Micromanometer	LAB 01-07
Oven Box	LAB 09-16	FT-IR Oven Box	-	Digital Temperature Meter	LAB 03-34
Probe	LAB 1013	Bernath 3006 FID	-	Stack Thermocouple	LAB 11-08
S-Pitot	LAB 05-08	Signal 3010 MINIFID	-	Drycal	-
L-Pitot	-	Signal 3030 FID	-	Mass Flow Controller	-
Site Balance	LAB 14-09	Servomex	-	Mass Flow Control Box	-
Last Impinger Arm	-	JCT Heated Head Filter	-	1m Heated Line	-
Calipers	LAB 0058	Stackmaster Heated Filter	-	5m Heated Line (1)	-
Small DGM	-		-	5m Heated Line (2)	-
			-	10m Heated Line (1)	-
			-	10m Heated Line (2)	-
			-	15m Heated Line (1)	-
			-	15m Heated Line (2)	-
			-	20m Heated Line (1)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

APPENDIX 4 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - TOTAL PARTICULATE MATTER

Run	Sampled Volume m ³	Sampled Gas Temp K	Sampled Gas Pressure KPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Mass of Particulate mg	Leak %	Uncollected Mass mg
MU required	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 5% of ELV	≤ 2%	≤ 10% of ELV
Run 1	0.001	2	1	1	N/A	0.29120	-	-
as a %	0.16	0.69	0.99	1.00	N/A	1.37750	0.55	0.00
compliant?	Yes	Yes	Yes	Yes	N/A	Yes	Yes	Yes

Run	Volume (STP) m ³	Mass of particulate mg	O2 Correction -	Leak mg/m ³	Uncollected Mass mg	Combined uncertainty
Run 1	0.58	21.1400	1.00	0.110	0.00	-
MU as mg/m ³	0.15	0.2092	-	0.068	0.00	0.73
MU as %	1.57	1.3775	-	0.317	0.00	-

R1 - Uncertainty expressed at a 95% confidence level (where k = 2)	1.47	mg/m³	4.23	%
---	-------------	-------------------------	-------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)

Developed for the STA by R Robinson, NPL

APPENDIX 4 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - HEAVY METALS

Run	Sampled Volume m ³	Sampled Gas Temp K	Sampled Gas Pressure KPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Concentration in impinger mg	Mass of Heavy Metals %	Leak %
MU required	<=2%	<2.5 k	<=1%	<=1%	<=5%	<5%	<5%	<=2%
Run 1	0.71	273.00	105.80	0.00	-	2.88	0.81	-
as a %	0.14	0.73	0.95	1.00	-	3.00	-	0.38
compliant?	Yes	Yes	Yes	Yes	N/A	Yes	-	Yes

Run	Volume (STP) m ³	Mass of Heavy Metals mg	O2 Correction -	Leak mg/m ³	Lab Uncertainty mg	Combined uncertainty
Run 1	0.7400	0.8054	-	0.0025	-	-
MU as mg/m ³	0.0178	0.0344	-	0.0025	0.1137	0.1201
MU as %	1.5647	3.0228	-	0.2206	10.0	-

R1 - Uncertainty expressed at a 95% confidence level (where k = 2)	0.24	mg/m³	21.13	%
---	-------------	-------------------------	--------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)

Developed for the STA by R Robinson, NPL

APPENDIX 4 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - ISOKINETIC HYDROGEN CHLORIDE

Run	Sampled Volume	Sampled Gas Temp	Sampled Gas Pressure	Sampled Gas Humidity	Oxygen Content	Concentration in impinger	Mass of Hydrogen Chloride	Leak
	m ³	K	KPa	% by volume	% by volume	mg	%	%
MU required	<=2%	<2.5 k	<=1%	<=1%	<=5%	<5%	<5%	<=2%
Run 1	0.61005628	290.00	105.8	0	-	0.009911111	0.00223	-
as a %	0.16	0.69	0.95	1.00	-	3.00	3.03	0.55
compliant?	Yes	Yes	Yes	Yes	N/A	Yes	Yes	Yes

Run	Volume (STP)	Mass of Hydrogen Chloride	O2 Correction	Leak	Lab Uncertainty	Combined uncertainty
	m ³	mg	-	mg/m ³	mg	
Run 1	0.5998	0.0022	-	0.0018	-	-
MU as mg/m ³	0.0088	0.0172	-	0.0018	0.0000	0.0194
MU as %	1.5482	3.0327	-	0.3171	0.0	-

R1 - Uncertainty expressed at a 95% confidence level (where k = 2)	0.04	mg/m³	6.84	%
---	-------------	-------------------------	-------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)

Developed for the STA by R Robinson, NPL

APPENDIX 4 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - NON-ISOKINETIC HYDROGEN FLUORIDE

Run	Sampled Volume	Sampled Gas Temp	Sampled Gas Pressure	Sampled Gas Humidity	Oxygen Content	Concentration in impinger	Mass of Hydrogen Fluoride	Leak
	m ³	K	KPa	% by volume	% by volume	mg	%	%
MU required	<=2%	<2.5 k	<=1%	<=1%	<=5%	<5%	<5% of limit value	<=2%
Run 1	0.001	2.000	1.000	1.000	0.100	0.003	0.001	-
as a %	1.652	0.707	0.131	1.000	-	3.000	3.028	1.000
compliant?	Yes	Yes	Yes	Yes	N/A	Yes	Yes	Yes

Run	Volume (STP)	Mass of Hydrogen Fluoride	O2 Correction	Leak	Lab Uncertainty	Combined uncertainty
	m ³	mg	-	mg/m ³	mg	
Run 1	0.4392	0.0244	-	0.0023	-	-
MU as mg/m ³	0.0051	0.0123	-	0.0023	0.0203	0.0244
MU as %	1.2524	3.0279	-	0.5774	5.0	-

R1 - Uncertainty expressed at a 95% confidence level (where k = 2)	0.05	mg/m³	12.01	%
---	-------------	-------------------------	--------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)

Developed for the STA by R Robinson, NPL

APPENDIX 4 - Measurement Uncertainty Budget Calculations

MEASUREMENT UNCERTAINTY BUDGET - MOISTURE

Run	Sampled m ³	Sampled Gas K	Sampled Gas KPa	Sampled Gas % by volume	Oxygen % by volume	Leak %	Uncollected mg
MU required	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 2%	≤ 10% of ELV
Run 1	0.001	2	1	1	N/A	-	-
as a %	0.16	0.69	0.99	1.00	N/A	0.55	2.33
compliant?	Yes	Yes	Yes	Yes	N/A	Yes	Yes
Run	Volume (STP) m ³	Mass Gained mg	O2 Correction -	Leak mg/m ³	Uncollected Mass mg	Combined uncertainty	
Run 1	0.58	4300.00	1.00	22.35	57.74	-	
MU as % v/v	0.01	0.02	-	0.00	0.012	0.03	
MU as %	1.57	2.33	-	0.32	1.34	-	

R1 - Uncertainty expressed at a 95% confidence level (where k = 2)	0.06	% v/v	6.26	%
---	-------------	--------------	-------------	----------

APPENDIX 5 - Waste Oil Analysis

WASTE OIL ANALYSIS

Parameter	Concentration mg/kg	Limit
Cadmium	1	-
Nickel	2	-
Lead	23	-
Chromium	10	-
Copper	1	-
Vanadium	1	-
Chloride	150	-
Fluoride	47	-
Sulphur	0.39	1%
Total PCB's	< 5	5 mg/Kg