

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Premises Burton Brothers

Person Seen LUC Tibbles

Address Bury Road, Remsey PE26 1NG

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

conducted on behalf of Huntingdon District Council

22/07/143 - Works achieved

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N

Satisfactory Y/N

Notes:

No incidents recorded
Vent 2 damaged, has been
rechecked - not documented

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected Y/N

Satisfactory Y/N

Notes:

15/06/13

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N

Satisfactory Y/N

Notes:

No incidents

d) STAFF COMPETENCE & TRAINING

No of Staff 12

No Questioned 1

Inspected Y/N

Satisfactory Y/N

Notes:

inform staff training & let stock
to be transferred

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/N

Satisfactory Y/N

Notes:

Does the site have stage II vapour recovery? Y/N Y

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

enquired what the vents are for
- information to be transferred.

Are procedures in place adequate in the event of any leaks
or spillages? Y/N

Notes:

old site

Signed [Signature]

Tel /Email 01454 284 628

Received by [Signature]

Date/Time 18/06/13 10:16

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.