

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

APPENDIX 1

Premise Tesco Service Station Person Seen Caroline Horsted
Address Abbots Ripton Rd. Huntingdon

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes: No incidents reported.

d) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES (Annual)

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes: Certificate dated Oct 2010.

b) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes: Certificate of testing dated October 2010.

e) STAFF COMPETENCE & TRAINING

No of Staff No Questioned

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes: Training records inspected. All current and ongoing

c) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes: Sign required for tank 2. Has been ordered.

Does the site have stage II vapour recovery? ☒ Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory ☒ Y/N

Notes:

Are procedures in place adequate in the event of any leaks or spillages? ☒ Y/N

Notes:

Inspector Sharon Whittington Date 1/8/2011

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.

Contract for the conduct of process permits: HDC & CCC