

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

APPENDIX 1

Premise Pace, Person Seen Nichole Castle,
Address Needingworth Rd. St Ives.

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

See S.C.

Drainage channels have some dust/litter but are not a concern - suggested clearing in near future.

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N

Satisfactory Y/N

Notes:

None recorded.

d) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES (Annual)

Inspected Y/N

Satisfactory Y/N

Notes:

Certificate date 20/7/09.

b) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N

Satisfactory Y/N

Notes:

Satisfactory.

e) STAFF COMPETENCE & TRAINING

No of Staff 4

No Questioned 2

Inspected Y/N

Satisfactory Y/N

Notes:

c) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N

Satisfactory Y/N

Notes:

VR Notice to be removed from Tank 3 - Diesel.

Does the site have stage II vapour recovery? Y/N

Notes:

Due October when new dispensers are to be installed.

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes:

Forecourt drainage channels require clearing but are not detrimental at this time.

Inspector S. Smith Date 11/8/09.

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.

Contract for the conduct of process permits: HDC & CCC