

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

APPENDIX 1

Premise BP Little Hampton Serv St Person Seen Mr S Townsend
Address 23-25 London rd, York Ley, Peterborough, PE7 3NQ

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes:

d) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES (Annual)

Inspected Y/N Satisfactory Y/N

Notes:

Expired 23/08/10
VR to be kept locked

b) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes:

e) STAFF COMPETENCE & TRAINING

No of Staff No Questioned

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes:

c) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected ☒ Y/N Satisfactory Y/N

Notes:

Does the site have stage II vapour recovery? Y/N

Notes:


f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes:

Inspector  Date 31/09/10

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.

Contract for the conduct of process permits: HDC & CCC

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

APPENDIX 1

Premise BP Little Hampton Service St Person Seen Mr James Townsend
Address 23-25 London road. Yonckley, Peterborough, PE7 3NQ

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

received copy of VR Cert (expires 08/09/11) premises brought into compliance

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N Satisfactory Y/N

Notes:

d) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES (Annual)

Inspected Y/N Satisfactory Y/N

Notes:

b) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N Satisfactory Y/N

Notes:

e) STAFF COMPETENCE & TRAINING

No of Staff ☐ No Questioned ☐

Inspected Y/N Satisfactory Y/N

Notes:

c) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N Satisfactory Y/N

Notes:

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes:

Inspector 

Date 4/09/10

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation

STAGE 1B TESTING CERTIFICATE OF APPROVAL

CERTIFICATE NUMBER
FP/6081

ISSUED TO
Little Hampton SS (Vapour point 2), 23 - 25 London
Road, Yaxley, Peterborough, Cambridgeshire, PE7
3NQ

**THIS CERTIFICATE HAS BEEN ISSUED BY PETROMAN ENVIRONMENTAL
SERVICES LIMITED OF UNIT 5 SNEYD GREEN BUSINESS PARK,
SNEYD STREET, SNEYD GREEN, STOKE ON TRENT, ST6 2NP**

Full Site Address: Little Hampton SS (Vapour point 2), 23 - 25 London Road, Yaxley,
Peterborough, Cambridgeshire, PE7 3NQ

Name of Licence Holder:	TAE Service Stations Limited
Licensing Authority:	Cambridgeshire County Council
Authorised Testing Company:	Petroman Environmental Services LTD.
Authorised Test Engineer:	Alex Chatterton
ID Number:	26
Test Date:	09/09/2010

The Stage 1B Vapour Recovery System installed at the above site has been tested by the authorised engineer named above using the Petroman Testing Procedure. The results confirm that this Stage 1B Vapour Recovery System has **PASSED**.

We confirm that the PV and VR valves have proven to be in good operational condition and meet the environmental standards required of this equipment.

Pressure/Vacuum Valves Fitted:	Release Pressure	+35 mbars
	Vacuum Setting	-4 mbars

Vapour Recovery Connection Point **PASSED** for condition and sealing capacity.

This certificate is valid for a period of 1 year and expires on 08/09/2011

SIGNED



For and on behalf of Petroman Environmental Services Limited

STAGE 1B TESTING CERTIFICATE OF APPROVAL

CERTIFICATE NUMBER
FP/6081

ISSUED TO
Little Hampton SS (Vapour point 2), 23 - 25 London
Road, Yaxley, Peterborough, Cambridgeshire, PE7
3NQ

**THIS CERTIFICATE HAS BEEN ISSUED BY PETROMAN ENVIRONMENTAL
SERVICES LIMITED OF UNIT 5 SNEYD GREEN BUSINESS PARK,
SNEYD STREET, SNEYD GREEN, STOKE ON TRENT, ST6 2NP**

Full Site Address: Little Hampton SS (Vapour point 2), 23 - 25 London Road, Yaxley,
Peterborough, Cambridgeshire, PE7 3NQ

Name of Licence Holder:	TAE Service Stations Limited
Licensing Authority:	Cambridgeshire County Council
Authorised Testing Company:	Petroman Environmental Services LTD.
Authorised Test Engineer:	Alex Chatterton
ID Number:	26
Test Date:	09/09/2010

The Stage 1B Vapour Recovery System installed at the above site has been tested by the authorised engineer named above using the Petroman Testing Procedure. The results confirm that this Stage 1B Vapour Recovery System has **PASSED**.

We confirm that the PV and VR valves have proven to be in good operational condition and meet the environmental standards required of this equipment.

Pressure/Vacuum Valves Fitted:	Release Pressure	+35 mbars
	Vacuum Setting	-4 mbars

Vapour Recovery Connection Point **PASSED** for condition and sealing capacity.

This certificate is valid for a period of 1 year **and expires on** 08/09/2011

SIGNED



For and on behalf of Petroman Environmental Services Limited