

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

Premises Dauntsey Hunnigan Person Seen Ms Heather Livermore
Address 51 Germany Walk Hunnigan PR29 3TG

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

Inspection conducted by H Shepherd on behalf of Hunnigan
District Council.

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N Satisfactory Y/N

Notes:

Nothing documented
- no incidents

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected Y/N Satisfactory ☒ Y/N

Notes:

Date of next test 28/02/14
(E2S)

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N Satisfactory Y/N

Notes:

Nothing documented
No incidents.

d) STAFF COMPETENCE & TRAINING

No of Staff No Questioned

Inspected Y/N

Satisfactory Y/N

Notes:

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/N Satisfactory Y/N

Notes:

Vent 2 requires label

Does the site have stage II vapour recovery? ☒ Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory ☒ Y/N

Notes:

Workbook monitored externally
In my opinion a well run
site.

Are procedures in place adequate in the event of any leaks
or spillages? Y/N

Notes:

RA

Signed

[Signature]

Tel /Email

01954 284620

Received by

H. [Signature]

Date/Time

21/08/13 12:02

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.

9/9/13 - Points in hand.
28/01/14 - Message left