

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Premises Rekborough Services

Person Seen Ms Steph Wilson

Address A1 North

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

conducted on behalf of Rushmore District Council by H Shepherd
Trading Standards

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N

Satisfactory Y/N

Notes:

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected Y/N

Satisfactory Y/N

Notes:

Date of next test
17/11/13
No record of maintenance in
site register

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N

Satisfactory Y/N

Notes:

No records of maintenance

d) STAFF COMPETENCE & TRAINING

No of Staff 13

No Questioned 1

Inspected Y/N

Satisfactory Y/N

Notes:

Employee unable to explain
VF stage II. 13

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/N

Satisfactory Y/N

Notes:

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Are procedures in place adequate in the event of any leaks
or spillages? Y/N

Notes:

Risk assessment to be reviewed.

Signed [Signature]

Tel /Email 01454 284 628

Received by [Signature]

Date/Time 17/12/13

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.