

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Premises Texas Remedy

Person Seen Urky Lubbing

Address 11 Henry Road Remedy

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

concluded on behalf of Kershington District Council.

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N

Satisfactory Y/N

Notes:

Nothing documented

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected Y/N

Satisfactory Y/N

Notes:

Stage II Gilberts needle valve 18/04/13
expires

25/07/12 PM33

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N

Satisfactory Y/N

Notes:

Nothing documented
certs of inspection kept

d) STAFF COMPETENCE & TRAINING

No of Staff

No Questioned

Inspected Y/N

Satisfactory Y/N

Notes:

All silver & gold trained

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/N

Satisfactory Y/N

Notes:

Tanks topped and lifted - high
water table please ensure
labelled correctly tanks no grade
correctly (up own with Petrol)

Does the site have stage-II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Organised site

Are procedures in place adequate in the event of any leaks
or spillages? Y/N

Notes:

New site

Signed [Signature]

Tel / Email 01954 284628

Received by [Signature]

Date/Time 28/05/12