

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

Premises Alconbury Services

Person Seen Ms Lambert

Address Public Lee Alconbury Huntingdon PE28 4LD

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

Inspection conducted on behalf of Huntingdon District Council
Site opened August 2012

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N Satisfactory Y/N

Notes:

Nothing documented

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected Y/N Satisfactory Y/N

Notes:

~~No certificate available~~
Ideal tanks & Pumps had checked
Vents on 21/10/13
Stage II Gilbert & Keeler vent 6/5/15
(Empress)

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N Satisfactory Y/N

Notes:

Nothing documented

d) STAFF COMPETENCE & TRAINING

No of Staff ☒ 6 No Questioned ☐

Inspected Y/N

Satisfactory Y/N

Notes:

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/N Satisfactory Y/N

Notes:

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

reception advice issued -
records to be updated, fire
extinguisher in DCO to be checked &
phone to be programmed

Are procedures in place adequate in the event of any leaks
or spillages? Y/N

Notes:

Signed W. Replax

Received by W. Lambert

Tel /Email Wendy.L. Depherd@

depot@cambridgeshire.gov.uk

Date/Time 3/10/14