



NATIONAL PHYSICAL LABORATORY

Teddington Middlesex UK TW11 0LW Telephone +44 20 8977 3222

Test Report



This test report is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and to units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories. This test report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

PPC COMPLIANCE TESTING FOR PAXFORD COMPOSITES LIMITED 19TH - 20TH FEBRUARY 2013

Permit Number: **B01/02**

Operator Name: **Paxford Composites Ltd**

Installation Name: **Paxford Composites**

Dates of Monitoring Visit: **19th - 20th February 2013**

Contract Reference: **B0102/PAXFORD/PAXFORD/FEB2013/SBs/PPC/Visit 1**

Client Contact: **Neil Search**

Client Organisation: **Paxford Composites Ltd**

Address: **2 - 4 Redwongs Way
Huntingdon
PE29 7HB**

Monitoring Organisation: **National Physical Laboratory (NPL)**

Address: **Hampton Road
Teddington
Middlesex
TW11 0LW**

Date of Report: **13th March 2013**

Report Author: **Simon Render**

Reference: B0102/PAXFORD/PAXFORD/FEB2013/SBs/PPC/Visit 1

Report Approver: Kevin Blakley
MCERTS Registration: MM-03-317
Level & TEs Held: Level 2, TE1, TE2, TE3 & TE4
Signature:

NPL Authorised Signatory
Name: Mr R Robinson (for NPLML)
Signature:

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Contents Page

Part One: Executive Summary

Page

1.1	Monitoring Objectives	3
1.2.1	Particulate Monitoring Results	4
1.2.2	Isocyanates Monitoring Results	5
1.2.3	VOCs Monitoring Results	6
1.3	Operating Information	7
1.4	Monitoring Deviations	7
1.5	Conclusions	7
1.6	References	8

Part Two: Supporting Information

APPENDIX 1

2.1.1	Emissions Testing Personnel Details	10
2.1.2	Emissions Testing Procedures	10
2.1.3	Equipment Checklist Reference	11
2.1.4	Data Capture Location Reference	11

APPENDIX 2

2.2.1	Stack Diagram & Traverse Information	13
2.2.2	One Minute Averaged Gaseous Emissions Data	20
2.2.3	Gaseous Emissions Graphical Data	24
2.2.4	Gas Calibration Log	28
2.2.5	Particulate Summary Sheets	32
2.2.6	Sample Sheets	36
2.2.7	Moisture Calculations	55
2.2.8	Uncertainty Calculations	62
2.2.9	Analytical Results	69
2.2.10	Calculations Used in Reporting Results	71

1.1 Monitoring Objectives

NPL were awarded a contract by Paxford Composites Limited to carry out emissions compliance testing at their factory in Huntingdon. The scope of work includes carrying out monitoring on three spray paint booths.

Each spray paint booth was monitored for Particulates, Isocyanates and VOCs. Each test lasted for half an hour and was conducted during normal operation of the spray booths.

Results have been reported at standard conditions (273K and 101.3 kPa) on a wet gas basis. Testing was carried out on the 19th and 20th February 2013.

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

1.2.1 Particulate Monitoring Results

Client: Paxford Composites Ltd
Site: Paxford Composites

Emission Point		Spray Booth One		Spray Booth Two		Spray Booth Three	
Test Designation		Run One	Blank	Run One	Blank	Run One	Blank
Emission Limit Value	mg/m ³ , Reference Conditions	50	-	50	-	50	-
Periodic Monitoring Result	Reference Conditions	<0.2	<0.2	9.4	<0.2	1.2	<0.5
Uncertainty (95% Confidence Level)	Reference Conditions	0.2	-	0.6	-	1.1	-
	Units	mg/m ³					
Reference Conditions		273K, 101.3 kPa on a wet gas basis					
Date	dd/mm/yyyy	20/02/2013		19/02/2013		19/02/2013	
Sample Period	From hh:mm	10:36	-	14:00	-	15:45	-
	To hh:mm	11:06	-	14:30	-	16:15	-
Monitoring Method		BS EN 13284-1					
Accreditation		UKAS & MCERTS					
Process Status		Spray paint batch run					

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

1.2.2 Isocyanates (HDI) Monitoring Results

Client: Paxford Composites Ltd
Site: Paxford Composites

Emission Point		Spray Booth One		Spray Booth Two		Spray Booth Three	
Test Designation		Run One	Blank	Run One	Blank	Run One	Blank
Emission Limit Value	mg/m ³ , Reference Conditions	0.1	-	0.1	-	0.1	-
Periodic Monitoring Result	Reference Conditions	<0.0004	<0.0002	0.003	<0.0001	<0.0004	<0.0002
Uncertainty (95% Confidence Level)	Reference Conditions	0.0001	-	0.001	-	0.0001	-
	Units	mg/m ³					
Reference Conditions		273K, 101.3 kPa on a wet gas basis					
Date	dd/mm/yyyy	20/02/2013		19/02/2012		19/02/2013	
Sample Period	From hh:mm	11:12	-	14:50	-	16:23	-
	To hh:mm	11:42	-	15:20	-	16:53	-
Monitoring Method		US EPA CTM 36					
Accreditation		None					
Process Status		Spray paint batch run					

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

1.2.3 VOCs Monitoring Results

Client: Paxford Composites Ltd
Site: Paxford Composites

Emission Point		Spray Booth One	Spray Booth Two	Spray Booth Three
Test Designation		Run One	Run One	Run One
Emission Limit Value	mgC/m ³ , Reference Conditions	50	50	50
Periodic Monitoring Result	Reference Conditions	5.2	8.4	40.8
Uncertainty (95% Confidence Level)	Reference Conditions	1.0	1.2	5.8
	Units	mgC/m ³		
Reference Conditions		273K, 101.3 kPa on a wet gas basis		
Date	dd/mm/yyyy	20/02/2013	19/03/2013	19/03/2013
Sample Period	From hh:mm	11:00	14:45	16:15
	To hh:mm	11:30	15:15	16:45
Monitoring Method		BS EN 12619:2013		
Accreditation		UKAS & MCERTS		
Process Status		Spray paint batch run		

NATIONAL PHYSICAL LABORATORY

Continuation Sheet

1.3 Operating Information

Paxford Composites is located in Huntingdon and specialises in design and manufacturing of a wide range of components. The site also has spray painting facilities and can use a variety of different paints such as Epoxy, Polyurethane and Polyester.

The site has three spray paint booths each approximately the size of a garage, this allows large items to be transported inside. Air is pumped in from outside and can be heated if necessary to aid in the curing of the products. The paint filled air is then passed through a filter before being emitted to the atmosphere via a vent stack. Each batch run lasts approximately 20 to 30 minutes, depending upon how many layers of paint are required, and the size of the components.

Continuous or Batch Process?	Batch Process
What part of the batch process was sampled? (If applicable)	The whole batch process was sampled
What fuel was used during monitoring? (If applicable)	None
What feedstock was used during monitoring? (If applicable)	None
What was the load during monitoring?	N/A
What abatement systems are present? Were they in operation?	A filter is installed in the vent system to reduce particulate emissions. This was in operation during the time of the monitoring
Periodic monitoring results and corresponding CEM values	There are no CEMS installed on the spray booths

1.4 Monitoring Deviations

Were all substances in the monitoring objectives monitored? If not why?	All substances set out in the objectives were monitored
Were all substances monitored in accordance to the relevant method? If not why?	Due to the duct area size of each spray booth, two sampling lines are required to monitor particulates to BS EN 13284:1. Whilst ports were provided, only one port on each spray booth could be accessed due to external obstructions and general accessibility
Were there any other issues relevant to the monitoring results?	No

1.5 Conclusions

NPL carried out the emissions monitoring for particulates, isocyanates and VOCs on all three paint spray booths on the 19th and 20th February 2012. No homogeneity tests have been carried out.

1.6 References

1. STA – Risk Assessment Guide: Industrial-emission monitoring – Version 12 - June 2012.
2. Environmental Agency - Manual Stack emission monitoring performance standard for Organisations – Version 7.2 - November 2011.
3. Environmental Agency – M1 Technical Guidance Note – Sampling requirements for stack emission monitoring – Version 6 –January 2010.
4. Environmental Agency – M2 Technical Guidance Note – Monitoring of stack emissions to air – Version 9 – January 2013.
5. Guidance on Assessing Measurement Uncertainty in Stack Emissions Monitoring, by Pullen J and Robinson R, Source Testing Association, Quality Guidance Note QGN1.

APPENDIX 1

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

2.1.1 Emissions Testing Personnel Details

Name	Role	MCERTS Number	Certification Level & Expiry Dates					
			Level 1	Level 2	TE1	TE2	TE3	TE4
Simon Render	Team Leader	MM08 938	March-15	March-15	May-14	September-14	September-14	December-14
Matthew Ellison	Team Leader	MM05 682	September-13	September-13	September-13	September-13	December-13	September-13

2.1.2 Emissions Testing Procedures

Determinand	VOCs	Particulates	Isocyanates	H ₂ O	Stack Flow	Temperature
SRM Standard	BS EN 12619	BS EN 13284-1	US EPA CTM 36	BS EN 14790	BS EN 13284-1	BS EN 13284-1
Instrument	FID	APEX Method 5	APEX Method 5	APEX Method 5	Pitot	Type K Thermocouple
Instrument Serial No.	AS0234	AS0240	AS0240	AS0240	AS0466	N/A
Principle	FID	Gravimetric	HPLC	Gravimetric	Flow	Temperature
Operational Range	0 - 100 ppm	N/A	N/A	N/A	N/A	N/A
Certified Range	0 - 15 mg/m ³	N/A	N/A	N/A	N/A	N/A
Uncertainty	25%	15%	12%	20%	N/A	N/A
NPL Procedure	QPAS B 538	QPAS B 536	In House	QPAS B 536	QPAS B 536	QPAS B 536
UKAS Accreditation	YES	YES	NO	YES	YES	YES

Particulate and Isocyanate sampling was conducted using an APEX Method 5 and sampling train. A sample was extracted through a filter and then down a heated probe and sample line. The stack gas was then passed through a series of impingers to remove the moisture before passing through a dry gas meter (DGM) and out to atmosphere. The particulate filter had been weighed in a laboratory before and after testing in order to determine any weight gain. The isocyanate filter had been pre treated and sent to an analytical laboratory for analysis. The uncertainty quoted for the Isocyanate result is based upon the lab uncertainty.

VOC analysis was conducted using a SICK Bernath FID (Flame Ionisation Detector). A sample of stack gas was drawn through a heated filter and heated line before passing into the analyser.

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

The FID analyser zero and span settings were checked before and after each test run using zero grade nitrogen (ex BOC), a suitable gas mixture (BOC beta gas standard), traceable to national reference standards and a gas dilution system. The certified accuracies of the gas standards are listed below: -

SB1

Component	Sample Location	Cylinder ID	Certified Amount	Instrument Range	Certified Uncertainty
Propane	SB1	138227	53 ppm	0 - 100 ppm	1%

SB2

Component	Sample Location	Cylinder ID	Certified Amount	Instrument Range	Certified Uncertainty
Propane	SB2	138227	53 ppm	0 - 100 ppm	1%

SB3

Component	Sample Location	Cylinder ID	Certified Amount	Instrument Range	Certified Uncertainty
Propane	SB3	138227	53 ppm	0 - 1000 ppm	1%

These measurement uncertainties are expressed at a 95% level of confidence.

A leak test was conducted before testing to confirm hydraulic integrity of the gaseous sampling system. This was conducted by sending nitrogen down the entire sample line and ensuring a zero reading was obtained.

The electrical volt/millivolt outputs from the FID analyser was collected by a squirrel data logger and downloaded to digital media at the end of the day. Under the program used during the tests, the software records and stores individual readings every 2 seconds. From this data, the logger can perform a series of calculations to output 1 minute averaged measurement on a mass/volume basis. After each 1 minute average has been established the data buffer is reset and the process repeats.

2.1.3 Equipment Checklist Reference

See Work file PX05FEB13/CHECKLIST

2.1.4 Data Capture Location Reference


All data collected is transferred onto digital media at the end of the day, and then stored on the NPL internal servers upon arrival back at base. The location reference for this is below:

P:\Stack Emissions Team\Paxford Composites\PX05FEB13\7. Monitoring Record Sheets

APPENDIX 2

2.2.1 - Stack Diagram & Traverse Information

NATIONAL PHYSICAL LABORATORY
Continuation Sheet


Test no	SB1 Velocity		Site:	Paxford Composites		Stack Description:	SB1															
Date	20-2-13		Time of Survey:	10:05																		
Swirl Test Conducted	OK		SITE TEAM:	SDR & MRE																		
Stack Pres (with +/- above barometric if unknown enter zero)	0	mmH ₂ O	COMMENTS:	Temperature & Velocity Traverse																		
Pitot Type and Tube ID	AS0466		Diagram of Sample Location: 																			
Conditions	Value	Units																				
Stack pressure	768.63	mmHg																				
Ref oxygen Value	21	%																				
Moisture Content	1	%																				
CO	0	ppm																				
CO ₂	0	%																				
N ₂	79.05	%																				
O ₂	20.95	%																				
dry molecular wt	28.84																					
stack molecular wt	28.73																					
area of stack	0.47	m ²																				
Pbar	1024.5	mbar																				
Pbar	769	mmHg																				
pitot tube coeft	0.83																					
Reference Temp	273	K																				
Reference Pressure	760	mmHg																				
PITOT LEAK CHECK (Yes/No)	YES		<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 70%;">Flow Criteria Measurements</th> <th style="width: 10%;"></th> <th style="width: 20%;">Fulfilled?</th> </tr> <tr> <td>Is the gas flow angle <15° to the duct axis?</td> <td>Yes</td> <td>✓</td> </tr> <tr> <td>Is there any local negative flow?</td> <td>No</td> <td>✓</td> </tr> <tr> <td>Is the flow rate high enough to be measured?</td> <td>Yes</td> <td>✓</td> </tr> <tr> <td>Ratio of flows less than 3:1 (or 9:1 for pressure readings)?</td> <td>Yes</td> <td>✓</td> </tr> </table>					Flow Criteria Measurements		Fulfilled?	Is the gas flow angle <15° to the duct axis?	Yes	✓	Is there any local negative flow?	No	✓	Is the flow rate high enough to be measured?	Yes	✓	Ratio of flows less than 3:1 (or 9:1 for pressure readings)?	Yes	✓
Flow Criteria Measurements		Fulfilled?																				
Is the gas flow angle <15° to the duct axis?	Yes	✓																				
Is there any local negative flow?	No	✓																				
Is the flow rate high enough to be measured?	Yes	✓																				
Ratio of flows less than 3:1 (or 9:1 for pressure readings)?	Yes	✓																				

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

SAMPLING LINE: A							
Traverse Point	Distance into duct (m)	Δp mm H ₂ O	Δp Pa	Stack Temp T _s °C	Velocity @ stack gas T&P on wet gas basis m/s	Angle of Swirl °	$\sqrt{\Delta p}$
1	A10	18.20	178.42	13	14.09	<15	4.27
2	A9	16.40	160.77	13	13.38	<15	4.05
3	A8	16.00	156.85	13	13.21	<15	4.00
4	A7	11.20	109.79	13	11.05	<15	3.35
5	A6	5.60	54.90	13	7.82	<15	2.37
6	A5	4.80	47.05	13	7.24	<15	2.19
7	A4	3.80	37.25	12	6.43	<15	1.95
8	A3	3.60	35.29	12	6.26	<15	1.90
9	A2	2.40	23.53	12	5.11	<15	1.55
10	A1	2.20	21.57	12	4.89	<15	1.48
Average values		8.4	20.6	12.6	8.9	<15	2.7

Duct / Stack Flow Characteristics: SB1		
Test No: SB1 Velocity		
	Average	Units
Stack Velocity at stack gas T & P and a wet gas basis	8.95	ms ⁻¹
Stack flow @ STP, O ₂ (ref) and on a dry gas basis	N/A	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a wet gas basis	4.20	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a dry gas basis	4.16	m ³ s ⁻¹
Stack flow @ STP and on a wet gas basis	4.06	m ³ s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a wet gas basis	N/A	m ³ s ⁻¹

NATIONAL PHYSICAL LABORATORY
Continuation Sheet


Test no	SB2 Velocity		Site: Paxford Composites	Stack Description: SB2																
Date	19-2-13		Time of Survey:	12:55																
Swirl Test Conducted	OK		SITE TEAM: SDR & MRE																	
Stack Pres (with +/- above barometric if unknown enter zero)	0	mmH ₂ O	COMMENTS: Temperature & Velocity Traverse																	
Pitot Type and Tube ID	AS0466		Diagram of Sample Location: 																	
Conditions	Value	Units																		
Stack pressure	768.63	mmHg																		
Ref oxygen Value	21	%																		
Moisture Content	1	%																		
CO	0	ppm																		
CO ₂	0	%																		
N ₂	79.05	%																		
O ₂	20.95	%																		
dry molecular wt	28.84																			
stack molecular wt	28.73																			
area of stack	0.64	m ²																		
Pbar	1024.5	mbar																		
Pbar	769	mmHg																		
PITOT LEAK CHECK (Yes/No)	YES					<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 70%;">Flow Criteria Measurements</th> <th style="width: 10%;"></th> <th style="width: 20%;">Fulfilled?</th> </tr> <tr> <td>Is the gas flow angle <15° to the duct axis?</td> <td>Yes</td> <td>✓</td> </tr> <tr> <td>Is there any local negative flow?</td> <td>No</td> <td>✓</td> </tr> <tr> <td>Is the flow rate high enough to be measured?</td> <td>Yes</td> <td>✓</td> </tr> <tr> <td>Ratio of flows less than 3:1 (or 9:1 for pressure readings)?</td> <td>Yes</td> <td>✓</td> </tr> </table>			Flow Criteria Measurements		Fulfilled?	Is the gas flow angle <15° to the duct axis?	Yes	✓	Is there any local negative flow?	No	✓	Is the flow rate high enough to be measured?	Yes	✓
Flow Criteria Measurements		Fulfilled?																		
Is the gas flow angle <15° to the duct axis?	Yes	✓																		
Is there any local negative flow?	No	✓																		
Is the flow rate high enough to be measured?	Yes	✓																		
Ratio of flows less than 3:1 (or 9:1 for pressure readings)?	Yes	✓																		

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

SAMPLING LINE: A							
Traverse Point	Distance into duct (m)	Δp mm H ₂ O	Δp Pa	Stack Temp T _s °C	Velocity @ stack gas T&P on wet gas basis m/s	Angle of Swirl °	$\sqrt{\Delta p}$
1	A10	28.00	274.49	21	17.72	<15	5.29
2	A9	26.00	254.88	21	17.08	<15	5.10
3	A8	26.00	254.88	21	17.08	<15	5.10
4	A7	22.60	221.55	21	15.92	<15	4.75
5	A6	18.80	184.30	21	14.52	<15	4.34
6	A5	16.60	162.73	22	13.67	<15	4.07
7	A4	14.00	137.24	22	12.55	<15	3.74
8	A3	8.40	82.35	22	9.72	<15	2.90
9	A2	6.60	64.70	22	8.62	<15	2.57
10	A1	6.00	58.82	22	8.22	<15	2.45
Average values		17.3	42.4	21.5	13.5	<15	4.0

Duct / Stack Flow Characteristics: SB2		
Test No: SB2 Velocity		
	Average	Units
Stack Velocity at stack gas T & P and a wet gas basis	13.51	ms ⁻¹
Stack flow @ STP, O ₂ (ref) and on a dry gas basis	N/A	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a wet gas basis	8.65	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a dry gas basis	8.56	m ³ s ⁻¹
Stack flow @ STP and on a wet gas basis	8.11	m ³ s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a wet gas basis	N/A	m ³ s ⁻¹

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Test no	SB3 Velocity		Site: Paxford Composites	Stack Description: SB3																					
Date	19-2-13		Time of Survey:	15:15																					
Swirl Test Conducted	OK		SITE TEAM: SDR & MRE																						
Stack Pres (with +/- above barometric if unknown enter zero)	20	mmH ₂ O	COMMENTS: Temperature & Velocity Traverse																						
Pitot Type and Tube ID	AS0466		Diagram of Sample Location: 																						
Conditions	Value	Units																							
Stack pressure	770.10	mmHg																							
Ref oxygen Value	21	%																							
Moisture Content	1	%																							
CO	0	ppm																							
CO ₂	0	%																							
N ₂	79.05	%																							
O ₂	20.95	%																							
dry molecular wt	28.84																								
stack molecular wt	28.73																								
area of stack	0.59	m ²																							
Pbar	1024.5	mbar																							
Pbar	769	mmHg																							
pitot tube coeft	0.83																								
Reference Temp	273	K	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2" style="text-align: left;">Flow Criteria Measurements</th> <th></th> <th>Fulfilled?</th> </tr> <tr> <td colspan="2">Is the gas flow angle <15° to the duct axis?</td> <td>Yes</td> <td>✓</td> </tr> <tr> <td colspan="2">Is there any local negative flow?</td> <td>No</td> <td>✓</td> </tr> <tr> <td colspan="2">Is the flow rate high enough to be measured?</td> <td>Yes</td> <td>✓</td> </tr> <tr> <td colspan="2">Ratio of flows less than 3:1 (or 9:1 for pressure readings)?</td> <td>Yes</td> <td>✓</td> </tr> </table>			Flow Criteria Measurements			Fulfilled?	Is the gas flow angle <15° to the duct axis?		Yes	✓	Is there any local negative flow?		No	✓	Is the flow rate high enough to be measured?		Yes	✓	Ratio of flows less than 3:1 (or 9:1 for pressure readings)?		Yes	✓
Flow Criteria Measurements			Fulfilled?																						
Is the gas flow angle <15° to the duct axis?		Yes	✓																						
Is there any local negative flow?		No	✓																						
Is the flow rate high enough to be measured?		Yes	✓																						
Ratio of flows less than 3:1 (or 9:1 for pressure readings)?		Yes	✓																						
Reference Pressure	760	mmHg																							
PITOT LEAK CHECK (Yes/No)	YES																								

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

SAMPLING LINE: A							
Traverse Point	Distance into duct (m)	Δp mm H ₂ O	Δp Pa	Stack Temp T _s °C	Velocity @ stack gas T&P on wet gas basis m/s	Angle of Swirl °	$\sqrt{\Delta p}$
1	A10	22.00	215.67	22	15.72	<15	4.69
2	A9	22.00	215.67	22	15.72	<15	4.69
3	A8	21.40	209.79	22	15.50	<15	4.63
4	A7	20.60	201.94	22	15.21	<15	4.54
5	A6	18.80	184.30	22	14.53	<15	4.34
6	A5	16.00	156.85	22	13.41	<15	4.00
7	A4	15.60	152.93	22	13.24	<15	3.95
8	A3	10.20	99.99	22	10.70	<15	3.19
9	A2	8.00	78.42	22	9.48	<15	2.83
10	A1	8.20	80.39	22	9.60	<15	2.86
Average values		16.3	39.9	22.0	13.3	<15	4.0

Duct / Stack Flow Characteristics: SB3		
Test No: SB3 Velocity		
	Average	Units
Stack Velocity at stack gas T & P and a wet gas basis	13.31	ms ⁻¹
Stack flow @ STP, O ₂ (ref) and on a dry gas basis	N/A	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a wet gas basis	7.85	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a dry gas basis	7.78	m ³ s ⁻¹
Stack flow @ STP and on a wet gas basis	7.36	m ³ s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a wet gas basis	N/A	m ³ s ⁻¹

2.2.2 - One Minute Averaged Gaseous Emissions Data

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Paxford Composites - Spray Booth One
273K, 101.3 kPa, on a Wet Gas Basis
20th February 2013

Time	VOCs (Cmg/m³)
11:00	7.8
11:01	8.1
11:02	5.5
11:03	4.7
11:04	4.0
11:05	3.7
11:06	4.8
11:07	4.6
11:08	4.6
11:09	4.6
11:10	4.8
11:11	4.6
11:12	3.8
11:13	4.3
11:14	5.4
11:15	6.4
11:16	6.9
11:17	6.7
11:18	6.9
11:19	7.0
11:20	6.2
11:21	5.7
11:22	5.3
11:23	4.9
11:24	5.0
11:25	4.2
11:26	3.5
11:27	3.1
11:28	3.5
11:29	5.1
11:30	6.2
Maximum	8.1
Minimum	3.1
Average	5.2

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Paxford Composites - Spray Booth Two
273K, 101.3 kPa, on a Wet Gas Basis
19th February 2013

Time	VOCs (Cmg/m³)
14:45	7.4
14:46	9.0
14:47	9.7
14:48	9.0
14:49	11.3
14:50	18.3
14:51	15.8
14:52	13.3
14:53	18.0
14:54	21.4
14:55	18.1
14:56	13.1
14:57	10.0
14:58	8.1
14:59	7.1
15:00	6.2
15:01	6.8
15:02	5.6
15:03	5.0
15:04	4.5
15:05	4.3
15:06	4.1
15:07	3.8
15:08	3.7
15:09	3.5
15:10	3.3
15:11	3.3
15:12	3.1
15:13	6.6
15:14	3.8
15:15	3.1
Maximum	21.4
Minimum	3.1
Average	8.4


NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Paxford Composites - Spray Booth Three
273K, 101.3 kPa on a Wet Gas Basis
19th February 2013


Time	VOCs (Cmg/m ³)
16:15	39.2
16:16	37.1
16:17	35.4
16:18	34.6
16:19	35.1
16:20	34.1
16:21	34.3
16:22	34.3
16:23	33.7
16:24	31.6
16:25	29.9
16:26	28.3
16:27	26.7
16:28	25.5
16:29	26.5
16:30	96.5
16:31	102
16:32	75.9
16:33	60.2
16:34	49.4
16:35	42.3
16:36	37.0
16:37	33.2
16:38	30.5
16:39	28.6
16:40	27.1
16:41	26.1
16:42	25.3
16:43	24.6
16:44	28.0
16:45	92.9
Maximum	102
Minimum	24.6
Average	40.8

2.2.3 - Gaseous Emissions Graphical Data


Spray Booth One Minute Averaged VOCs Emissions Data - 20th February 2013
(273.15K, 101.325kPa, on a Wet Gas basis) using the NPL Conventional Analysis Package



Spray Booth Two Minute Averaged VOCs Emissions Data - 19th February 2013
(273.15K, 101.325kPa, on a Wet Gas basis) using the NPL Conventional Analysis Package



Spray Booth Three Minute Averaged VOCs Emissions Data - 19th February 2013
(273.15K, 101.325kPa on a Wet Gas basis) using the NPL Conventional Analysis Package



2.2.4 - Gas Calibration Log

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

GAS CALIBRATION MEASUREMENTS

Client:	Paxford Composites	Date:	20/02/2013	Horiba ID:	-
Site:	Paxford Composites	Job Number:	PX05FEB13	FID ID:	AS0234
Stack ID:	SB1	Mobile Lab ID:	BD09 WUR	Sonimix ID:	-
Reference oxygen %	N/A	Nitrogen cylinder ID:	Zero Grade	Initial N ₂ pressure bar	-

GAS CALIBRATION LOG - DIRECT CALIBRATION

		SO ₂	CO	NOx	O ₂	CO ₂	VOCs
Gas Cylinder ID:							138227
Initial Reg. Pressure bar							85
Cylinder Concentration:							53.0 ppm C ₃ H ₈
Span Value:							53.0 ppm C ₃ H ₈
Analyser Range:0 -							100 ppm C ₃ H ₈
Check	Time						09:24
Zero	Reading						0.27 ppm C ₃ H ₈
Adjust	Time						09:25
Zero	Reading						0 ppm C ₃ H ₈
Check	Time						09:26
Span	Reading						54.9 ppm C ₃ H ₈
Adjust	Time						09:27
Span	Reading						53.0 ppm C ₃ H ₈
Check	Time						09:29
Zero	Reading						0.0 ppm C ₃ H ₈

GAS CALIBRATION LOG - SYSTEM CAL (Including heated line and chiller unit)

		SO ₂	CO	NOx	O ₂	CO ₂	VOCs
Span Value:							53.0 ppm C ₃ H ₈
Check	Time						09:31
Zero	Reading						0.1 ppm
	Pass/fail						PASS
Check	Time						09:32
Span	Reading						52.9 ppm
	Response Time/s						20
	Pass/fail						PASS
Check	Time						09:34
Zero	Reading						0.1 ppm

GAS CALIBRATION LOG - POST CAL (Including heated line and chiller unit)

		SO ₂	CO	NOx	O ₂	CO ₂	VOCs
Span Value:							53.0 ppm C ₃ H ₈
Check	Time						11:45
Zero	Reading						0.01 ppm C ₃ H ₈
Check	Time						11:46
Span	Reading						52.4 ppm C ₃ H ₈
	Reg Pressure						85
Zero Repeatability as % of Range							0.1%
Acceptance							Accept
Zero Drift (%)							0.1
Span Drift (%)							1.0
							Accept

Comments:

CALIBRATION TO BE CARRIED OUT BY OR UNDER THE SUPERVISION OF MCERTS QUALIFIED PERSONNEL WITH LEVEL TWO AND TE4

Name:	Simon Render
MCERTS ID:	MM08-938

Personnel Present:	SDR/MRE
--------------------	---------

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

GAS CALIBRATION MEASUREMENTS

Client:	Paxford Composites	Date:	19/02/2013	Horiba ID:	-
Site:	Paxford Composites	Job Number:	PX05FEB13	FID ID:	AS0234
Stack ID:	SB2	Mobile Lab ID:	BD09 WUR	Sonimix ID:	-
Reference oxygen %	N/A	Nitrogen cylinder ID:	Zero Grade	Initial N ₂ pressure bar	-

GAS CALIBRATION LOG - DIRECT CALIBRATION

		SO ₂	CO	NOx	O ₂	CO ₂	VOCs
Gas Cylinder ID:							138227
Initial Reg. Pressure bar							85
Cylinder Concentration:							53.0 ppm C ₃ H ₈
Span Value:							53.0 ppm C ₃ H ₈
Analyser Range:0 -							100 ppm C ₃ H ₈
Check	Time						14:15
Zero	Reading						-0.19 ppm C ₃ H ₈
Adjust	Time						14:16
Zero	Reading						0 ppm C ₃ H ₈
Check	Time						14:17
Span	Reading						49.9 ppm C ₃ H ₈
Adjust	Time						14:18
Span	Reading						53.0 ppm C ₃ H ₈
Check	Time						14:19
Zero	Reading						0.0 ppm C ₃ H ₈

GAS CALIBRATION LOG - SYSTEM CAL (Including heated line and chiller unit)

		SO ₂	CO	NOx	O ₂	CO ₂	VOCs
Span Value:							53.0 ppm C ₃ H ₈
Check	Time						14:22
Zero	Reading						0.0 ppm
	Pass/fail						PASS
Check	Time						14:24
Span	Reading						52.7 ppm
	Response Time/s						20
	Pass/fail						PASS
Check	Time						14:26
Zero	Reading						0.1 ppm

GAS CALIBRATION LOG - POST CAL (Including heated line and chiller unit)

		SO ₂	CO	NOx	O ₂	CO ₂	VOCs
Span Value:							53.0 ppm C ₃ H ₈
Check	Time						15:22
Zero	Reading						-0.01 ppm C ₃ H ₈
Check	Time						15:24
Span	Reading						53.6 ppm C ₃ H ₈
	Reg Pressure						85
Zero Repeatability as % of Range							0.0%
Acceptance							Accept
Zero Drift (%)							0.0
Span Drift (%)							1.7
							Accept

Comments:

CALIBRATION TO BE CARRIED OUT BY OR UNDER THE SUPERVISION OF MCERTS QUALIFIED PERSONNEL WITH LEVEL TWO AND TE4

Name:	Simon Render
MCERTS ID:	MM08-938

Personnel Present:	SDR/MRE
--------------------	---------

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

GAS CALIBRATION MEASUREMENTS

Client:	Paxford Composites	Date:	19/02/2013	Horiba ID:	-
Site:	Paxford Composites	Job Number:	PX05FEB13	FID ID:	AS0234
Stack ID:	SB3	Mobile Lab ID:	BD09 WUR	Sonimix ID:	-
Reference oxygen %	N/A	Nitrogen cylinder ID:	Zero Grade	Initial N ₂ pressure bar	-

GAS CALIBRATION LOG - DIRECT CALIBRATION

	SO ₂	CO	NOx	O ₂	CO ₂	VOCs
Gas Cylinder ID:						138227
Initial Reg. Pressure bar						85
Cylinder Concentration:						53.0 ppm C ₃ H ₈
Span Value:						53.0 ppm C ₃ H ₈
Analyser Range:0 -						1000 ppm C ₃ H ₈
Check Zero	Time					15:33
	Reading					-0.08 ppm C ₃ H ₈
Adjust Zero	Time					15:34
	Reading					0 ppm C ₃ H ₈
Check Span	Time					15:35
	Reading					52.9 ppm C ₃ H ₈
Adjust Span	Time					15:36
	Reading					53.0 ppm C ₃ H ₈
Check Zero	Time					15:38
	Reading					0.1 ppm C ₃ H ₈

GAS CALIBRATION LOG - SYSTEM CAL (Including heated line and chiller unit)

	SO ₂	CO	NOx	O ₂	CO ₂	VOCs
Span Value:						53.0 ppm C ₃ H ₈
Check Zero	Time					15:40
	Reading					0.0 ppm
	Pass/fail					PASS
Check Span	Time					15:41
	Reading					52.9 ppm
	Response Time/s					20
	Pass/fail					PASS
Check Zero	Time					15:42
	Reading					0.0 ppm

GAS CALIBRATION LOG - POST CAL (Including heated line and chiller unit)

	SO ₂	CO	NOx	O ₂	CO ₂	VOCs
Span Value:						53.0 ppm C ₃ H ₈
Check Zero	Time					17:00
	Reading					-0.1 ppm C ₃ H ₈
Check Span	Time					17:02
	Reading					52.8 ppm C ₃ H ₈
	Reg Pressure					85
Zero Repeatability as % of Range						0.0%
Acceptance						Accept
Zero Drift (%)						0.0
Span Drift (%)						0.2
						Accept
Comments:						

CALIBRATION TO BE CARRIED OUT BY OR UNDER THE SUPERVISION OF MCERTS QUALIFIED PERSONNEL WITH LEVEL TWO AND TE4

Name:	Simon Render
MCERTS ID:	MM08-938

Personnel Present:	SDR/MRE
--------------------	---------

2.2.5 - Particulate Summary Sheets

SB1 Particulates Results Summary

Field	Units	Blank	TEST 1
Date	dd/mm/yyyy	20/02/2013	20/02/2013
Test No.		Blank	PM1
Filter No.		12TF220	12TF223
Stack Description		SB1	SB1
Start Time	hh:mm	-	10:36
End Time	hh:mm	-	11:06
Total Time	min	-	30
Stack Temp.	C	-	14
Gas Meter Temp	C	-	16
Gas Meter Pressure	kPa	-	102.5
Filter	mg	<0.2	<0.2
Washings	mg	<0.2	<0.2
TOTAL Mass Collected	mg	<0.2	<0.2
Test H ₂ O	% Vol	-	0.5
Stack Pressure	kPa	-	102.5
Nozzle Diameter	mm	-	5.02
Duct Area	m ²	-	0.47
Isokinicity	%	-	99
Stack Velocity	Stack T & P, uncorrected, ms ⁻¹	-	11.60
Gas Vol. Sampled	Dry Gas Basis, Ambient T and P	-	0.40
Gas Vol. Sampled	Wet Gas Basis, Standard T and P	-	0.39
Particulate Concentration	Wet Gas Basis, Standard T and P, mg Nm ⁻³	<0.2	<0.2
Expanded Uncertainty	+/-mg Nm ⁻³ , 95% Conf. k=2	-	0.2
Emission Limit Value (ELV)	Wet Gas Basis, Standard T and P, mg Nm ⁻³	50	50
Percentage of Emission Limit Value (ELV) for Test	Wet Gas Basis, Standard T and P, %	-	0
Mass Emission	Wet Gas Basis, Standard T and P, g s ⁻¹	-	0.002

SB2 Particulates Results Summary


Field	Units	Blank	TEST 1
Date	dd/mm/yyyy	19/02/2013	19/02/2013
Test No.		Blank	PM1
Filter No.		12TF216	12TF217
Stack Description		SB2	SB2
Start Time	hh:mm	-	14:00
End Time	hh:mm	-	14:30
Total Time	min	-	30
Stack Temp.	C	-	21
Gas Meter Temp	C	-	20
Gas Meter Pressure	kPa	-	102.5
Filter	mg	<0.2	5.0
Washings	mg	<0.2	3.7
TOTAL Mass Collected	mg	<0.2	8.8
Test H ₂ O	% Vol	-	0.9
Stack Pressure	kPa	-	102.5
Nozzle Diameter	mm	-	6.02
Duct Area	m ²	-	0.64
Isokinicity	%	-	100
Stack Velocity	Stack T & P, uncorrected, ms ⁻¹	-	19.37
Gas Vol. Sampled	Dry Gas Basis, Ambient T and P	-	0.99
Gas Vol. Sampled	Wet Gas Basis, Standard T and P	-	0.93
Particulate Concentration	Wet Gas Basis, Standard T and P, mg Nm ⁻³	<0.2	9.4
Expanded Uncertainty	+/-mg Nm ⁻³ , 95% Conf. k=2	-	0.6
Emission Limit Value (ELV)	Wet Gas Basis, Standard T and P, mg Nm ⁻³	50	50
Percentage of Emission Limit Value (ELV) for Test	Wet Gas Basis, Standard T and P, %	-	19
Mass Emission	Wet Gas Basis, Standard T and P, g s ⁻¹	-	0.2

SB3 Particulates Results Summary

Field	Units	Blank	TEST 1
Date	dd/mm/yyyy	19/02/2013	19/02/2013
Test No.		Blank	PM1
Filter No.		12TF218	12TF219
Stack Description		SB3	SB3
Start Time	hh:mm	-	15:45
End Time	hh:mm	-	16:15
Total Time	min	-	30
Stack Temp.	C	-	25
Gas Meter Temp	C	-	22
Gas Meter Pressure	kPa	-	101.8
Filter	mg	<0.2	0.5
Washings	mg	0.3	0.1
TOTAL Mass Collected	mg	<0.5	0.5
Test H ₂ O	% Vol	-	0.5
Stack Pressure	kPa	-	101.8
Nozzle Diameter	mm	-	5.02
Duct Area	m ²	-	0.59
Isokinicity	%	-	104
Stack Velocity	Stack T & P, uncorrected, ms ⁻¹	-	12.35
Gas Vol. Sampled	Dry Gas Basis, Ambient T and P	-	0.44
Gas Vol. Sampled	Wet Gas Basis, Standard T and P	-	0.42
Particulate Concentration	Wet Gas Basis, Standard T and P, mg Nm ⁻³	<0.5	1.2
Expanded Uncertainty	+/-mg Nm ⁻³ , 95% Conf. k=2	-	1.1
Emission Limit Value (ELV)	Wet Gas Basis, Standard T and P, mg Nm ⁻³	50	50
Percentage of Emission Limit Value (ELV) for Test	Wet Gas Basis, Standard T and P, %	-	2
Mass Emission	Wet Gas Basis, Standard T and P, g s ⁻¹	-	0.02

2.2.6 - Sample Sheets

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Test no	PM1		Site:	Paxford Composites		Stack Description:	SB1		
Date	20-2-13	dd/mm/yy	Filter No:	12TF223		Absorber No(s):	T01, A-D		
nozzle diameter	5.0	mm	Blank I.D.:	12TF220					
Stack Pres (with +/- above barometric if unknown enter zero)	0	mmH ₂ O	SITE TEAM:		SDR & MRE				
			COMMENTS:		Particulates Test 1				
end volume reading	26.575	m ³				Control Box I.D. No:	AS0003		
start volume reading	26.175	m ³	end time	11:06	hh:mm	Stack Thermocouple I.D. No.	AS0257A		
volume sampled	0.40	m ³	start time	10:36	hh:mm	Probe I.D. No.	AS0257		
Conditions	Value	Units	total time	00:30	hh:mm	Barometer I.D. No.	AS0300		
			stop time	00:00	hh:mm	Pitot I.D. No.	AS0015		
Stack pressure	768.63	mmHg	Diagram of Sample Location: 						
Gas Meter Calibration Factor Y	1.0214								
Ref oxygen Value	21	%							
Moisture content	0.5	%							
CO	0	ppm							
CO ₂	0	%							
N ₂	79.05	%							
O ₂	20.95	%							
dry molecular wt	28.84								
stack molecular wt	28.78								
Orifice ΔH@ Factor	41.70	mmH ₂ O							
area of stack	0.47	m ²	LEAK CHECK						
Pbar	1024.5	mbar	Pre Vac (in Hg):			15	Post Vac (in Hg):		0.5
Pbar	768.6	mmHg	Leak rate (m ³ /l) or (%):			<2%	Leak rate (m ³ /l) or (%):		<2%
pitot tube coeft	0.83								
Reference Temp	273	K							
Reference Pressure	760	mmHg							

NATIONAL PHYSICAL LABORATORY
Continuation Sheet


	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
1:	10:36	26.1750	A3	5	17.80	24.9	11	158	N/A	17	N/A	15	15	0.5
2:	10:41	26.2610	A3	5	17.80	24.9	10	159	N/A	16	N/A	15	15	0.5
3:	10:46	26.3440	A2	5	14.60	20.4	10	160	N/A	18	N/A	16	16	0.5
4:	10:51	26.4140	A2	5	14.20	19.9	18	160	N/A	19	N/A	17	17	0.5
5:	10:56	26.4830	A1	5	6.20	8.7	17	160	N/A	19	N/A	17	17	0.5
6:	11:01	26.5290	A1	5	6.40	9.0	18	159	N/A	20	N/A	17	17	0.5
7:	11:06	26.5750	STOP											
8:														
9:														
10:														

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
11:														
12:														
13:														
14:														
15:														
Summary values		26.58		30		17.97	14.0	159.3	#DIV/0!	18.2	n/a		16.2	0.5

Duct / Stack Flow Characteristics:	SB1		Units
Test No	PM1		
Stack Velocity at stack gas T & P and a wet gas basis		11.60	ms ⁻¹
Stack flow @ STP, O ₂ (ref) and on a dry gas basis		5.22	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a wet gas basis		5.45	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a dry gas basis		5.42	m ³ s ⁻¹
Stack flow @ STP and on a wet gas basis		5.24	m ³ s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a wet gas basis		5.72	m ³ s ⁻¹
Gas vol. samp. @ STP and on a dry gas basis		0.39	m ³
Gas vol. samp. @ STP, O ₂ (ref), and on a dry gas basis		0.39	m ³
Gas vol. samp. @ STP and on a wet gas basis		0.39	m ³
Gas vol. samp. @ STP, O ₂ (ref) and on a wet gas basis		0.39	m ³
Percentage Isokinicity		99	%

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Test no	ISOCYANATES 1		Site:	Paxford Composites		Stack Description:	SB1		
Date	20-2-13	dd/mm/yy	Filter No:	-		Absorber No(s):	T01, A-D		
nozzle diameter	5.02	mm	Blank I.D.:	-					
Stack Pres (with +/- above barometric if unknown enter zero)	0	mmH ₂ O	SITE TEAM:		SDR & MRE				
			COMMENTS:		Isocyanates Test 1				
end volume reading	26.994	m ³				Control Box I.D. No:	AS0003		
start volume reading	26.582	m ³	end time	11:42	hh:mm	Stack Thermocouple I.D. No.	AS0257A		
volume sampled	0.41	m ³	start time	11:12	hh:mm	Probe I.D. No.	AS0257		
Conditions	Value	Units	total time	00:30	hh:mm	Barometer I.D. No.	AS0300		
			stop time	00:00	hh:mm	Pitot I.D. No.	AS0015		
Stack pressure	768.63	mmHg	Diagram of Sample Location: 						
Gas Meter Calibration Factor Y	0.9808								
Ref oxygen Value	21	%							
Moisture content	0.7	%							
CO	0	ppm							
CO ₂	0	%							
N ₂	79.05	%							
O ₂	20.95	%							
dry molecular wt	28.84								
stack molecular wt	28.77								
Orifice ΔH@ Factor	47.10	mmH ₂ O							
area of stack	0.47	m ²	LEAK CHECK						
Pbar	1024.5	mbar	Pre Vac (in Hg):			15	Post Vac (in Hg):		1
Pbar	768.6	mmHg	Leak rate (m ³ /l) or (%):			<2%	Leak rate (m ³ /l) or (%):		<2%
pitot tube coeft	0.83								
Reference Temp	273	K							
Reference Pressure	760	mmHg							

NATIONAL PHYSICAL LABORATORY
Continuation Sheet


	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
1:	11:12	26.582	A3	5	18.20	25.5	17	160	N/A	15	N/A	18	18	0.5
2:	11:17	26.664	A3	5	17.60	24.6	15	160	N/A	17	N/A	19	19	0.5
3:	11:22	26.742	A2	5	15.00	21.0	12	161	N/A	20	N/A	19	19	0.5
4:	11:27	26.811	A2	5	14.80	20.7	10	161	N/A	21	N/A	20	20	0.5
5:	11:32	26.881	A1	5	6.60	9.2	10	160	N/A	22	N/A	21	21	0.5
6:	11:37	26.937	A1	5	6.40	9.0	10	160	N/A	22	N/A	21	21	0.5
7:	11:42	26.994	STOP											
8:														
9:														
10:														

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
11:														
12:														
13:														
14:														
15:														
Summary values		26.99		30		18.34	12.3	160.3	#DIV/0!	19.5	n/a		19.7	0.5

Duct / Stack Flow Characteristics:	SB1		Units
Test No	ISOCYANATES 1		
Stack Velocity at stack gas T & P and a wet gas basis		11.69	ms ⁻¹
Stack flow @ STP, O ₂ (ref) and on a dry gas basis		5.28	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a wet gas basis		5.50	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a dry gas basis		5.46	m ³ s ⁻¹
Stack flow @ STP and on a wet gas basis		5.32	m ³ s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a wet gas basis		5.79	m ³ s ⁻¹
Gas vol. samp. @ STP and on a dry gas basis		0.38	m ³
Gas vol. samp. @ STP, O ₂ (ref), and on a dry gas basis		0.38	m ³
Gas vol. samp. @ STP and on a wet gas basis		0.38	m ³
Gas vol. samp. @ STP, O ₂ (ref) and on a wet gas basis		0.38	m ³
Percentage Isokinicity		95	%

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Test no	PM1		Site:	Paxford Composites		Stack Description:	SB2		
Date	19-2-13	dd/mm/yy	Filter No:	12TF217		Absorber No(s):	T01, A-D		
nozzle diameter	6.02	mm	Blank I.D.:	12TF216					
Stack Pres (with +/- above barometric if unknown enter zero)	0	mmH ₂ O	SITE TEAM:		SDR & MRE				
			COMMENTS:		Particulates Test 1				
end volume reading	24.667	m ³				Control Box I.D. No:	AS0240		
start volume reading	23.678	m ³	end time	14:30	hh:mm	Stack Thermocouple I.D. No.	AS0257A		
volume sampled	0.99	m ³	start time	14:00	hh:mm	Probe I.D. No.	AS0257		
Conditions	Value	Units	total time	00:30	hh:mm	Barometer I.D. No.	AS0300		
			stop time	00:00	hh:mm	Pitot I.D. No.	AS0466		
Stack pressure	768.63	mmHg	Diagram of Sample Location: 						
Gas Meter Calibration Factor Y	0.9808								
Ref oxygen Value	21	%							
Moisture content	0.9	%							
CO	0	ppm							
CO ₂	0	%							
N ₂	79.05	%							
O ₂	20.95	%							
dry molecular wt	28.84								
stack molecular wt	28.74								
Orifice ΔH@ Factor	47.10	mmH ₂ O							
area of stack	0.64	m ²	LEAK CHECK						
Pbar	1024.5	mbar	Pre Vac (in Hg):			15	Post Vac (in Hg):		1
Pbar	768.6	mmHg	Leak rate (m ³ /l) or (%):			<2%	Leak rate (m ³ /l) or (%):		<2%
pitot tube coeft	0.83								
Reference Temp	273	K							
Reference Pressure	760	mmHg							

NATIONAL PHYSICAL LABORATORY
Continuation Sheet


	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp Ts °C	Probe Temp Tp °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in Tm(in) °C	Meter out Tm(out) °C	Vacuum in Hg
1:	14:00	23.6780	A1	5	52.00	145.6	18	160	N/A	14	N/A	14	14	0.5
2:	14:05	23.9000	A1	5	48.00	134.4	20	160	N/A	15	N/A	17	17	0.5
3:	14:10	24.1080	A2	5	38.00	106.4	20	160	N/A	16	N/A	20	20	0.5
4:	14:15	24.2890	A2	5	28.00	78.4	21	160	N/A	16	N/A	22	22	0.5
5:	14:20	24.4350	A3	5	24.00	67.2	22	160	N/A	17	N/A	23	23	0.5
6:	14:25	24.5690	A3	5	18.00	50.4	22	160	N/A	18	N/A	24	24	0.5
7:	14:30	24.6670	END											
8:														
9:														
10:														

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
11:														
12:														
13:														
14:														
15:														
Summary values		24.67		30		97.07	20.5	160.0	#DIV/0!	16.0	n/a		20.0	0.5

Duct / Stack Flow Characteristics:	SB2		Units
Test No	PM1		
Stack Velocity at stack gas T & P and a wet gas basis		19.37	ms ⁻¹
Stack flow @ STP, O ₂ (ref) and on a dry gas basis		11.56	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a wet gas basis		12.40	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a dry gas basis		12.29	m ³ s ⁻¹
Stack flow @ STP and on a wet gas basis		11.66	m ³ s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a wet gas basis		12.84	m ³ s ⁻¹
Gas vol. samp. @ STP and on a dry gas basis		0.92	m ³
Gas vol. samp. @ STP, O ₂ (ref), and on a dry gas basis		0.92	m ³
Gas vol. samp. @ STP and on a wet gas basis		0.93	m ³
Gas vol. samp. @ STP, O ₂ (ref) and on a wet gas basis		0.93	m ³
Percentage Isokinicity		100	%

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Test no	ISOCYANATES 1		Site:	Paxford Composites		Stack Description:	SB2		
	Date	19-2-12	dd/mm/yy	Filter No:	-	Absorber No(s):	T01, A-D		
	nozzle diameter	5.02	mm	Blank I.D.:	-				
	Stack Pres (with +/- above barometric if unknown enter zero)	0	mmH ₂ O	SITE TEAM:		SDR & MRE			
				COMMENTS:		Isocyanates Test 1			
end volume reading	25.239	m ³				Control Box I.D. No:	AS0003		
start volume reading	24.692	m ³	end time	15:20	hh:mm	Stack Thermocouple I.D. No.	AS0257A		
volume sampled	0.55	m ³	start time	14:50	hh:mm	Probe I.D. No.	AS0257		
Conditions	Value	Units	total time	00:30	hh:mm	Barometer I.D. No.	AS0300		
			stop time	00:00	hh:mm	Pitot I.D. No.	AS0466		
Stack pressure	758.50	mmHg	<div style="display: flex; align-items: center;"> <div style="flex: 1;"> <p>Diagram of Sample Location:</p> </div>  </div>						
Gas Meter Calibration Factor Y	0.9808								
Ref oxygen Value	21	%							
Moisture content	0.8	%							
CO	0	ppm							
CO ₂	0	%							
N ₂	79.05	%							
O ₂	20.95	%							
dry molecular wt	28.84								
stack molecular wt	28.76								
Orifice ΔH@ Factor	47.10	mmH ₂ O							
area of stack	0.64	m ²	LEAK CHECK						
Pbar	1011	mbar	Pre Vac (in Hg):			15	Post Vac (in Hg):		0.5
Pbar	758.5	mmHg	Leak rate (m ³ /l) or (%):			<2%	Leak rate (m ³ /l) or (%):		<2%
pitot tube coeft	0.83								
Reference Temp	273	K							
Reference Pressure	760	mmHg							

NATIONAL PHYSICAL LABORATORY
Continuation Sheet


	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
1:	14:50	24.6920	A1	5	26.00	36.4	19	160	N/A	17	N/A	19	19	0.5
2:	14:55	24.7870	A2	5	24.00	33.6	20	160	N/A	14	N/A	23	23	0.5
3:	15:00	24.8920	A3	5	10.00	14.0	25	160	N/A	16	N/A	24	24	0.5
4:	15:05	24.9480	A1	5	32.00	44.8	24	161	N/A	17	N/A	24	24	0.5
5:	15:10	25.0580	A2	5	26.00	36.4	25	160	N/A	17	N/A	24	24	0.5
6:	15:15	25.1620	A3	5	11.00	15.4	25	161	N/A	17	N/A	24	24	0.5
7:	15:20	25.2390	END											
8:														
9:														
10:														

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
11:														
12:														
13:														
14:														
15:														
Summary values		25.24		30		30.10	23.0	160.3	#DIV/0!	16.3	n/a		23.0	0.5

Duct / Stack Flow Characteristics:	SB2		Units
Test No	ISOCYANATES 1		
Stack Velocity at stack gas T & P and a wet gas basis		15.35	ms ⁻¹
Stack flow @ STP, O ₂ (ref) and on a dry gas basis		8.97	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a wet gas basis		9.82	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a dry gas basis		9.75	m ³ s ⁻¹
Stack flow @ STP and on a wet gas basis		9.04	m ³ s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a wet gas basis		9.99	m ³ s ⁻¹
Gas vol. samp. @ STP and on a dry gas basis		0.50	m ³
Gas vol. samp. @ STP, O ₂ (ref), and on a dry gas basis		0.50	m ³
Gas vol. samp. @ STP and on a wet gas basis		0.50	m ³
Gas vol. samp. @ STP, O ₂ (ref) and on a wet gas basis		0.50	m ³
Percentage Isokinicity		99	%

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Test no	PM1		Site:	Paxford Composites		Stack Description:	SB3		
	Date	19-2-13	dd/mm/yy	Filter No:	12TF219	Absorber No(s):	T01, A-D		
	nozzle diameter	5.02	mm	Blank I.D.:	12TF218				
	Stack Pres (with +/- above barometric if unknown enter zero)	0	mmH ₂ O	SITE TEAM:		SDR & MRE			
				COMMENTS:		Particulates Test 1			
end volume reading	25.695	m ³				Control Box I.D. No:	AS0003		
start volume reading	25.254	m ³	end time	16:15	hh:mm	Stack Thermocouple I.D. No.	AS0257A		
volume sampled	0.44	m ³	start time	15:45	hh:mm	Probe I.D. No.	AS0257		
Conditions	Value	Units	total time	00:30	hh:mm	Barometer I.D. No.	AS0300		
			stop time	00:00	hh:mm	Pitot I.D. No.	AS0466		
Stack pressure	763.75	mmHg	<p>Diagram of Sample Location:</p> 						
Gas Meter Calibration Factor Y	1.0214								
Ref oxygen Value	21	%							
Moisture content	0.5	%							
CO	0	ppm							
CO ₂	0	%							
N ₂	79.05	%							
O ₂	20.95	%							
dry molecular wt	28.84								
stack molecular wt	28.79								
Orifice ΔH@ Factor	41.70	mmH ₂ O							
area of stack	0.59	m ²	LEAK CHECK						
Pbar	1018	mbar	Pre Vac (in Hg):			15	Post Vac (in Hg):		0.5
Pbar	763.8	mmHg	Leak rate (m ³ /l) or (%):			<2%	Leak rate (m ³ /l) or (%):		<2%
pitot tube coeft	0.83								
Reference Temp	273	K							
Reference Pressure	760	mmHg							

NATIONAL PHYSICAL LABORATORY
Continuation Sheet


	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
1:	15:45	25.2540	A3	5	22.00	30.8	26	158	N/A	13	N/A	22	22	0.5
2:	15:50	25.3610	A3	5	20.00	28.0	24	159	N/A	13	N/A	22	22	0.5
3:	15:55	25.4670	A2	5	16.00	22.4	23	159	N/A	14	N/A	22	22	0.5
4:	16:00	25.5460	A2	5	15.00	21.0	22	160	N/A	15	N/A	22	22	0.5
5:	16:05	25.6110	A1	5	6.00	8.4	30	160	N/A	15	N/A	22	22	0.5
6:	16:10	25.6540	A1	5	6.00	8.4	24	159	N/A	15	N/A	21	21	0.5
7:	16:15	25.6950	STOP											
8:														
9:														
10:														

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
11:														
12:														
13:														
14:														
15:														
Summary values		25.70		30		19.83	24.8	159.2	#DIV/0!	14.2	n/a		21.8	0.5

Duct / Stack Flow Characteristics:	SB3		Units
Test No	PM1		
Stack Velocity at stack gas T & P and a wet gas basis		12.35	m s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a dry gas basis		6.68	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a wet gas basis		7.29	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a dry gas basis		7.25	m ³ s ⁻¹
Stack flow @ STP and on a wet gas basis		6.71	m ³ s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a wet gas basis		7.43	m ³ s ⁻¹
Gas vol. samp. @ STP and on a dry gas basis		0.42	m ³
Gas vol. samp. @ STP, O ₂ (ref), and on a dry gas basis		0.42	m ³
Gas vol. samp. @ STP and on a wet gas basis		0.42	m ³
Gas vol. samp. @ STP, O ₂ (ref) and on a wet gas basis		0.42	m ³
Percentage Isokinicity		104	%

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Test no	ISOCYANATES 1		Site:	Paxford Composites		Stack Description:	SB3	
Date	19-2-13	dd/mm/yy	Filter No:	-		Absorber No(s):	T01, A-D	
nozzle diameter	5.02	mm	Blank I.D.:	-				
Stack Pres (with +/- above barometric if unknown enter zero)	0	mmH ₂ O	SITE TEAM:		SDR & MRE			
			COMMENTS:		Isocyanates Test 1			
end volume reading	26.104	m ³				Control Box I.D. No:	AS0003	
start volume reading	25.700	m ³	end time	16:53	hh:mm	Stack Thermocouple I.D. No.	AS0257A	
volume sampled	0.40	m ³	start time	16:23	hh:mm	Probe I.D. No.	AS0257	
Conditions	Value	Units	total time	00:30	hh:mm	Barometer I.D. No.	AS0300	
			stop time	00:00	hh:mm	Pitot I.D. No.	AS0466	
Stack pressure	768.63	mmHg	<p>Diagram of Sample Location:</p> 					
Gas Meter Calibration Factor Y	1.0214							
Ref oxygen Value	21	%						
Moisture content	0.9	%						
CO	0	ppm						
CO ₂	0	%						
N ₂	79.05	%						
O ₂	20.95	%						
dry molecular wt	28.84							
stack molecular wt	28.74							
Orifice ΔH@ Factor	47.10	mmH ₂ O						
area of stack	0.59	m ²						
Pbar	1024.5	mbar	Pre Vac (in Hg):			15	Post Vac (in Hg):	
Pbar	768.6	mmHg	Leak rate (m ³ /l) or (%):			<2%	Leak rate (m ³ /l) or (%):	
pitot tube coeft	0.83							
Reference Temp	273	K						
Reference Pressure	760	mmHg						

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
1:	16:23	25.7000	A1	5	21.00	29.4	23	159	59	13	N/A	20	20	0.5
2:	16:28	25.7820	A2	5	20.00	28.0	29	161	N/A	13	N/A	21	21	0.5
3:	16:33	25.8630	A3	5	15.00	21.0	24	161	N/A	13	N/A	21	21	0.5
4:	16:38	25.9440	B1	5	15.00	21.0	29	160	N/A	15	N/A	21	21	0.5
5:	16:43	26.0160	B2	5	6.00	8.4	24	159	N/A	16	N/A	21	21	0.5
6:	16:48	26.0600	B3	5	6.20	8.7	29	160	N/A	16	N/A	20	20	0.5
7:	16:53	26.1040	END											
8:														
9:														
10:														

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

	Start Time at this Position or Setting hh: mm	volume reading at start m ³	Probe position	Time at each position / min	Δp mm H ₂ O	Δh mm H ₂ O	Stack Temp T _s °C	Probe Temp T _p °C	Oven Temp °C	Impinger Temp °C	Resin/L ine °C	Meter in T _m (in) °C	Meter out T _m (out) °C	Vacuum in Hg
11:														
12:														
13:														
14:														
15:														
Summary values		26.10		30		19.41	26.3	160.0	59.0	14.3	n/a		20.7	0.5

Duct / Stack Flow Characteristics:	SB3		Units
Test No	ISOCYANATES 1		
Stack Velocity at stack gas T & P and a wet gas basis		12.24	ms ⁻¹
Stack flow @ STP, O ₂ (ref) and on a dry gas basis		6.60	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a wet gas basis		7.22	m ³ s ⁻¹
Stack flow @ stack gas T & P and on a dry gas basis		7.16	m ³ s ⁻¹
Stack flow @ STP and on a wet gas basis		6.66	m ³ s ⁻¹
Stack flow @ STP, O ₂ (ref) and on a wet gas basis		7.39	m ³ s ⁻¹
Gas vol. samp. @ STP and on a dry gas basis		0.39	m ³
Gas vol. samp. @ STP, O ₂ (ref), and on a dry gas basis		0.39	m ³
Gas vol. samp. @ STP and on a wet gas basis		0.39	m ³
Gas vol. samp. @ STP, O ₂ (ref) and on a wet gas basis		0.39	m ³
Percentage Isokinicity		97	%

2.2.7 - Moisture Calculations

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

National Physical Laboratory
Absorber Test Form

Test No	PM1
Date	20-2-13
pbar (mbar)	1025
pbar (mmHg):	769
nozzle diameter (mm)	5.02
Temp of Meter (in)/(out) deg. C	16
ΔH_{ave} (mmH ₂ O)	18.0
Filter No (If app)	12TF223

Site	Paxford Composites
Stack	SB1
Site Team:	SDR & MRE
Data Entered By:	Simon Render

End Volume Reading	26.58	m ³
Start Volume reading	26.18	m ³
Volume Sampled	0.40	m ³

end time	11:06	hr:min
start time	10:36	hr:min
total time	00:30	hr:min

IMPINGER	1	2	3	4	5	6	7	Initials of Analyst
Absorber Solution (Type):	DI Water	DI Water	Empty	Silica Gel				MRE
Sample No:	T1/A	T1/B	T1/C	T1/D				MRE
Analysis Required:	H2O	H2O	H2O	H2O				MRE
Weight of jars plus absorber plus washings (g)								
Weight of Jars plus absorber after sampling (g)	814.6	825.4	593.3	839.8				MRE
Weight of Jars plus absorber (g)	829.6	815.5	593.6	832.9				MRE
Weight of Jars (g)	609.9	604.3	593.6	593.0				MRE
Weight Gain (g)	-15.0	9.9	-0.3	6.9				

Total Weight Gain (1+2+3+4) (g)	1.55
---------------------------------	------

Gas Volume of water at 0°C (l)	1.93
Gas Meter volume at 0°C (l)	382.58

Moisture content of Gases (%)	0.5
-------------------------------	-----

NOTES:

at 0°C

Volume (l) of water in gas phase is $V_{wc} = 1.2444 \times \text{wt of water collected (g)}$

Volume of gas sampled by meter (l) dry $V_{mc} = 359.2 \times \text{gas meter reading (m}^3\text{)} \times (\text{Pbar} + \Delta H/13.6) / (\text{meter temp} + 273)$

moisture content (fraction) = $V_{wc} / (V_{wc} + V_{mc})$

an approximation is: 1 m³ of gas weighs approx 1.2 kg

moisture content approx =
$$\frac{\text{wt of water collected (g)} \times 100}{\text{wt of water collected (g)} + (\text{m}^3 \text{ of gas on meter} \times 1200)}$$

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

National Physical Laboratory
Absorber Test Form

Test No	ISOCYANATE S 1
Date	20-2-13
pbar (mbar)	1025
pbar (mmHg):	769
nozzle diameter (mm)	5.02
Temp of Meter (in)/(out) deg. C	20
ΔH_{ave} (mmH ₂ O)	18.3
Filter No (if app)	-

Site	Paxford Composites
Stack	SB1
Site Team:	SDR & MRE
Data Entered By:	Simon Render

End Volume Reading	26.99	m ³
Start Volume reading	26.58	m ³
Volume Sampled	0.41	m ³

end time	11:42	hr:min
start time	11:12	hr:min
total time	00:30	hr:min

IMPINGER	1	2	3	4	5	6	7	Initials of Analyst
Absorber Solution (Type):	DI Water	DI Water	Empty	Silica Gel				MRE
Sample No:	T1/A	T1/B	T1/C	T1/D				MRE
Analysis Required:	H2O	H2O	H2O	H2O				MRE
Weight of jars plus absorber plus washings (g)								
Weight of Jars plus absorber after sampling (g)	840.3	792.4	479.4	834.6				MRE
Weight of Jars plus absorber (g)	843.5	793.1	479.4	828.6				MRE
Weight of Jars (g)	645.3	585.6	479.4	585.5				MRE
Weight Gain (g)	-3.2	-0.6	0.0	6.0				

Total Weight Gain (1+2+3+4) (g)	2.09
---------------------------------	------

Gas Volume of water at 0°C (l)	2.60
Gas Meter volume at 0°C (l)	389.36

Moisture content of Gases (%)	0.7
-------------------------------	-----

NOTES:

at 0°C

Volume (l) of water in gas phase is $V_{wc} = 1.2444 \times \text{wt of water collected (g)}$

Volume of gas sampled by meter (l) dry $V_{mc} = 359.2 \times \text{gas meter reading (m}^3\text{)} \times (\text{Pbar} + \Delta H/13.6) / (\text{meter temp} + 273)$

moisture content (fraction) = $V_{wc}/(V_{wc} + V_{mc})$

an approximation is: 1 m³ of gas weighs approx 1.2 kg

moisture content approx =
$$\frac{\text{wt of water collected (g)} \times 100}{\text{wt of water collected (g)} + (\text{m}^3 \text{ of gas on meter} \times 1200)}$$

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

National Physical Laboratory
Absorber Test Form

Test No	PM1
Date	19-2-13
pbar (mbar)	1025
pbar (mmHg):	769
nozzle diameter (mm)	6.02
Temp of Meter (in)/(out) deg. C	20
ΔH_{ave} (mmH ₂ O)	97.1
Filter No (if app)	12TF217

Site	Paxford Composites
Stack	SB2
Site Team:	SDR & MRE
Data Entered By:	Simon Render

End Volume Reading	24.67	m ³
Start Volume reading	23.68	m ³
Volume Sampled	0.99	m ³

end time	14:30	hr:min
start time	14:00	hr:min
total time	00:30	hr:min

IMPINGER	1	2	3	4	5	6	7	Initials of Analyst
Absorber Solution (Type):	DI Water	DI Water	Empty	Silica Gel				MRE
Sample No:	T1/A	T1/B	T1/C	T1/D				MRE
Analysis Required:	H2O	H2O	H2O	H2O				MRE
Weight of jars plus absorber plus washings (g)								
Weight of Jars plus absorber after sampling (g)	759.7	811.4	598.8	851.4				MRE
Weight of Jars plus absorber (g)	762.3	812.1	593.6	846.6				MRE
Weight of Jars (g)	609.9	604.3	593.6	593.0				MRE
Weight Gain (g)	-2.6	-0.7	5.2	4.8				

Total Weight Gain (1+2+3+4) (g)	6.7
---------------------------------	-----

Gas Volume of water at 0°C (l)	8.34
Gas Meter volume at 0°C (l)	940.61

Moisture content of Gases (%)	0.9
-------------------------------	-----

NOTES:

at 0°C

Volume (l) of water in gas phase is $V_{wc} = 1.2444 \times \text{wt of water collected (g)}$

Volume of gas sampled by meter (l) dry $V_{mc} = 359.2 \times \text{gas meter reading (m}^3\text{)} \times (\text{Pbar} + \Delta H/13.6) / (\text{meter temp} + 273)$

moisture content (fraction) = $V_{wc} / (V_{wc} + V_{mc})$

an approximation is: 1 m³ of gas weighs approx 1.2 kg

moisture content approx =
$$\frac{\text{wt of water collected (g)} \times 100}{\text{wt of water collected (g)} + (\text{m}^3 \text{ of gas on meter} \times 1200)}$$

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

National Physical Laboratory
Absorber Test Form

Test No	ISOCYANATE S 1
Date	19-2-12
pbar (mbar)	1011
pbar (mmHg):	758
nozzle diameter (mm)	5.02
Temp of Meter (in)/(out) deg. C	23
ΔH_{avo} (mmH ₂ O)	30.1
Filter No (if app)	-

Site	Paxford Composites
Stack	SB2
Site Team:	SDR & MRE
Data Entered By:	Simon Render

End Volume Reading	25.24	m ³
Start Volume reading	24.69	m ³
Volume Sampled	0.55	m ³

end time	15:20	hr:min
start time	14:50	hr:min
total time	00:30	hr:min

IMPINGER	1	2	3	4	5	6	7	Initials of Analyst
Absorber Solution (Type):	DI Water	DI Water	Empty	Silica Gel				MRE
Sample No:	T1/A	T1/B	T1/C	T1/D				MRE
Analysis Required:	H2O	H2O	H2O	H2O				MRE
Weight of jars plus absorber plus washings (g)								
Weight of Jars plus absorber after sampling (g)	833.8	790.6	479.4	846.0				MRE
Weight of Jars plus absorber (g)	840.3	792.4	479.4	834.6				MRE
Weight of Jars (g)	645.3	585.6	479.4	585.5				MRE
Weight Gain (g)	-6.5	-1.8	0	11.4				

Total Weight Gain (1+2+3+4) (g)	3.1
---------------------------------	-----

Gas Volume of water at 0°C (l)	3.86
Gas Meter volume at 0°C (l)	504.97

Moisture content of Gases (%)	0.8
-------------------------------	-----

NOTES:

at 0°C

Volume (l) of water in gas phase is $V_{wc} = 1.2444 \times \text{wt of water collected (g)}$

Volume of gas sampled by meter (l) dry $V_{mc} = 359.2 \times \text{gas meter reading (m}^3\text{)} \times (\text{Pbar} + \Delta H/13.6) / (\text{meter temp} + 273)$

moisture content (fraction) = $V_{wc} / (V_{wc} + V_{mc})$

an approximation is: 1 m³ of gas weighs approx 1.2 kg

moisture content approx =
$$\frac{\text{wt of water collected (g)} \times 100}{\text{wt of water collected (g)} + (\text{m}^3 \text{ of gas on meter} \times 1200)}$$

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

National Physical Laboratory
Absorber Test Form

Test No	PM1
Date	19-2-13
pbar (mbar)	1018
pbar (mmHg):	764
nozzle diameter (mm)	5.02
Temp of Meter (in)/(out) deg. C	22
ΔH_{ave} (mmH ₂ O)	19.8
Filter No (if app)	12TF219

Site	Paxford Composites
Stack	SB3
Site Team:	SDR & MRE
Data Entered By:	Simon Render

End Volume Reading	25.70	m ³
Start Volume reading	25.25	m ³
Volume Sampled	0.44	m ³

end time	16:15	hr:min
start time	15:45	hr:min
total time	00:30	hr:min

IMPINGER	1	2	3	4	5	6	7	Initials of Analyst
Absorber Solution (Type):	DI Water	DI Water	Empty	Silica Gel				MRE
Sample No:	T1/A	T1/B	T1/C	T1/D				MRE
Analysis Required:	H2O	H2O	H2O	H2O				MRE
Weight of jars plus absorber plus washings (g)								
Weight of Jars plus absorber after sampling (g)	757.3	810.9	598.8	855.8				MRE
Weight of Jars plus absorber (g)	759.7	811.4	598.8	851.4				MRE
Weight of Jars (g)	609.9	604.3	593.6	593.0				MRE
Weight Gain (g)	-2.4	-0.5	0	4.4				

Total Weight Gain (1+2+3+4) (g)	1.5
---------------------------------	-----

Gas Volume of water at 0°C (l)	1.87
Gas Meter volume at 0°C (l)	411.14

Moisture content of Gases (%)	0.5
-------------------------------	-----

NOTES:

at 0°C

Volume (l) of water in gas phase is $V_{wc} = 1.2444 \times \text{wt of water collected (g)}$

Volume of gas sampled by meter (l) dry $V_{mc} = 359.2 \times \text{gas meter reading (m}^3\text{)} \times (\text{Pbar} + \Delta H/13.6) / (\text{meter temp} + 273)$

moisture content (fraction) = $V_{wc}/(V_{wc}+V_{mc})$

an approximation is: 1 m³ of gas weighs approx 1.2 kg

moisture content approx =
$$\frac{\text{wt of water collected (g)} \times 100}{\text{wt of water collected (g)} + (\text{m}^3 \text{ of gas on meter} \times 1200)}$$

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

National Physical Laboratory
Absorber Test Form

Test No	ISOCYANATE S 1
Date	19-2-13
pbar (mbar)	1025
pbar (mmHg):	769
nozzle diameter (mm)	5.02
Temp of Meter (in)/(out) deg. C	21
ΔH_{ave} (mmH ₂ O)	19.4
Filter No (if app)	-

Site	Paxford Composites
Stack	SB3
Site Team:	SDR & MRE
Data Entered By:	Simon Render

End Volume Reading	26.10	m ³
Start Volume reading	25.70	m ³
Volume Sampled	0.40	m ³

end time	16:53	hr:min
start time	16:23	hr:min
total time	00:30	hr:min

IMPINGER	1	2	3	4	5	6	7	Initials of Analyst
Absorber Solution (Type):	DI Water	DI Water	Empty	Silica Gel				MRE
Sample No:	T1/A	T1/B	T1/C	T1/D				MRE
Analysis Required:	H2O	H2O	H2O	H2O				MRE
Weight of jars plus absorber plus washings (g)								
Weight of Jars plus absorber after sampling (g)	829.8	790.2	479.4	853.1				MRE
Weight of Jars plus absorber (g)	833.8	790.6	479.4	846.0				MRE
Weight of Jars (g)	645.3	585.6	479.4	585.5				MRE
Weight Gain (g)	-4.0	-0.4	0.0	7.1				

Total Weight Gain (1+2+3+4) (g)	2.7
---------------------------------	-----

Gas Volume of water at 0°C (l)	3.36
Gas Meter volume at 0°C (l)	380.54

Moisture content of Gases (%)	0.9
-------------------------------	-----

NOTES:

at 0°C

Volume (l) of water in gas phase is $V_{wc} = 1.2444 \times \text{wt of water collected (g)}$

Volume of gas sampled by meter (l) dry $V_{mc} = 359.2 \times \text{gas meter reading (m}^3\text{)} \times (\text{Pbar} + \Delta H/13.6) / (\text{meter temp} + 273)$

moisture content (fraction) = $V_{wc} / (V_{wc} + V_{mc})$

an approximation is: 1 m³ of gas weighs approx 1.2 kg

moisture content approx =
$$\frac{\text{wt of water collected (g)} \times 100}{\text{wt of water collected (g)} + (\text{m}^3 \text{ of gas on meter} \times 1200)}$$

2.2.8 - Uncertainty Calculations

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Uncertainty calculation for EN 13284 Determination of low range mass concentration of dust, Manual Gravimetric Method

Spray Booth One Test One

Measurement Equation

$$c = \frac{m}{V} f_c$$

Limit value (ELV)	50	mg.m ⁻³	Reference oxygen	20.9	% by volume
Measured concentration	0.2	mg.m ⁻³ (at reference conditions)			

Measured Quantities	Symbol	Value	Standard uncertainty	Units	Uncertainty as percentage	Uncertainty at lv	Requirement of std
Sampled Volume	V _m	0.40	uV _m	0.001 m ³	0.25		<=2%
Sampled gas Temperature	T _m	289	uT _m	2 K	0.69		<=1%
Sampled gas Pressure	p _m	102.45	up _m	1 kPa	0.98		<=1%
Sampled gas Humidity	H _m	0	uH _m	1 % by volume	1.00		<=1%
Mass particulate	m	0.4	um	0.23 mg	57.30	0.23	<5% of limit value
Note - Sampled gas humidity, temperature and pressure are values at the gas meter							
Leak	L	2		%	2.00		<=2%
Uncollected Mass (Instack filter - no rinse)	UCM	0		mg	0		<=10%

Intermediate calculations

Factor for std conds	fs	0.95				
uncertainty components	symbol	sensitivity coeff	u (in units of fs)			
	p _m	0.009	0.009			
	H _m	0.010	0.010			
	T _m	0.003	0.007			
	ufs		0.015			1.56
Corrected volume	V	0.38	uV	0.006 m ³	V = V _m f _s	1.58

$$f_s = \frac{(100 - H_m) 273}{100 T_m 101.3} \frac{p_m}{101.3}$$

Parameter	Value	Units	Sensitivity coeff	Uncertainty contribution	Uncertainty as %
Corrected Volume (standard)	V	0.38 m ³	0.52	0.00 mg.m ⁻³	1.58 %
Mass	m	0.40 mg	0.50	0.11 mg.m ⁻³	57.30 %
Leak	L	0.00 mg.m ⁻³	1.00	0.00 mg.m ⁻³	1.15 %
Uncollected mass	UCM	0.00 mg	0.50	0.00 mg.m ⁻³	0.00 %
Combined measurement uncertainty				0.11 mg.m ⁻³	

Expanded uncertainty as percentage of measured value	114.68	% measured of value	expressed with a level of confidence of 95% (Using a coverage factor k=2)
Expanded uncertainty in units of measurement	0.23	mg.m ⁻³	
Expanded uncertainty as percentage of limit value	0.46	% ELV	

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Uncertainty calculation for EN 13284 Determination of low range mass concentration of dust, Manual Gravimetric Method

Spray Booth Two Run One

Measurement Equation

$$c = \frac{m}{V} f_c$$

Limit value (ELV)	50	mg.m ⁻³	Reference oxygen	20.9	% by volume
Measured concentration	9.41	mg.m ⁻³ (at reference conditions)			

Measured Quantities	Symbol	Value	Standard uncertainty	Units	Uncertainty as percentage	Uncertainty at lv	Requirement of std
Sampled Volume	V _m	0.99	uV _m	0.001 m ³	0.10		<=2%
Sampled gas Temperature	T _m	293	uT _m	2 K	0.68		<=1%
Sampled gas Pressure	p _m	102.45	up _m	1 kPa	0.98		<=1%
Sampled gas Humidity	H _m	0	uH _m	1 % by volume	1.00		<=1%
Mass particulate	m	8.756666667	um	0.24 mg	2.71	0.51	<5% of limit value
Note - Sampled gas humidity, temperature and pressure are values at the gas meter							
Leak	L	2		%	2.00		<=2%
Uncollected Mass (Instack filter - no rinse)	UCM	0		mg	0		<=10%

Intermediate calculations

Factor for std conds	fs	0.94				
uncertainty components	symbol	sensitivity coeff	u (in units of fs)			
	p _m	0.009	0.009			
	H _m	0.009	0.009			
	T _m	0.003	0.006			
	ufs		0.015			1.56
Corrected volume	V	0.93	uV	0.015 m ³	V = V _m f _s	1.56

$$f_s = \frac{(100 - H_m) 273}{100 T_m 101.3} p_m$$

Parameter	Value	Units	Sensitivity coeff	Uncertainty contribution	Uncertainty as %
Corrected Volume (standard)	V	0.93 m ³	10.10	0.15 mg.m ⁻³	1.56 %
Mass	m	8.76 mg	1.07	0.26 mg.m ⁻³	2.71 %
Leak	L	0.11 mg.m ⁻³	1.00	0.11 mg.m ⁻³	1.15 %
Uncollected mass	UCM	0.00 mg	1.07	0.00 mg.m ⁻³	0.00 %
Combined measurement uncertainty				0.32 mg.m ⁻³	

Expanded uncertainty as percentage of measured value

6.75

% measured of value

expressed with a level of confidence of 95%
(Using a coverage factor k=2)

Expanded uncertainty in units of measurement

0.64

mg.m⁻³

Expanded uncertainty as percentage of limit value

1.27

% ELV

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Uncertainty calculation for EN 13284 Determination of low range mass concentration of dust, Manual Gravimetric Method

Spray Booth Three Run One

Measurement Equation

$$c = \frac{m}{V} f_c$$

Limit value (ELV)	50	mg.m ⁻³	Reference oxygen	20.9	% by volume
Measured concentration	1.25	mg.m ⁻³ (at reference conditions)			

Measured Quantities	Symbol	Value	Standard uncertainty	Units	Uncertainty as percentage	Uncertainty at lv	Requirement of std
Sampled Volume	V _m	0.44	uV _m	0.001 m ³	0.23		<=2%
Sampled gas Temperature	T _m	295	uT _m	2 K	0.68		<=1%
Sampled gas Pressure	p _m	101.8	up _m	1 kPa	0.98		<=1%
Sampled gas Humidity	H _m	0	uH _m	1 % by volume	1.00		<=1%
Mass particulate	m	0.53	um	0.23 mg	43.53	1.09	<5% of limit value
Note - Sampled gas humidity, temperature and pressure are values at the gas meter							
Leak	L	2		%	2.00		<=2%
Uncollected Mass	UCM	0		mg	0		<=10%
(Instack filter - no rinse)							

Intermediate calculations					
Factor for std conds	fs	0.93			
uncertainty components	symbol	sensitivity coeff	u (in units of fs)		
	p _m	0.009	0.009		
	H _m	0.009	0.009		
	T _m	0.003	0.006		
	ufs		0.014		1.56
Corrected volume	V	0.41	uV	0.006 m ³	1.58
V = V _m f _s					

$$f_s = \frac{(100 - H_m) 273}{100 T_m 101.3}$$

Parameter	Value	Units	Sensitivity coeff	Uncertainty contribution	Uncertainty as %
Corrected Volume (standard)	V	0.41 m ³	3.04	0.02 mg.m ⁻³	1.58 %
Mass	m	0.53 mg	2.37	0.54 mg.m ⁻³	43.53 %
Leak	L	0.01 mg.m ⁻³	1.00	0.01 mg.m ⁻³	1.15 %
Uncollected mass	UCM	0.00 mg	2.37	0.00 mg.m ⁻³	0.00 %
Combined measurement uncertainty				0.54 mg.m ⁻³	

Expanded uncertainty as percentage of measured value	87.15	% measured of value	expressed with a level of confidence of 95% (Using a coverage factor k=2)
Expanded uncertainty in units of measurement	1.09	mg.m ⁻³	
Expanded uncertainty as percentage of limit value	2.18	% ELV	

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Uncertainty calculation for Gaseous Measurement TOC to EN 12619:1999

Spray Booth One

Limit value	50 mg/m ³ (corrected) TOC	Cal gas conc	85.1 mg.m ⁻³ TOC
Measured concentration	5.2 mg/m ³	Full Scale	161 mg/m ³
Measured concentration	5.2 mg/m ³ (Corrected)		

Correction for reference conditions				
	O ₂ , %	Moisture, %	Pressure, KPa	Temperature, K
ref	20.90	0.00	101.30	273.00
measured	20.90	0.00	101.30	273.00
Uncert	0.00	1.00	0.00	1.00
Factors	1.00	1.00	1.00	1.00
Uncertainty in factor	0.00	0.01	0.00	0.00
Correction Factor	1.00	uf	0.01	

Performance characteristics	Value		specification
Response time	20	seconds	60.000
Logger sampling interval	60	seconds	
Measurement period	31	minutes	
Number of readings in measurement	31		
Repeatability at zero	0.133	mg/m ³	0.133 mg/m ³
Repeatability at span level	0.15	mg/m ³	0.2 mg/m ³
Deviation from linearity (lack of fit)	0.4	mg/m ³	< 0.4 mg/m ³
Zero drift	0.2	mg/m ³	0.4 mg/m ³ (long term)
Span drift	1.54	mg/m ³	0.7 mg/m ³ (long term)
Volume or pressure flow dependence	0.02	% of full scale/3 kPa	< 2 % / 3 kPa
atmospheric pressure dependence	0.8	% of full scale/2 kPa	< 3% / 2 kPa
ambient temperature dependence	0.01	mg/m ³	0.5 mg/m ³ / 10K (at span)
O ₂ (% vol)	20	0.2	mg/m ³
SO ₂ (mg/m ³)	260	0.2	mg/m ³
NO (mg/m ³)	660	0.2	mg/m ³
NO ₂ (mg/m ³)	150	0.2	mg/m ³
CO (mg/m ³)	430	0.2	mg/m ³
CO ₂ (% vol)	18	0.2	mg/m ³
HCl (mg/m ³)	40	0.2	mg/m ³
H ₂ O (% vol)	20	0.2	mg/m ³
dependence on voltage		0.1	% full scale/10V
Control gas reading difference		10	% of value
losses in the line (leak)		1	% of value
Uncertainty of calibration gas		2.00	% of value

Effect of drift
0.29 mg/m ³
0.18 % full scale

	min	max	value at calib.
flow	95.00	105	100 kPa
pressure	100.76	100.92	100.88 kPa
temp	287	288.5	287.5 K
O ₂ range	0	16	20 % vol
SO ₂ range	0	300	0 mg/m ³
NO range	0	600	0 mg/m ³
NO ₂ range	0	50	0 mg/m ³
CO range	0	500	0 mg/m ³
CO ₂ range	0	20	0 % vol
HCl range	0	5	0 mg/m ³
H ₂ O range	0	20	0 % vol
Voltage	93	121	110 V

Performance characteristic	Uncertainty	Value of uncertainty quantity	mg/m ³
Standard deviation of repeatability at zero	U ₀₂	for mean	0.02
Standard deviation of repeatability at span level	U ₀₃	for mean	use rep at zero
Lack of fit	U ₀₄		0.23
Drift	U ₀₅		0.17
Volume or pressure flow dependence	U ₀₆		0.03
atmospheric pressure dependence	U ₀₇		0.04
ambient temperature dependence	U ₀₈		0.00
O ₂	U ₀₉		0.11
SO ₂ (mg/m ³)	U ₁₀		0.13
NO (mg/m ³)	U ₁₁		0.08
NO ₂ (mg/m ³)	U ₁₂		0.04
CO (mg/m ³)	U ₁₃		0.13
CO ₂ (% vol)	U ₁₄		0.13
HCl (mg/m ³)	U ₁₅		0.01
H ₂ O (% vol)	U ₁₆		0.12
Dependence on voltage	U ₁₇		0.14
losses in the line (leak)	U ₁₈		0.03
Uncertainty of calibration gas	U ₁₉		0.06
control gas	U ₂₀		0.30
Uncertainty in factor	uf		0.06

Use largest of sum of all positive or all negative influences		
Criteria		
sum < 1 mg/m ³		
0.104459613		
Value to use for interference uncertainty		
U _{int}	0.17	

Measurement uncertainty			
Combined uncertainty		0.48	mg/m ³
Expanded uncertainty	k = 2	0.96	mg/m ³
Uncertainty corrected to std conds		0.96	mg/m ³
Expanded uncertainty	expressed with a level of confidence of 95%	1.93	% ELV
Expanded uncertainty	expressed with a level of confidence of 95%	0.96	mg.m ⁻³
Expanded uncertainty	expressed with a level of confidence of 95%	18.44	% value

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

Uncertainty calculation for Gaseous Measurement TOC to EN 13526:2001

Spray Booth Two			
Limit value	50 mg/m ³ (corrected) TOC	Cal gas conc	82.8 mg.m ⁻³ TOC
Measured concentration	8.4 mg/m ³	Full Scale	161 mg/m ³
Measured concentration	8.4 mg/m ³ (Corrected)		

Correction for reference conditions				
	O ₂ , %	Moisture, %	Pressure, KPa	Temperature, K
ref	20.95	0.00	101.30	273.00
measured	20.95	0.00	101.30	273.00
Uncert	0.00	1.00	0.00	1.00
Factors	1.00	1.00	1.00	1.00
Uncertainty in factor	0.00	0.01	0.00	0.00
Correction Factor	1.00	uf	0.01	

Effect of drift	
0.29 mg/m ³	
0.18 % full scale	

Performance characteristics	Value		specification
Response time	20	seconds	60,000
Logger sampling interval	60	seconds	
Measurement period	31	minutes	
Number of readings in measurement	31		
Repeatability at zero	0.133	mg/m ³	0.133 mg/m ³
Repeatability at span level	0.15	mg/m ³	0.2 mg/m ³
Deviation from linearity (lack of fit)	0.4	mg/m ³	< 0.4 mg/m ³
Zero drift	0.03	mg/m ³	0.4 mg/m ³ (long term)
Span drift	2.54	mg/m ³	0.7 mg/m ³ (long term)
volume or pressure flow dependence	0.02	% of full scale/3 kPa	<2 % / 3 kPa
atmospheric pressure dependence	0.8	% of full scale/2 kPa	<3% / 2 kPa
ambient temperature dependence	0.01	mg/m ³	0.5 mg/m ³ /10k (at span)
O ₂ (% vol)	20	mg/m ³	0.8 mg/m ³
SO ₂ (mg/m ³)	260	mg/m ³	
NO (mg/m ³)	880	mg/m ³	
NO ₂ (mg/m ³)	150	mg/m ³	
CO (mg/m ³)	430	mg/m ³	
CO ₂ (% vol)	18	mg/m ³	
HCl (mg/m ³)	40	mg/m ³	
H ₂ O (% vol)	20	mg/m ³	
dependence on voltage	0.1	% full scale/10V	<2% range
Control gas reading difference	10	% of value	within 15% of test gas value (5 mg/m ³)
losses in the line (leak)	1	% of value	< 0.1%vol /10 volt
Uncertainty of calibration gas	2.00	% of value	< 2% of value

	min	max	value at calib
flow	95.00	105	100 kPa
pressure	100.78	100.92	100.88 kPa
temp	287	288.5	287.5 K
O ₂ range	6	16	20 % vol
SO ₂ range	0	300	0 mg/m ³
NO range	0	600	0 mg/m ³
NO ₂ range	0	50	0 mg/m ³
CO range	0	500	0 mg/m ³
CO ₂ range	0	20	0 % vol
HCl range	0	5	0 mg/m ³
H ₂ O range	0	20	0 % vol
Voltage	93	121	110 V

Performance characteristic	Uncertainty	Value of uncertainty quantity	mg/m ³
Standard deviation of repeatability at zero	U ₀	for mean	0.02
Standard deviation of repeatability at span level	U ₁	for mean	use rep at zero
Lack of fit	U ₂		0.23
Drift	U ₃		0.17
volume or pressure flow dependence	U ₄		0.03
atmospheric pressure dependence	U ₅		0.04
ambient temperature dependence	U ₆		0.00
O ₂	U ₇		0.11
SO ₂ (mg/m ³)	U ₈		0.13
NO (mg/m ³)	U ₉		0.08
NO ₂ (mg/m ³)	U ₁₀		0.04
CO (mg/m ³)	U ₁₁		0.13
CO ₂ (% vol)	U ₁₂		0.13
HCl (mg/m ³)	U ₁₃		0.01
H ₂ O (% vol)	U ₁₄		0.12
Dependence on voltage	U ₁₅		0.14
losses in the line (leak)	U ₁₆		0.05
Uncertainty of calibration gas	U ₁₇		0.10
control gas	U ₁₈		0.49
Uncertainty in factor	uf		0.09

Use largest of sum of all positive or all negative influences		

Measurement uncertainty			
Combined uncertainty		0.62	mg/m ³
Expanded uncertainty	k = 2	1.23	mg/m ³
Uncertainty corrected to std conds			
Expanded uncertainty	expressed with a level of confidence of 95%	2.49	% ELV
Expanded uncertainty	expressed with a level of confidence of 95%	1.24	mg.m ⁻³
Expanded uncertainty	expressed with a level of confidence of 95%	14.81	% value

NATIONAL PHYSICAL LABORATORY

Continuation Sheet

Uncertainty calculation for Gaseous Measurement TOC to EN 12619:1999

Spray Booth Three			
Limit value	50	mg/m ³ (corrected) TOC	Cal gas conc
			82.8 mg.m ⁻³ TOC
Measured concentration	40.8	mg/m ³	Full Scale
Measured concentration	40.8	mg/m ³ (Corrected)	1605 mg/m ³

Correction for reference conditions					
		O ₂ , %	Moisture, %	Pressure, KPa	Temperature, K
	ref	20.95	0.00	101.30	273.00
	measured	20.95	0.00	101.30	273.00
	Uncert	0.00	1.00	0.00	1.00
Factors		1.00	1.00	1.00	1.00
Uncertainty in factor		0.00	0.01	0.00	0.00
Correction Factor		1.00	1.01	0.01	0.00

Effect of drift
0.33 mg/m ³
0.02 % full scale

Performance characteristics	Value		specification
Response time	20	seconds	60.000
Logger sampling interval	60	seconds	
Measurement period	31	minutes	
Number of readings in measurement	31		
Repeatability at zero	0.133	mg/m ³	0.133 mg/m ³
Repeatability at span level	0.15	mg/m ³	0.2 mg/m ³
Deviation from linearity(lack of fit)	0.4	mg/m ³	< 0.4 mg/m ³
Zero drift	0.17	mg/m ³	0.4 mg/m ³ (long term)
Span drift	0.33	mg/m ³	0.7 mg/m ³ (long term)
volume or pressure flow dependence	0.02	% of full scale/3 kPa	<2 % / 3 kPa
atmospheric pressure dependence	0.8	% of full scale/2 kPa	<3% / 2 kPa
ambient temperature dependence	0.01	mg/m ³	0.5 mg/m ³ /10k (at span)
O ₂ (% vol)	20	mg/m ³	0.8 mg/m ³
SO ₂ (mg/m ³)	260	mg/m ³	
NO (mg/m ³)	860	mg/m ³	
NO ₂ (mg/m ³)	150	mg/m ³	
CO (mg/m ³)	430	mg/m ³	
CO ₂ (% vol)	18	mg/m ³	
HCl (mg/m ³)	40	mg/m ³	
H ₂ O (% vol)	20	mg/m ³	
dependence on voltage	0.1	% full scale/10V	<2% range
Control gas reading difference	10	% of value	within 15% of test gas value
losses in the line (leak)	1	% of value	< 0.1%/vol /10 volt
Uncertainty of calibration gas	2.00	% of value	< 2% of value

	ranges		value at calib
	min	max	
flow	95.00	105	100 kPa
pressure	100.76	100.92	100.88 kPa
temp	267	268.5	267.5 K
O2 range	6	16	20 % vol
SO2 range	0	300	20 mg/m3
NO range	0	600	0 mg/m3
NO2 range	0	50	0 mg/m3
CO range	0	500	0 mg/m3
CO2 range	0	20	0 % vol
HCl range	0	5	0 mg/m3
H2O range	0	20	0 % vol
Voltage	93	121	110 V

Performance characteristic	Uncertainty	Value of uncertainty quantity	mg/m3
Standard deviation of repeatability at zero	u_{r0}	for mean	0.02
Standard deviation of repeatability at span level	u_{rs}	for mean	use rep at zero
Lack of fit	u_{lof}		0.23
Drift	u_{drf}		0.19
volume or pressure flow dependence	u_{qpmx}		0.31
atmospheric pressure dependence	u_{apmx}		0.39
ambient temperature dependence	u_{atmp}		0.00
O2	u_{o2ref}		0.11
SO2 (mg/m3)	u_{so2ref}		0.13
NO (mg/m3)	u_{no2ref}		0.08
NO2 (mg/m3)	u_{no2ref}		0.04
CO (mg/m3)	u_{co2ref}		0.13
CO2 (% vol)	u_{co2ref}		0.13
HCl (mg/m ³)	u_{hclref}		0.01
H2O (% vol)	u_{h2oref}		0.12
Dependence on voltage	u_{vlt}		1.38
losses in the line (leak)	u_{lak}		0.24
Uncertainty of calibration gas	u_{cals}		0.47
control gas	u_{conref}		2.36
Uncertainty in factor	u_f		0.43

Use largest of sum of all positive or all negative influences	
0.17 all +ves	Criteria
0.00 all -ves	sum < 1 mg/m3
0.17 largest	0.816815565
Value to use for interference uncertainty	
u_{int}	0.17

Measurement uncertainty				
Combined uncertainty			2.85	mg/m ³
Expanded uncertainty	k =	2	5.70	mg/m ³
Uncertainty corrected to std cond			5.77	mg/m ³
Expanded uncertainty	expressed with a level of confidence of 95%		11.53	% ELV
Expanded uncertainty	expressed with a level of confidence of 95%		5.77	mg.m ⁻³
Expanded uncertainty	expressed with a level of confidence of 95%		14.12	% value

2.2.9 - Analytical Results

NATIONAL PHYSICAL LABORATORY
Continuation Sheet

2.2.9 Analytical Laboratory Details

	Isocyanates
Analytical Laboratory	RPS Laboratories
UKAS Lab Number	0605
Analytical Method	HPLC
Accreditation	UKAS
Date of Analysis	25/02/2013

2.2.10 - Calculations Used in Reporting Results

Nozzle Selection

For isokinetic sampling, the pressure difference of the orifice meter must equal the pressure difference of the Pitot tube pressure multiplied by the K-factor. Where:

$$K = \text{Constant} \times C_p^2 \times D_n^4 \times DH_{@} \times \left(\frac{M_d}{M_s} \right) \left(\frac{1 - B_{wm}}{1 - B_{ws}} \right)^2 \left(\frac{T_m + 273}{T_s + 273} \right) \left(\frac{P_s}{P_m} \right)$$

$$DH = K \times Dp$$

Where:-

Constant: is a constant dependent on the units used to measure the nozzle (8.038×10^{-5} for mm)

D_n the nozzle diameter mm

$DH_{@}$ a constant dependent on the sampler control box orifice and gas meter

B_{ws} the percent water vapour in the emission as a fraction i.e. 12% = 0.12

B_{wm} the percentage water vapour in the air around the meter box often assumed to be zero

C_p Pitot tube coefficient dependent on the Pitot tube type

T_m the meter temperature in °C

T_s the stack temperature in °C

P_s the stack pressure

P_m the meter pressure

M_d dry gas molecular weight

M_s apparent stack gas molecular weight

DH pressure drop across the orifice (mm water)

DP differential Pitot pressure (mm water)

From this the correct nozzle size can be determined.

$$D_n = \sqrt{\left(\frac{\text{Constant} \cdot Q_m \cdot P_m}{(T_m + 273) C_p} \right) \left(\frac{1 - B_{wm}}{1 - B_{ws}} \right) \sqrt{\frac{(T_s + 273) M_s}{(P_s \cdot (\Delta P)_{avg})}}}$$

Where the Constant = 0.6071 Metric

Q_m = Orifice flow rate normally 21.2 actual lmin⁻¹

$$= K_m \sqrt{\frac{(T_m + 273) \Delta H}{P_m M_m}}$$

Where K_m = Orifice meter coefficient

$$K_m = Q_m \sqrt{\frac{P_m M_m}{\Delta H (T_m + 273)}} = \text{Const} \sqrt{\frac{1}{\Delta H_{@}}}$$

Where Const = 183.7 metric

Moisture Determination Calculations

These calculations are based at 273K and 101.325kPa

To calculate moisture the following equation is used:

$$B_{ws} = \frac{0.001245 \times W_I \times 100}{(0.001245 \times W_I) + 0.359V_m \left(\frac{P_b + \frac{\Delta H_{avg}}{13.6}}{(T_m + 273)} \right)}$$

Particulate Concentration C_s in stack Gases
At 273K and 101.325kPa and dry gas

$$C_s = \frac{W_t}{V_m} \times \frac{T_m + 273}{273} \times \frac{760}{\left(P_b + \frac{\Delta H_{avg}}{13.6} \right)} \times 1000 \quad \text{mg/Nm}^3$$

Oxygen Concentration Correction C_{oxy} to Particulate concentration

$$C_{oxy} = C \times \frac{(20.9 - \%O_2 \text{ref})}{(20.9 - \%O_2 \text{Meas})} \quad \text{mg/Nm}^3$$

Dry Molecular Weight of gases

$$M_D = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%CO + \%N)$$

Stack Molecular Weight of gases

$$M_s = 0.18(B_{ws}) + \frac{M_d}{100}(100 - B_{ws})$$

Stack Gas Velocity

$$(V_s)_{avg} = 34.96 \times C_p \times \sqrt{(\Delta P)_{avg}} \sqrt{\frac{T_s + 273}{P_s M_s}} \quad \text{m/s}$$

Mass Emission Rate M_R

$$M_R = \frac{C_m \times (V_s)_{avg} \times A \times 3600}{10^6} \quad \text{kg/hr}$$

IsoKinicity

$$I = \frac{2.12 \times 10^8 \times V_m \times Y \times \left(P_b + \left(\frac{\Delta H_{avg}}{13.6} \right) \right) \left(\frac{273 + T_s}{273 + T_m} \right)}{\Theta P_s \pi D_n^2 (V_s)_{avg} (100 - B_{ws})} \%$$

- W_I = the weight change of the impingers during sampling in g
- V_m = volume of dry gas sample in litres at temperature of the meter box
- B_{ws} = the percent water vapour in the emission
- Q = length of time sampling in minutes
- Y = Gas Meter Calibration correction factor
- V_s = Velocity of stack gas m/s
- C_M = measured concentration of particulate matter (mg/m³)
- T_m = average temperature at dry gas meter (°C)
- P_b = atmospheric pressure (mmHg)
- $\%O_{2ref}$ = % oxygen at standard temperature & pressure
- $\%O_{2Meas}$ = % oxygen measured on site
- C_p = Pitot tube coefficient
- DP = mean differential Pitot pressure drop (mm H₂O)
- DH = mean orifice pressure drop (mm H₂O)
- D_s = diameter of stack (m)
- D_n = Nozzle diameter (mm)
- T_s = stack temperature (°C)
- M_d = molecular weight of dry stack gas
- B_w = moisture fraction
- P_s = stack pressure (mmHg)
- A = duct c.s.a. (m²)
- M_s = molecular weight of wet stack gas
- M_d = molecular weight of dry stack gas
- W_t = total weight of particulate matter (g)