



**Client** Linx Printing Technologies Limited  
 Linx House  
 8 Stocks Bridge Way  
 St Ives  
 Cambridgeshire  
 PE27 5JL

**Part 1: Executive Summary**

**Report for the Periodic Monitoring of Emissions to Air.**

<i>Site</i>	<b>St Ives</b>
<i>Plant</i>	<b>Environmental Chamber Room 2</b>
<i>Sampling Date</i>	<b>4th November 2015</b>
<i>Report Date</i>	<b>2nd December 2015</b>
<i>Job Number</i>	<b>EM-2112</b>
<i>Permit Number</i>	<b>B18/14</b>

<b>Report Prepared by:</b>	<i>Print</i>	<b>Harpreet Badwal</b>	
	<i>MCERTS No.</i>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<i>Sign</i>		
	<i>Print</i>	<b>Derek Myers</b>	
	<i>MCERTS No.</i>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
 Unit 19  
 Bordesley Green Trading Estate  
 Bordesley Green Road  
 Birmingham  
 B8 1BZ

Tel: 0845 676 9303  
 Company Registration No 03133832



## Contents

Page 1	<b>Part 1: Executive Summary</b>
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results
Page 5	Summary Of Results, Exhaust Gases
Page 6	Operating Information
Page 6	Comments On Monitoring Procedures
Page 7	<b>Part 2: Supporting Information</b>
Page 8	<b>Appendix 1</b>
Page 9	Emission Monitoring Procedures and Instrumentation
Page 10	Sampling Personnel
Page 10	Equipment References
Page 11	<b>Appendix 2</b>
Page 12	Preliminary Velocity Traverse Data
Page 13	Exhaust Gases - Continuous Analysis Data
Page 14	Chart 1 - VOC Emissions Data
Page 15	<b>Appendix 3</b>
Page 16	Diagram of Sampling Location
Page 17	Generic Calculations
Page 18	Flow Calculations
Page 19	Concentration Calculation
Page 20	Uncertainty Estimate Calculations - Instrumental Techniques
Page 21	<b>Appendix 4</b>
Page 22	Uncertainty Estimates:- TOC

## Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
Environmental Chamber Room 2	Total organic carbon

## Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

## Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow TOC	TPM/01A TPM/13	BS EN ISO 16911-1:2013 BS EN 12619 : 2013

### Summary Of Results

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**  
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives Environmental Chamber Room 2	Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
	Date	Start	End					
TOC	04/11/15	09:45	11:15	16.5	75	1.2	0.2	7.1

* at reference conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
---------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
 \*\* Analysis not required # - UKAS accredited only  
 ND Non detectable ## - Not Accredited  
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated.  
 Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



### Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**. The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives		Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
		Date	Start	End					
Environmental Chamber Room 2									
TOC	Test 1	04/11/15	09:45	10:15	30.5	75	1.3	0.2	13.1
TOC	Test 2	04/11/15	10:15	10:45	17.7	75	1.2	0.2	7.6
TOC	Test 3	04/11/15	10:45	11:15	1.2	75	1.2	0.2	0.5

* at ref	Stack Gas Weight	0 °C	Without correction for moisture
Conditions	29.00 Kg/kmol	101.3 kPa	Oxygen No Correction %

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
 \*\* Analysis not required # - UKAS accredited only  
 ND Non detectable ## - Not Accredited  
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



## Operating Information

The table below shows details of the operating information on each sampling date for: **Environmental Chamber Room 2**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
04/11/2015	Environmental Test Chamber	Continuous	N/A	Methyl Ethyl Ketone	None	Three printers being tested at 50°C

There are no CEM's available on this process.

## Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-  
The homogeneity test is not applicable to non-combustion processes.  
The homogeneity test is not applicable to duct areas less than 1m<sup>2</sup>.

All monitoring was performed in accordance with the relevant procedures.

The sampling location is a vertical duct.

Only one sample port was available on the vertical duct.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.




**Part 2: Supporting Information**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Client</b>	Linx Printing Technologies Limited
<b>Site</b>	St Ives
<b>Plant</b>	Environmental Chamber Room 2
<b>Sampling Date</b>	4th November 2015
<b>Report Date</b>	2nd December 2015
<b>Job Number</b>	EM-2112
<b>Permit Number</b>	B18/14

<b>Report Prepared by:</b>	<b>Print</b>	<b>Harpreet Badwal</b>	
	<b>MCERTS No.</b>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	<b>Derek Myers</b>	
	<b>MCERTS No.</b>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832

 a CONCEPT LIFE SCIENCES company



## APPENDIX 1

## **Emission Monitoring Procedures And Instrumentation**

### **Gas velocity and temperature**

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013. Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

### **Total organic carbon**

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013. Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

### Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Report authorised by:	Derek Myers	MM02 115	-	30/09/2017	31/05/2018	30/11/2018	30/11/2018	30/11/2018
Team leader:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Team leader:	Aidan Wryenne	MM08 921	-	31/05/2017	31/05/2017	31/11/2018	30/11/2017	30/06/2018

### Equipment References

Equipment	Reference Number
FID	AQ271
Heated Line	HL40
Heated Filter	Sintered
Stack Thermocouple	PTTS97
Timer / Stopwatch	ST41
Barometer	WS03
Pitot	PT129
Thermometer	TK28
Manometer	PI03

## APPENDIX 2

Date	04/11/2015
Time	11:35
Pitot Cp	1.01

Barometric pressure	101.0	kPa
Duct static pressure	0.01	kPa
Stack Area	0.031	m <sup>2</sup>

Stack Diameter (circular)	0.20	m
---------------------------	------	---

Traverse Point	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s
1	A						B					
2	A						B					
3	A						B					
4	A						B					
5	A	5.0	1.1	53	<15	4.6	B					
6	A	7.1	1.1	53	<15	4.6	B					
7	A	12.9	1.2	53	<15	4.8	B					
8	A	15.0	1.0	53	<15	4.3	B					
9	A						B					
10	A						B					
11	A						B					
12	A						B					

Average Pitot DP	1.12	mmH <sub>2</sub> O
Average Temperature	326.2	K
Average Velocity	4.6	m/s
Average volumetric flow rate	0.14	m <sup>3</sup> /s at stack conditions
Average volumetric flow rate	0.12	m <sup>3</sup> /s (wet STP)

**Sampling plane requirements Re: BS EN 13284-1:2001 5.2**

a	Angle of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	4.3
	Maximum local gas velocity	4.8
	Ratio of highest to lowest local gas velocity	1.10

**Preliminary Velocity Traverse Data**

Date 04/11/2015

From 09:45 to 10:15 30 minute mean

Volatile organic compounds	vppm, wet	19.00	mg/m <sup>3</sup> *	30.54
----------------------------	-----------	-------	---------------------	-------

From 10:15 to 10:45 30 minute mean

Volatile organic compounds	vppm, wet	11.03	mg/m <sup>3</sup> *	17.72
----------------------------	-----------	-------	---------------------	-------

From 10:45 to 11:15 30 minute mean

Volatile organic compounds	vppm, wet	0.77	mg/m <sup>3</sup> *	1.23
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m <sup>3</sup> *	0.16
----------------------------	------	------	---------------------	------

Reference Gas Details


Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VCK01959	-	± 2
Volatile organic compounds	vppm	74.7	VC59841	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	08:54	Final Time	17:55
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	74.70	0.12	75.08

**Exhaust Gas Continuous Analysis Data**

Chart 1 - VOC Emissions Data - Environmental Chamber Room 2, 04/11/2015




## APPENDIX 3

## Diagram Of The Sampling Location

Diagram of sampling points across the cross section of the duct (not to scale).

Traverse length = 0.20 m

Point	% of D	Location cm
1	50.0	10.0



## General Calculations

### Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

$\pi$  = 3.142

### Pressure conversion:

1mmH<sub>2</sub>O = 0.00980665 kPa

1mmH<sub>2</sub>O = 9.80665 Pa

1 mar = 0.1 kPa

### Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m<sup>3</sup> of water vapour in m<sup>3</sup> of wet gas)

V<sub>m(std)</sub> = Dry gas volume measured, corrected to standard conditions (m<sup>3</sup>)

m<sub>WC</sub> = Mass of water collected in the impingers (g)

M<sub>w</sub> = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

V<sub>mol(std)</sub> = Molar volume of water at standard conditions = 0.0224 (m<sup>3</sup>/mol)

### Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

V<sub>m(std)</sub> = Dry gas meter volume at standard conditions (m<sup>3</sup>)

y<sub>d</sub> = Gas meter calibration coefficient

(V<sub>2</sub>-V<sub>1</sub>) = Dry gas meter volume at actual conditions (m<sup>3</sup>)

T<sub>m</sub> = Actual Temperature (K)

T<sub>std</sub> = Standard temperature (273 K)

p<sub>m</sub> = Absolute pressure at the gas meter (kPa)

p<sub>std</sub> = Standard gas pressure (101.3 kPa)

### Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

### Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

## Flow Calculations

### Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

$\bar{v}$  = Average velocity (m/s)

$C$  = velocity calculation constant = 129

$T_s$  = Average stack temperature (K)

$M_s$  = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

$K$  = Pitot calibration coefficient

$p_e$  = Absolute gas pressure (kPa)

$\Delta p$  = Average pitot tube pressure differential (kPa)

### Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

$q_{va}$  = Average flow rate (m<sup>3</sup>/s)

$\bar{v}$  = Average velocity (m/s)

$A$  = Stack cross-sectional area (m<sup>2</sup>)

### Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$H_a$  = Moisture at actual conditions (%volume)

$H_m$  = Reference moisture (%volume)

### Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$T_a$  = Temperature at actual conditions (K)

$T_m$  = Reference Temperature (K)

$p_a$  = Absolute gas pressure at actual conditions (kPa)

$p_m$  = Reference pressure (kPa)

### Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$O_{2,m}$  = Actual oxygen concentration (%)

$O_{2,ref}$  = Reference oxygen concentration (%)

## Concentration Calculations

### Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

$c$  = Concentration  
 $m$  = Mass of substance  
 $V$  = Volume sampled

### Mass Emission

$$\text{Mass emission} = c \times q_m$$

$c$  = Concentration  
 $q$  = Volume flow rate

### Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

$c_m$  = Concentration at reference conditions  
 $c_a$  = Actual concentration  
 $O_{2, ref}$  = Reference oxygen (%)  
 $O_{2, a}$  = Actual Oxygen (%)

### Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

$c_{wet}$  = Concentration wet gas  
 $c_{dry}$  = Concentration dry gas  
 $H_a$  = Water vapour content (%vol)

### Conversion of parts per million (ppm) to mg/m<sup>3</sup>

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

### When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

## Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

### Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

$C_{ppm}$	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

### Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left( \frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$  is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:  
 $S_{r,0}$  is the standard uncertainty at zero level  
 $S_{r,s}$  is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:  
 $u(Corr_{loss})$  is the uncertainty due to losses in sample line  
 $u(Corr_{cal})$  is the uncertainty due to losses in sample line  
 $c_{j,loss}$  is the concentration of sample loss at span level  
 $U_{cal}$  is the expanded uncertainty of the calibration gas

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:  
 $c_j$  is the sensitivity coefficient of the influence quantity  
 $x_{j,min}$  is the minimum value of the influence quantity during monitoring  
 $x_{j,max}$  is the maximum value of the influence quantity during monitoring  
 $x_{j,adj}$  is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:  
 $c_j$  is the sensitivity coefficient of the interferent j  
 $Int_{j,test}$  is the concentration of the interferent j used to determine  $c_j$   
 $Int_{j,min}$  is the minimum value of the interferent j quantity during monitoring  
 $Int_{j,max}$  is the maximum value of the interferent j quantity during monitoring  
 $Int_{j,adj}$  is the concentration of the interferent j in the cal gas used to adjust the analyser  
 $S_{int,p}$  is the sum of interferences with positive impact  
 $S_{int,n}$  is the sum of interferences with negative impact

### Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2)  $U(C_m) = u(C_m) \times k$

### Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:  
 $C_{NOx}$  is the concentration of NOx measured by the analyser  
 $R$  is the ratio of NO:Nox in the stack gas  
 $\eta$  is the NOx converter efficiency

### Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

### Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left( \frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O <sub>2</sub> ref. concentration	in	mg/m <sup>3</sup>
$C_{O_2,ref}$	=	mass concentration at O <sub>2</sub> reference concentration	in	mg/m <sup>3</sup>
$O_{2,meas}$	=	O <sub>2</sub> measured concentration	in	% volume
$u(O_{2,meas,dry})$	=	uncertainty associated to the measured O <sub>2</sub> concentration	in	% (relative to O <sub>2,meas</sub> )

## APPENDIX 4

**Uncertainty Estimate For The Measurement Of Total Organic Carbon**

Analyser Type/Model 

Sick Maihak
-------------

  
 Reference Oxygen % 

0
---

 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m <sup>3</sup>	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	19.0	11.0	0.8
Measured concentration	mg/m <sup>3</sup>	30.5	17.7	1.2
Concentration at O <sub>2</sub> ref. concentration	mg/m <sup>3</sup>	N/A	N/A	N/A

Calibration gas	ppm	74.7	74.7	74.7
Calibration gas	mg/m <sup>3</sup>	120.1	120.1	120.1
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m <sup>3</sup>	15.0	15.0	15.0

Correction of Lack of Fit

Lack of fit	% range	2.0	2.0	2.0
	u(Corr <sub>lof</sub> )	0.11	0.11	0.11

Corrections of Zero and Span Drift (\*All drift is calculated for ∴ the residual is assumed to be < 5% u(max) )

Zero Drift	% range	0.00	0.00	0.00
	u(Corr <sub>zdrift</sub> )	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr <sub>spdrift</sub> )	0.00	0.00	0.00

Correction of Repeatability of Measurement

Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr <sub>rep</sub> )	0.00	0.00	0.00

Correction of adjustment

losses in the line	% range	0.27	0.27	0.27
	u(Corr <sub>loss</sub> )	0.03	0.02	0.00
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr <sub>cal</sub> )	0.19	0.11	0.01

Correction of Influence of Interferents

N <sub>2</sub> O	% range			
	u(Corr <sub>N2O</sub> )	0.00	0.00	0.00
CO <sub>2</sub>	% range			
	u(Corr <sub>CO2</sub> )	0.00	0.00	0.00
CH <sub>4</sub>	% range			
	u(Corr <sub>CH4</sub> )	0.00	0.00	0.00
Total of interferent influences u(ΣCorr <sub>int</sub> ) = max{Σ <sub>int,p</sub> <sup>2</sup> + Σ <sub>int,s</sub> }	% range	2.50	2.50	2.50
	u(ΣCorr <sub>int</sub> )	0.16	0.16	0.16

Correction of Influence Quantities

Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr <sub>flow</sub> )	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr <sub>press</sub> )	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr <sub>tempo</sub> )	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr <sub>volt</sub> )	0.10	0.10	0.10

Maximum standard uncertainty	u(Corr <sub>max</sub> )	0.19	0.11	0.11
5% of maximum standard uncertainty	u(Corr <sub>5%</sub> )	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH <sub>4</sub> range	0	10	0	50	mg/m <sup>3</sup>
N <sub>2</sub> O range	0	0	0	20	mg/m <sup>3</sup>
CO <sub>2</sub> range	8	12	0	15	mg/m <sup>3</sup>
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m <sup>3</sup>

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty		Test 1	Test 2	Test 3
Combined uncertainty	ppm	0.41	0.38	0.36
Combined uncertainty	mg/m <sup>3</sup>	0.66	0.61	0.59
Combined uncertainty at oxygen reference	mg/m <sup>3</sup>	0.66	0.61	0.59

Expanded uncertainty expressed with a level of confidence of 95%, k=2

Overall uncertainty	ppm	0.8	0.8	0.7
Overall uncertainty	mg/m <sup>3</sup>	1.3	1.2	1.2
Overall uncertainty relative to measured value	%	4.3	6.9	95.3
Overall uncertainty relative to range	%	8.8	8.2	7.8
Overall uncertainty relative to ELV	%	1.1	1.0	1.0

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



**Client** Linx Printing Technologies Limited  
 Linx House  
 8 Stocks Bridge Way  
 St Ives  
 Cambridgeshire  
 PE27 5JL

**Part 1: Executive Summary**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Site</b>	<b>St Ives</b>
<b>Plant</b>	<b>Fume Cupboard Extract Vent</b>
<b>Sampling Date</b>	<b>4th November 2015</b>
<b>Report Date</b>	<b>2nd December 2015</b>
<b>Job Number</b>	<b>EM-2112</b>
<b>Permit Number</b>	<b>B18/14</b>

<b>Report Prepared by:</b>	<b>Print</b>	<b>Harpreet Badwal</b>	
	<b>MCERTS No.</b>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	<b>Derek Myers</b>	
	<b>MCERTS No.</b>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
 Unit 19  
 Bordesley Green Trading Estate  
 Bordesley Green Road  
 Birmingham  
 B8 1BZ

Tel: 0845 676 9303  
 Company Registration No 03133832



## Contents

Page 1	<b>Part 1: Executive Summary</b>
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results
Page 5	Summary Of Results, Exhaust Gases
Page 6	Operating Information
Page 6	Comments On Monitoring Procedures
Page 7	<b>Part 2: Supporting Information</b>
Page 8	<b>Appendix 1</b>
Page 9	Emission Monitoring Procedures and Instrumentation
Page 10	Sampling Personnel
Page 10	Equipment References
Page 11	<b>Appendix 2</b>
Page 12	Preliminary Velocity Traverse Data
Page 13	Exhaust Gases - Continuous Analysis Data
Page 14	Chart 1 - VOC Emissions Data
Page 15	<b>Appendix 3</b>
Page 16	Diagram of Sampling Location
Page 17	Generic Calculations
Page 18	Flow Calculations
Page 19	Concentration Calculation
Page 20	Uncertainty Estimate Calculations - Instrumental Techniques
Page 21	<b>Appendix 4</b>
Page 22	Uncertainty Estimates:- TOC

## Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
Fume Cupboard Extract Vent	Total organic carbon

## Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

## Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow TOC	TPM/01A TPM/13	BS EN ISO 16911-1:2013 BS EN 12619 : 2013

### Summary Of Results

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**  
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives Fume Cupboard Extract Vent	Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
	Date	Start	End					
TOC	04/11/15	11:20	12:50	2.3	75	1.2	0.2	2.9

* at reference conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
---------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
 \*\* Analysis not required # - UKAS accredited only  
 ND Non detectable ## - Not Accredited  
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated.  
 Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



### Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**. The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives		Sampling Time			Emission Result mg/m <sup>3*</sup>	Authorised Limit mg/m <sup>3*</sup>	Uncertainty +/- mg/m <sup>3*</sup>	Detection Limit mg/m <sup>3*</sup>	Mass Emission g/h
		Date	Start	End					
Fume Cupboard Extract Vent									
TOC	Test 1	04/11/15	11:20	11:50	6.0	75	1.2	0.2	7.7
TOC	Test 2	04/11/15	11:50	12:20	0.3	75	1.2	0.2	0.4
TOC	Test 3	04/11/15	12:20	12:50	0.5	75	1.2	0.2	0.6

* at ref	Stack Gas Weight	0 °C	Without correction for moisture
Conditions	29.00 Kg/kmol	101.3 kPa	Oxygen No Correction %

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
\*\* Analysis not required # - UKAS accredited only  
ND Non detectable ## - Not Accredited  
s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



## Operating Information

The table below shows details of the operating information on each sampling date for: **Fume Cupboard Extract Vent**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
04/11/2015	Laboratory Fume Cupboard	Continuous	N/A	Methyl Ethyl Ketone, Acetone & Ethanol	None	Normal Operation

There are no CEM's available on this process.

## Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-  
The homogeneity test is not applicable to non-combustion processes.  
The homogeneity test is not applicable to duct areas less than 1m<sup>2</sup>.

All monitoring was performed in accordance with the relevant procedures.

The sampling location is a vertical duct.

Only one sample port was available on the vertical duct.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



**Part 2: Supporting Information**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Client</b>	Linx Printing Technologies Limited
<b>Site</b>	St Ives
<b>Plant</b>	Fume Cupboard Extract Vent
<b>Sampling Date</b>	4th November 2015
<b>Report Date</b>	2nd December 2015
<b>Job Number</b>	EM-2112
<b>Permit Number</b>	B18/14

<b>Report Prepared by:</b>	<b>Print</b>	<b>Harpreet Badwal</b>	
	<b>MCERTS No.</b>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	<b>Derek Myers</b>	
	<b>MCERTS No.</b>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832

 a CONCEPT LIFE SCIENCES company



1783

## APPENDIX 1

## **Emission Monitoring Procedures And Instrumentation**

### **Gas velocity and temperature**

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013. Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

### **Total organic carbon**

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013. Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

## Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Report authorised by:	Derek Myers	MM02 115	-	30/09/2017	31/05/2018	30/11/2018	30/11/2018	30/11/2018
Team leader:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Team leader:	Aidan Wrynn	MM08 921	-	31/05/2017	31/05/2017	31/11/2018	30/11/2017	30/06/2018

## Equipment References

Equipment	Reference Number
FID	AQ271
Heated Line	HL40
Heated Filter	Sintered
Stack Thermocouple	PTTS97
Timer / Stopwatch	ST41
Barometer	WS03
Pitot	PT129
Thermometer	TK28
Manometer	PI03

## APPENDIX 2

Date	04/11/2015
Time	09:32
Pitot Cp	1.01

Barometric pressure	101.0	kPa
Duct static pressure	0.06	kPa
Stack Area	0.031	m <sup>2</sup>

Stack Diameter (circular)	0.20	m
---------------------------	------	---

Traverse Point	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s
1	A						B					
2	A						B					
3	A						B					
4	A						B					
5	A	5.0	7.8	21	<15	11.5	B					
6	A	7.1	8.4	21	<15	11.8	B					
7	A	12.9	9.3	22	<15	12.5	B					
8	A	15.0	9.8	22	<15	12.8	B					
9	A						B					
10	A						B					
11	A						B					
12	A						B					

Average Pitot DP	8.80	mmH <sub>2</sub> O
Average Temperature	294.7	K
Average Velocity	12.1	m/s
Average volumetric flow rate	0.38	m <sup>3</sup> /s at stack conditions
Average volumetric flow rate	0.35	m <sup>3</sup> /s (wet STP)

**Sampling plane requirements Re: BS EN 13284-1:2001 5.2**

a	Angle of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	11.5
	Maximum local gas velocity	12.8
	Ratio of highest to lowest local gas velocity	1.12

**Preliminary Velocity Traverse Data**

Date 04/11/2015

From 11:20 to 11:50 30 minute mean

Volatile organic compounds	vppm, wet	3.76	mg/m <sup>3</sup> *	6.05
----------------------------	-----------	------	---------------------	------

From 11:50 to 12:20 30 minute mean

Volatile organic compounds	vppm, wet	0.21	mg/m <sup>3</sup> *	0.34
----------------------------	-----------	------	---------------------	------

From 12:20 to 12:50 30 minute mean

Volatile organic compounds	vppm, wet	0.30	mg/m <sup>3</sup> *	0.48
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m <sup>3</sup> *	0.16
----------------------------	------	------	---------------------	------

Reference Gas Details


Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VCK01959	-	± 2
Volatile organic compounds	vppm	74.7	VC59841	10	± 2

Zero And Span Gas Details

Species	units	Initial Time	08:54	Final Time	17:55
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	74.70	0.12	75.08

Exhaust Gas Continuous Analysis Data

Chart 1 - VOC Emissions Data, Fume Cupboard Extract Vent, 04/11/2015




## APPENDIX 3

## Diagram Of The Sampling Location

Diagram of sampling points across the cross section of the duct (not to scale).

Traverse length = 0.20 m

Point	% of D	Location cm
1	50.0	10.0



## General Calculations

### Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)  
 $\pi = 3.142$

### Pressure conversion:

1mmH2O = 0.00980665 kPa  
 1mmH2O = 9.80665 Pa  
 1 mar = 0.1 kPa

### Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m<sup>3</sup> of water vapour in m<sup>3</sup> of wet gas)  
 Vm(std) = Dry gas volume measured, corrected to standard conditions (m<sup>3</sup>)  
 mWC = Mass of water collected in the impingers (g)  
 Mw = Molecular weight of water, 18.01534 rounded to 18 (g/mol)  
 Vmol(std) = Molar volume of water at standard conditions = 0.0224 (m<sup>3</sup>/mol)

### Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

Vm(std) = Dry gas meter volume at standard conditions (m<sup>3</sup>)  
 yd = Gas meter calibration coefficient  
 (V2-V1) = Dry gas meter volume at actual conditions (m<sup>3</sup>)  
 Tm = Actual Temperature (K)  
 Tstd = Standard temperature (273 K)  
 pm = Absolute pressure at the gas meter (kPa)  
 pstd = Standard gas pressure (101.3 kPa)

### Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

### Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

## Flow Calculations

### Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

$\bar{v}$  = Average velocity (m/s)

$C$  = velocity calculation constant = 129

$T_s$  = Average stack temperature (K)

$M_s$  = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

$K$  = Pitot calibration coefficient

$p_e$  = Absolute gas pressure (kPa)

$\Delta p$  = Average pitot tube pressure differential (kPa)

### Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

$q_{va}$  = Average flow rate (m<sup>3</sup>/s)

$\bar{v}$  = Average velocity (m/s)

$A$  = Stack cross-sectional area (m<sup>2</sup>)

### Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$H_a$  = Moisture at actual conditions (%volume)

$H_m$  = Reference moisture (%volume)

### Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$T_a$  = Temperature at actual conditions (K)

$T_m$  = Reference Temperature (K)

$p_a$  = Absolute gas pressure at actual conditions (kPa)

$p_m$  = Reference pressure (kPa)

### Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$O_{2,m}$  = Actual oxygen concentration (%)

$O_{2,ref}$  = Reference oxygen concentration (%)

## Concentration Calculations

### Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

$c$  = Concentration  
 $m$  = Mass of substance  
 $V$  = Volume sampled

### Mass Emission

$$\text{Mass emission} = c \times q_m$$

$c$  = Concentration  
 $q$  = Volume flow rate

### Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

$c_m$  = Concentration at reference conditions  
 $c_a$  = Actual concentration  
 $O_{2, ref}$  = Reference oxygen (%)  
 $O_{2, a}$  = Actual Oxygen (%)

### Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

$c_{wet}$  = Concentration wet gas  
 $c_{dry}$  = Concentration dry gas  
 $H_a$  = Water vapour content (%vol)

### Conversion of parts per million (ppm) to mg/m<sup>3</sup>

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

### When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

## Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

### Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

$C_{ppm}$	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

### Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left( \frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$  is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:  
 $S_{r,0}$  is the standard uncertainty at zero level  
 $S_{r,s}$  is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:  
 $u(Corr_{loss})$  is the uncertainty due to losses in sample line  
 $u(Corr_{cal})$  is the uncertainty due to losses in sample line  
 $c_{j,loss}$  is the concentration of sample loss at span level  
 $U_{cal}$  is the expanded uncertainty of the calibration gas

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:  
 $c_j$  is the sensitivity coefficient of the influence quantity  
 $x_{j,min}$  is the minimum value of the influence quantity during monitoring  
 $x_{j,max}$  is the maximum value of the influence quantity during monitoring  
 $x_{j,adj}$  is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:  
 $c_j$  is the sensitivity coefficient of the interferent j  
 $Int_{j,test}$  is the concentration of the interferent j used to determine  $c_j$   
 $Int_{j,min}$  is the minimum value of the interferent j quantity during monitoring  
 $Int_{j,max}$  is the maximum value of the interferent j quantity during monitoring  
 $Int_{j,adj}$  is the concentration of the interferent j in the cal gas used to adjust the analyser  
 $S_{int,p}$  is the sum of interferences with positive impact  
 $S_{int,n}$  is the sum of interferences with negative impact

### Combined uncertainty

$$u(C, ppm) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2)  $U(C_m) = u(C_m) \times k$

### Uncertainty of NOx measurements

$$u(C_{NOx, conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:  
 $C_{NOx}$  is the concentration of NOx measured by the analyser  
 $R$  is the ratio of NO:Nox in the stack gas  
 $\eta$  is the NOx converter efficiency

### Combined uncertainty NOx measurements

$$u(C_{NOx, stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

### Uncertainty of mass concentration at oxygen reference concentration

$$u(C, O_2 ref) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left( \frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C, O_{2,ref})$	=	uncertainty associated with the mass concentration at O <sub>2</sub> ref. concentration	in	mg/m <sup>3</sup>
$C, O_{2,ref}$	=	mass concentration at O <sub>2</sub> reference concentration	in	mg/m <sup>3</sup>
$O_{2,meas}$	=	O <sub>2</sub> measured concentration	in	% volume
$u(O_{2,meas,dry})$	=	uncertainty associated to the measured O <sub>2</sub> concentration	in	% (relative to O <sub>2,meas</sub> )

## APPENDIX 4

**Uncertainty Estimate For The Measurement Of Total Organic Carbon**

Analyser Type/Model 

Sick Maihak
-------------

  
 Reference Oxygen % 

0
---

 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m <sup>3</sup>	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	3.8	0.2	0.3
Measured concentration	mg/m <sup>3</sup>	6.0	0.3	0.5
Concentration at O <sub>2</sub> ref. concentration	mg/m <sup>3</sup>	N/A	N/A	N/A

Calibration gas	ppm	74.7	74.7	74.7
Calibration gas	mg/m <sup>3</sup>	120.1	120.1	120.1
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m <sup>3</sup>	15.0	15.0	15.0

Correction of Lack of Fit

Lack of fit	% range	2.0	2.0	2.0
	u(Corr <sub>lof</sub> )	0.11	0.11	0.11

Corrections of Zero and Span Drift (\*All drift is calculated for ∴ the residual is assumed to be < 5% u(max) )

Zero Drift	% range	0.00	0.00	0.00
	u(Corr <sub>zdr</sub> )	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr <sub>spd</sub> )	0.00	0.00	0.00

Correction of Repeatability of Measurement

Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr <sub>rep</sub> )	0.00	0.00	0.00

Correction of adjustment

losses in the line	% range	0.27	0.27	0.27
	u(Corr <sub>loss</sub> )	0.01	0.00	0.00
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr <sub>cal</sub> )	0.04	0.00	0.00

Correction of Influence of Interferents

N <sub>2</sub> O	% range			
	u(Corr <sub>N2O</sub> )	0.00	0.00	0.00
CO <sub>2</sub>	% range			
	u(Corr <sub>CO2</sub> )	0.00	0.00	0.00
CH <sub>4</sub>	% range			
	u(Corr <sub>CH4</sub> )	0.00	0.00	0.00
Total of interferent influences $u(\Sigma Corr_{int}) = \max\{S_{int,p}^2 + S_{int,s}\}$	% range	2.50	2.50	2.50
	u(Σ Corr <sub>int</sub> )	0.16	0.16	0.16

Correction of Influence Quantities

Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr <sub>flow</sub> )	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr <sub>press</sub> )	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr <sub>tempo</sub> )	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr <sub>volt</sub> )	0.10	0.10	0.10

Maximum standard uncertainty	u(Corr <sub>max</sub> )	0.11	0.11	0.11
5% of maximum standard uncertainty	u(Corr <sub>5%</sub> )	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH <sub>4</sub> range	0	10	0	50	mg/m <sup>3</sup>
N <sub>2</sub> O range	0	0	0	20	mg/m <sup>3</sup>
CO <sub>2</sub> range	8	12	0	15	mg/m <sup>3</sup>
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m <sup>3</sup>

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty		Test 1	Test 2	Test 3
Combined uncertainty	ppm	0.37	0.36	0.36
Combined uncertainty	mg/m <sup>3</sup>	0.59	0.59	0.59
Combined uncertainty at oxygen reference	mg/m <sup>3</sup>	0.59	0.59	0.59

Expanded uncertainty expressed with a level of confidence of 95%, k=2

Overall uncertainty	ppm	0.7	0.7	0.7
Overall uncertainty	mg/m <sup>3</sup>	1.2	1.2	1.2
Overall uncertainty relative to measured value	%	19.5	344.7	246.0
Overall uncertainty relative to range	%	7.9	7.8	7.8
Overall uncertainty relative to ELV	%	1.0	1.0	1.0

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



**Client** Linx Printing Technologies Limited  
Linx House  
8 Stocks Bridge Way  
St Ives  
Cambridgeshire  
PE27 5JL

**Part 1: Executive Summary**

**Report for the Periodic Monitoring of Emissions to Air.**

<i>Site</i>	St Ives
<i>Plant</i>	Labs
<i>Sampling Date</i>	4th November 2015
<i>Report Date</i>	2nd December 2015
<i>Job Number</i>	EM-2112
<i>Permit Number</i>	B18/14

<b>Report Prepared by:</b>	<i>Print</i>	Harpreet Badwal	
	<i>MCERTS No.</i>	MM03 149	Level 2 TE: 1,2,3,4

<b>Report Approved by:</b>	<i>Sign</i>		
	<i>Print</i>	Derek Myers	
	<i>MCERTS No.</i>	MM02 115	Level 2 TE: 1,2,3,4

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832



1783

## Contents

Page 1	<b>Part 1: Executive Summary</b>
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results
Page 5	Summary Of Results, Exhaust Gases
Page 6	Operating Information
Page 6	Comments On Monitoring Procedures
Page 7	<b>Part 2: Supporting Information</b>
Page 8	<b>Appendix 1</b>
Page 9	Emission Monitoring Procedures and Instrumentation
Page 10	Sampling Personnel
Page 10	Equipment References
Page 11	<b>Appendix 2</b>
Page 12	Preliminary Velocity Traverse Data
Page 13	Exhaust Gases - Continuous Analysis Data
Page 14	Chart 1 - VOC Emissions Data
Page 15	<b>Appendix 3</b>
Page 16	Diagram of Sampling Location
Page 17	Generic Calculations
Page 18	Flow Calculations
Page 19	Concentration Calculation
Page 20	Uncertainty Estimate Calculations - Instrumental Techniques
Page 21	<b>Appendix 4</b>
Page 22	Uncertainty Estimates:- TOC

## Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
Labs	Total organic carbon

## Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

## Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow TOC	TPM/01A TPM/13	BS EN ISO 16911-1:2013 BS EN 12619 : 2013

### Summary Of Results

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**  
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives Labs	Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
	Date	Start	End					
TOC	04/11/15	13:05	14:35	3.8	75	1.2	0.2	12.8

* at reference conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
---------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
 \*\* Analysis not required # - UKAS accredited only  
 ND Non detectable ## - Not Accredited  
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated.  
 Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



## Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**. The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives Labs		Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
		Date	Start	End					
TOC	Test 1	04/11/15	13:05	13:35	2.9	75	1.2	0.2	9.9
TOC	Test 2	04/11/15	13:35	14:05	4.5	75	1.2	0.2	15.3
TOC	Test 3	04/11/15	14:05	14:35	3.9	75	1.2	0.2	13.2

* at ref Conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
\*\* Analysis not required # - UKAS accredited only  
ND Non detectable ## - Not Accredited  
s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



## Operating Information

The table below shows details of the operating information on each sampling date for: **Labs**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
04/11/2015	Laboratory	Continuous	N/A	Methyl Ethyl Ketone, Acetone & Ethanol	None	Normal Operation

There are no CEM's available on this process.

## Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-  
 The homogeneity test is not applicable to non-combustion processes.  
 The homogeneity test is not applicable to duct areas less than 1m<sup>2</sup>.

All monitoring was performed in accordance with the relevant procedures.

The sampling location is a vertical duct.

Only one sample port was available on the vertical duct.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



**Part 2: Supporting Information**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Client</b>	Linx Printing Technologies Limited
<b>Site</b>	St Ives
<b>Plant</b>	Labs
<b>Sampling Date</b>	4th November 2015
<b>Report Date</b>	2nd December 2015
<b>Job Number</b>	EM-2112
<b>Permit Number</b>	B18/14

<b>Report Prepared by:</b>	<b>Print</b>	<b>Harpreet Badwal</b>	
	<b>MCERTS No.</b>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	<b>Derek Myers</b>	
	<b>MCERTS No.</b>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
 Unit 19  
 Bordesley Green Trading Estate  
 Bordesley Green Road  
 Birmingham  
 B8 1BZ



Tel: 0845 676 9303  
 Company Registration No 03133832



## APPENDIX 1

## **Emission Monitoring Procedures And Instrumentation**

### **Gas velocity and temperature**

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013. Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

### **Total organic carbon**

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013. Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

## Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Report authorised by:	Derek Myers	MM02 115	-	30/09/2017	31/05/2018	30/11/2018	30/11/2018	30/11/2018
Team leader:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Team leader:	Aidan Wrynnne	MM08 921	-	31/05/2017	31/05/2017	31/11/2018	30/11/2017	30/06/2018

## Equipment References

Equipment	Reference Number
FID	AQ271
Heated Line	HL40
Heated Filter	Sintered
Stack Thermocouple	PTTS97
Timer / Stopwatch	ST41
Barometer	WS03
Pitot	PT129
Thermometer	TK28
Manometer	PI03

## APPENDIX 2

Date	04/11/2015
Time	10:15
Pitot Cp	1.01

Barometric pressure	101.0	kPa
Duct static pressure	0.08	kPa
Stack Area	0.071	m <sup>2</sup>

Stack Diameter (circular)	0.30	m
---------------------------	------	---

Traverse Point	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s
1	A						B					
2	A						B					
3	A	5.0	18.0	22	<15	17.4	B					
4	A	5.3	15.1	22	<15	15.9	B					
5	A	7.5	10.8	22	<15	13.5	B					
6	A	10.7	10.0	22	<15	12.9	B					
7	A	19.3	16.1	22	<15	16.4	B					
8	A	22.5	12.4	22	<15	14.4	B					
9	A	24.7	9.6	22	<15	12.7	B					
10	A	25.0	9.0	22	<15	12.3	B					
11	A						B					
12	A						B					

Average Pitot DP	12.43	mmH <sub>2</sub> O
Average Temperature	295.2	K
Average Velocity	14.4	m/s
Average volumetric flow rate	1.02	m <sup>3</sup> /s at stack conditions
Average volumetric flow rate	0.94	m <sup>3</sup> /s (wet STP)

**Sampling plane requirements Re: BS EN 13284-1:2001 5.2**

a	Angle of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	12.3
	Maximum local gas velocity	17.4
	Ratio of highest to lowest local gas velocity	1.42

**Preliminary Velocity Traverse Data**

Date 04/11/2015

From 13:05 to 13:35 30 minute mean

Volatile organic compounds	vppm, wet	1.82	mg/m <sup>3</sup> *	2.93
----------------------------	-----------	------	---------------------	------

From 13:35 to 14:05 30 minute mean

Volatile organic compounds	vppm, wet	2.80	mg/m <sup>3</sup> *	4.51
----------------------------	-----------	------	---------------------	------

From 14:05 to 14:35 30 minute mean

Volatile organic compounds	vppm, wet	2.42	mg/m <sup>3</sup> *	3.88
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m <sup>3</sup> *	0.16
----------------------------	------	------	---------------------	------

Reference Gas Details


Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VCK01959	-	± 2
Volatile organic compounds	vppm	74.7	VC59841	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	08:54	Final Time	17:55
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	74.70	0.12	75.08

**Exhaust Gas Continuous Analysis Data**

Chart 1 - VOC Emissions Data - Labs, 04/11/2015




## APPENDIX 3

## Diagram Of The Sampling Location

Diagram of sampling points across the cross section of the duct (not to scale).

Traverse length = 0.30 m

Point	% of D	Location cm
1	50.0	15.0



## General Calculations

### Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

$\pi$  = 3.142

### Pressure conversion:

1mmH<sub>2</sub>O = 0.00980665 kPa

1mmH<sub>2</sub>O = 9.80665 Pa

1 mar = 0.1 kPa

### Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m<sup>3</sup> of water vapour in m<sup>3</sup> of wet gas)

V<sub>m(std)</sub> = Dry gas volume measured, corrected to standard conditions (m<sup>3</sup>)

m<sub>WC</sub> = Mass of water collected in the impingers (g)

M<sub>w</sub> = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

V<sub>mol(std)</sub> = Molar volume of water at standard conditions = 0.0224 (m<sup>3</sup>/mol)

### Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

V<sub>m(std)</sub> = Dry gas meter volume at standard conditions (m<sup>3</sup>)

y<sub>d</sub> = Gas meter calibration coefficient

(V<sub>2</sub>-V<sub>1</sub>) = Dry gas meter volume at actual conditions (m<sup>3</sup>)

T<sub>m</sub> = Actual Temperature (K)

T<sub>std</sub> = Standard temperature (273 K)

p<sub>m</sub> = Absolute pressure at the gas meter (kPa)

p<sub>std</sub> = Standard gas pressure (101.3 kPa)

### Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

### Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

## Flow Calculations

### Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

$\bar{v}$  = Average velocity (m/s)

$C$  = velocity calculation constant = 129

$T_s$  = Average stack temperature (K)

$M_s$  = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

$K$  = Pitot calibration coefficient

$p_e$  = Absolute gas pressure (kPa)

$\Delta p$  = Average pitot tube pressure differential (kPa)

### Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

$q_{va}$  = Average flow rate (m<sup>3</sup>/s)

$\bar{v}$  = Average velocity (m/s)

$A$  = Stack cross-sectional area (m<sup>2</sup>)

### Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$H_a$  = Moisture at actual conditions (%volume)

$H_m$  = Reference moisture (%volume)

### Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$T_a$  = Temperature at actual conditions (K)

$T_m$  = Reference Temperature (K)

$p_a$  = Absolute gas pressure at actual conditions (kPa)

$p_m$  = Reference pressure (kPa)

### Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$O_{2,m}$  = Actual oxygen concentration (%)

$O_{2,ref}$  = Reference oxygen concentration (%)

## Concentration Calculations

### Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

$c$  = Concentration  
 $m$  = Mass of substance  
 $V$  = Volume sampled

### Mass Emission

$$\text{Mass emission} = c \times q_m$$

$c$  = Concentration  
 $q$  = Volume flow rate

### Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

$c_m$  = Concentration at reference conditions  
 $c_a$  = Actual concentration  
 $O_{2, ref}$  = Reference oxygen (%)  
 $O_{2, a}$  = Actual Oxygen (%)

### Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

$c_{wet}$  = Concentration wet gas  
 $c_{dry}$  = Concentration dry gas  
 $H_a$  = Water vapour content (%vol)

### Conversion of parts per million (ppm) to mg/m<sup>3</sup>

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

### When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

## Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

### Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

$C_{ppm}$	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

### Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left( \frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$  is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:  
 $S_{r,0}$  is the standard uncertainty at zero level  
 $S_{r,s}$  is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:  
 $u(Corr_{loss})$  is the uncertainty due to losses in sample line  
 $u(Corr_{cal})$  is the uncertainty due to losses in sample line  
 $c_{j,loss}$  is the concentration of sample loss at span level  
 $U_{cal}$  is the expanded uncertainty of the calibration gas

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:  
 $c_j$  is the sensitivity coefficient of the influence quantity  
 $x_{j,min}$  is the minimum value of the influence quantity during monitoring  
 $x_{j,max}$  is the maximum value of the influence quantity during monitoring  
 $x_{j,adj}$  is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:  
 $c_j$  is the sensitivity coefficient of the interferent j  
 $Int_{j,test}$  is the concentration of the interferent j used to determine  $c_j$   
 $Int_{j,min}$  is the minimum value of the interferent j quantity during monitoring  
 $Int_{j,max}$  is the maximum value of the interferent j quantity during monitoring  
 $Int_{j,adj}$  is the concentration of the interferent j in the cal gas used to adjust the analyser  
 $S_{int,p}$  is the sum of interferences with positive impact  
 $S_{int,n}$  is the sum of interferences with negative impact

### Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,dr}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2)  $U(C_m) = u(C_m) \times k$

### Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:  
 $C_{NOx}$  is the concentration of NOx measured by the analyser  
 $R$  is the ratio of NO:Nox in the stack gas  
 $\eta$  is the NOx converter efficiency

### Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,dr}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

### Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,dr}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left( \frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O <sub>2</sub> ref. concentration	in	mg/m <sup>3</sup>
$C_{O_2,ref}$	=	mass concentration at O <sub>2</sub> reference concentration	in	mg/m <sup>3</sup>
$O_{2,meas}$	=	O <sub>2</sub> measured concentration	in	% volume
$u(O_{2,meas,dry})$	=	uncertainty associated to the measured O <sub>2</sub> concentration	in	% (relative to O <sub>2,meas</sub> )

## APPENDIX 4

**Uncertainty Estimate For The Measurement Of Total Organic Carbon**

Analyser Type/Model 

Sick Maihak
-------------

  
 Reference Oxygen % 

0
---

 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m <sup>3</sup>	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	1.8	2.8	2.4
Measured concentration	mg/m <sup>3</sup>	2.9	4.5	3.9
Concentration at O <sub>2</sub> ref. concentration	mg/m <sup>3</sup>	N/A	N/A	N/A

Calibration gas	ppm	74.7	74.7	74.7
Calibration gas	mg/m <sup>3</sup>	120.1	120.1	120.1
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m <sup>3</sup>	15.0	15.0	15.0

Correction of Lack of Fit

Lack of fit	% range	2.0	2.0	2.0
	u(Corr <sub>lof</sub> )	0.11	0.11	0.11

Corrections of Zero and Span Drift (\*All drift is calculated for ∴ the residual is assumed to be < 5% u(max) )

Zero Drift	% range	0.00	0.00	0.00
	u(Corr <sub>zdrift</sub> )	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr <sub>spdrift</sub> )	0.00	0.00	0.00

Correction of Repeatability of Measurement

Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr <sub>rep</sub> )	0.00	0.00	0.00

Correction of adjustment

losses in the line	% range	0.27	0.27	0.27
	u(Corr <sub>loss</sub> )	0.00	0.00	0.00
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr <sub>cal</sub> )	0.02	0.03	0.02

Correction of Influence of Interferents

N <sub>2</sub> O	% range			
	u(Corr <sub>N2O</sub> )	0.00	0.00	0.00
CO <sub>2</sub>	% range			
	u(Corr <sub>CO2</sub> )	0.00	0.00	0.00
CH <sub>4</sub>	% range			
	u(Corr <sub>CH4</sub> )	0.00	0.00	0.00
Total of interferent influences u(ΣCorr <sub>int</sub> ) = max{Σ <sub>int, p</sub> ; Σ <sub>int, s</sub> }	% range	2.50	2.50	2.50
	u(ΣCorr <sub>int</sub> )	0.16	0.16	0.16

Correction of Influence Quantities

Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr <sub>flow</sub> )	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr <sub>press</sub> )	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr <sub>tempo</sub> )	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr <sub>volt</sub> )	0.10	0.10	0.10
Maximum standard uncertainty	u(Corr <sub>max</sub> )	0.11	0.11	0.11
5% of maximum standard uncertainty	u(Corr <sub>5%</sub> )	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH <sub>4</sub> range	0	10	0	50	mg/m <sup>3</sup>
N <sub>2</sub> O range	0	0	0	20	mg/m <sup>3</sup>
CO <sub>2</sub> range	8	12	0	15	mg/m <sup>3</sup>
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m <sup>3</sup>

Influence Quantity Variations

	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty

		Test 1	Test 2	Test 3
Combined uncertainty	ppm	0.37	0.37	0.37
Combined uncertainty	mg/m <sup>3</sup>	0.59	0.59	0.59
Combined uncertainty at oxygen reference	mg/m <sup>3</sup>	0.59	0.59	0.59

Expanded uncertainty expressed with a level of confidence of 95%, k=2

Overall uncertainty	ppm	0.7	0.7	0.7
Overall uncertainty	mg/m <sup>3</sup>	1.2	1.2	1.2
Overall uncertainty relative to measured value	%	40.1	26.1	30.3
Overall uncertainty relative to range	%	7.8	7.8	7.8
Overall uncertainty relative to ELV	%	1.0	1.0	1.0

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



**Client** Linx Printing Technologies Limited  
Linx House  
8 Stocks Bridge Way  
St Ives  
Cambridgeshire  
PE27 5JL

**Part 1: Executive Summary**

**Report for the Periodic Monitoring of Emissions to Air.**

<i>Site</i>	<b>St Ives</b>
<i>Plant</i>	<b>RASTA</b>
<i>Sampling Date</i>	<b>4th November 2015</b>
<i>Report Date</i>	<b>7th December 2015</b>
<i>Job Number</i>	<b>EM-2112</b>
<i>Permit Number</i>	<b>B18/14</b>

<b>Report Prepared by:</b>	<i>Print</i>	<b>Harpreet Badwal</b>	
	<i>MCERTS No.</i>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<i>Sign</i>		
	<i>Print</i>	<b>Derek Myers</b>	
	<i>MCERTS No.</i>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832



## Contents

Page 1	<b>Part 1: Executive Summary</b>
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results
Page 5	Summary Of Results, Exhaust Gases
Page 6	Operating Information
Page 6	Comments On Monitoring Procedures
Page 7	<b>Part 2: Supporting Information</b>
Page 8	<b>Appendix 1</b>
Page 9	Emission Monitoring Procedures and Instrumentation
Page 10	Sampling Personnel
Page 10	Equipment References
Page 11	<b>Appendix 2</b>
Page 12	Preliminary Velocity Traverse Data
Page 13	Exhaust Gases - Continuous Analysis Data
Page 14	Chart 1 - VOC Emissions Data
Page 15	<b>Appendix 3</b>
Page 16	Diagram of Sampling Location
Page 17	Generic Calculations
Page 18	Flow Calculations
Page 19	Concentration Calculation
Page 20	Uncertainty Estimate Calculations - Instrumental Techniques
Page 21	<b>Appendix 4</b>
Page 22	Uncertainty Estimates:- TOC

## Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
RASTA	Total organic carbon

## Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

## Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow TOC	TPM/01A TPM/13	BS EN ISO 16911-1:2013 BS EN 12619 : 2013

### Summary Of Results

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**  
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives RASTA	Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
	Date	Start	End					
TOC	04/11/15	14:40	16:10	2.9	75	1.2	0.2	1.2

* at reference conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
---------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
 \*\* Analysis not required # - UKAS accredited only  
 ND Non detectable ## - Not Accredited  
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated.  
 Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



### Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**. The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives RASTA		Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
		Date	Start	End					
TOC	Test 1	04/11/15	14:40	15:10	2.9	75	1.2	0.2	1.2
TOC	Test 2	04/11/15	15:10	15:40	3.0	75	1.2	0.2	1.2
TOC	Test 3	04/11/15	15:40	16:10	2.9	75	1.2	0.2	1.2

* at ref Conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
\*\* Analysis not required # - UKAS accredited only  
ND Non detectable ## - Not Accredited  
s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



## Operating Information

The table below shows details of the operating information on each sampling date for: **RASTA**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
04/11/2015	Ink Printer Test Rig RASTA	Batch	N/A	Methyl Ethyl Ketone	None	200 ml/day of solvent

There are no CEM's available on this process.

## Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-  
The homogeneity test is not applicable to non-combustion processes.  
The homogeneity test is not applicable to duct areas less than 1m<sup>2</sup>.

All monitoring was performed in accordance with the relevant procedures.

The sampling location is a horizontal duct.

Only one sample port was available on the horizontal duct.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



**Part 2: Supporting Information**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Client</b>	Linx Printing Technologies Limited
<b>Site</b>	St Ives
<b>Plant</b>	RASTA
<b>Sampling Date</b>	4th November 2015
<b>Report Date</b>	7th December 2015
<b>Job Number</b>	EM-2112
<b>Permit Number</b>	B18/14

<b>Report Prepared by:</b>	<b>Print</b>	<b>Harpreet Badwal</b>	
	<b>MCERTS No.</b>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	<b>Derek Myers</b>	
	<b>MCERTS No.</b>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832

 a CONCEPT LIFE SCIENCES company



## APPENDIX 1

## **Emission Monitoring Procedures And Instrumentation**

### **Gas velocity and temperature**

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013. Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

### **Total organic carbon**

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013. Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

### Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Report authorised by:	Derek Myers	MM02 115	-	30/09/2017	31/05/2018	30/11/2018	30/11/2018	30/11/2018
Team leader:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Team leader:	Aidan Wrynnne	MM08 921	-	31/05/2017	31/05/2017	31/11/2018	30/11/2017	30/06/2018

### Equipment References

Equipment	Reference Number
FID	AQ271
Heated Line	HL40
Heated Filter	Sintered
Stack Thermocouple	PTTS97
Timer / Stopwatch	ST41
Barometer	WS03
Pitot	PT129
Thermometer	TK28
Manometer	PI03

## APPENDIX 2

Date	04/11/2015
Time	13:40
Pitot Cp	1.01

Barometric pressure	101.0	kPa
Duct static pressure	-0.70	kPa
Stack Area	0.013	m <sup>2</sup>

Stack Diameter (circular)	0.13	m
---------------------------	------	---

Traverse Point	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s
1	A						B					
2	A						B					
3	A						B					
4	A						B					
5	A						B					
6	A	5.0	4.8	17	<15	8.9	B					
7	A	8.0	5.0	17	<15	9.1	B					
8	A						B					
9	A						B					
10	A						B					
11	A						B					
12	A						B					

Average Pitot DP	4.89	mmH <sub>2</sub> O
Average Temperature	290.2	K
Average Velocity	9.0	m/s
Average volumetric flow rate	0.12	m <sup>3</sup> /s at stack conditions
Average volumetric flow rate	0.11	m <sup>3</sup> /s (wet STP)

**Sampling plane requirements Re: BS EN 13284-1:2001 5.2**

a	Angle of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	8.9
	Maximum local gas velocity	9.1
	Ratio of highest to lowest local gas velocity	1.02

**Preliminary Velocity Traverse Data**

Date 04/11/2015

From 14:40 to 15:10 30 minute mean

Volatile organic compounds	vppm, wet	1.83	mg/m <sup>3</sup> *	2.94
----------------------------	-----------	------	---------------------	------

From 15:10 to 15:40 30 minute mean

Volatile organic compounds	vppm, wet	1.87	mg/m <sup>3</sup> *	3.01
----------------------------	-----------	------	---------------------	------

From 15:40 to 16:10 30 minute mean

Volatile organic compounds	vppm, wet	1.79	mg/m <sup>3</sup> *	2.88
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m <sup>3</sup> *	0.16
----------------------------	------	------	---------------------	------

Reference Gas Details


Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VCK01959	-	± 2
Volatile organic compounds	vppm	74.7	VC59841	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	08:54	Final Time	17:55
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	74.70	0.12	75.08

Exhaust Gas Continuous Analysis Data

Chart 1 - VOC Emissions Data - RASTA, 04/11/2015




## APPENDIX 3

## Diagram Of The Sampling Location

Diagram of sampling points across the cross section of the duct (not to scale).

Traverse length = 0.13 m

Point	% of D	Location cm
1	50.0	6.5



## General Calculations

### Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

$\pi$  = 3.142

### Pressure conversion:

1mmH<sub>2</sub>O = 0.00980665 kPa

1mmH<sub>2</sub>O = 9.80665 Pa

1 mar = 0.1 kPa

### Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m<sup>3</sup> of water vapour in m<sup>3</sup> of wet gas)

V<sub>m(std)</sub> = Dry gas volume measured, corrected to standard conditions (m<sup>3</sup>)

m<sub>WC</sub> = Mass of water collected in the impingers (g)

M<sub>w</sub> = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

V<sub>mol(std)</sub> = Molar volume of water at standard conditions = 0.0224 (m<sup>3</sup>/mol)

### Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

V<sub>m(std)</sub> = Dry gas meter volume at standard conditions (m<sup>3</sup>)

y<sub>d</sub> = Gas meter calibration coefficient

(V<sub>2</sub>-V<sub>1</sub>) = Dry gas meter volume at actual conditions (m<sup>3</sup>)

T<sub>m</sub> = Actual Temperature (K)

T<sub>std</sub> = Standard temperature (273 K)

p<sub>m</sub> = Absolute pressure at the gas meter (kPa)

p<sub>std</sub> = Standard gas pressure (101.3 kPa)

### Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

### Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

## Flow Calculations

### Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{P_e M_s}}$$

$\bar{v}$  = Average velocity (m/s)

$C$  = velocity calculation constant = 129

$T_s$  = Average stack temperature (K)

$M_s$  = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

$K$  = Pitot calibration coefficient

$P_e$  = Absolute gas pressure (kPa)

$\Delta p$  = Average pitot tube pressure differential (kPa)

### Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

$q_{va}$  = Average flow rate (m<sup>3</sup>/s)

$\bar{v}$  = Average velocity (m/s)

$A$  = Stack cross-sectional area (m<sup>2</sup>)

### Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$H_a$  = Moisture at actual conditions (%volume)

$H_m$  = Reference moisture (%volume)

### Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m P_a)}{(T_a P_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$T_a$  = Temperature at actual conditions (K)

$T_m$  = Reference Temperature (K)

$p_a$  = Absolute gas pressure at actual conditions (kPa)

$p_m$  = Reference pressure (kPa)

### Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$O_{2,m}$  = Actual oxygen concentration (%)

$O_{2,ref}$  = Reference oxygen concentration (%)

## Concentration Calculations

### Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

$c$  = Concentration  
 $m$  = Mass of substance  
 $V$  = Volume sampled

### Mass Emission

$$\text{Mass emission} = c \times q_m$$

$c$  = Concentration  
 $q$  = Volume flow rate

### Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

$c_m$  = Concentration at reference conditions  
 $c_a$  = Actual concentration  
 $O_{2, ref}$  = Reference oxygen (%)  
 $O_{2, a}$  = Actual Oxygen (%)

### Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

$c_{wet}$  = Concentration wet gas  
 $c_{dry}$  = Concentration dry gas  
 $H_a$  = Water vapour content (%vol)

### Conversion of parts per million (ppm) to mg/m<sup>3</sup>

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

### When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

## Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

### Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

$C_{ppm}$	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

### Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left( \frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$  is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:  
 $S_{r,0}$  is the standard uncertainty at zero level  
 $S_{r,s}$  is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:  
 $u(Corr_{loss})$  is the uncertainty due to losses in sample line  
 $u(Corr_{cal})$  is the uncertainty due to losses in sample line  
 $c_{j,loss}$  is the concentration of sample loss at span level  
 $U_{cal}$  is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:  
 $c_j$  is the sensitivity coefficient of the influence quantity  
 $x_{j,min}$  is the minimum value of the influence quantity during monitoring  
 $x_{j,max}$  is the maximum value of the influence quantity during monitoring  
 $x_{j,adj}$  is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:  
 $c_j$  is the sensitivity coefficient of the interferent j  
 $Int_{j,test}$  is the concentration of the interferent j used to determine  $c_j$   
 $Int_{j,min}$  is the minimum value of the interferent j quantity during monitoring  
 $Int_{j,max}$  is the maximum value of the interferent j quantity during monitoring  
 $Int_{j,adj}$  is the concentration of the interferent j in the cal gas used to adjust the analyser  
 $S_{int,p}$  is the sum of interferences with positive impact  
 $S_{int,n}$  is the sum of interferences with negative impact

### Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,dr}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2)  $U(C_m) = u(C_m) \times k$

### Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:  
 $C_{NOx}$  is the concentration of NOx measured by the analyser  
 $R$  is the ratio of NO:Nox in the stack gas  
 $\eta$  is the NOx converter efficiency

### Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,dr}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

### Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,dr}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left( \frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O <sub>2</sub> ref. concentration	in	mg/m <sup>3</sup>
$C_{O_2,ref}$	=	mass concentration at O <sub>2</sub> reference concentration	in	mg/m <sup>3</sup>
$O_{2,meas}$	=	O <sub>2</sub> measured concentration	in	% volume
$u(O_{2,meas,dry})$	=	uncertainty associated to the measured O <sub>2</sub> concentration	in	%(relative to O <sub>2,meas</sub> )

## APPENDIX 4

**Uncertainty Estimate For The Measurement Of Total Organic Carbon**

Analyser Type/Model 

Sick Maihak
-------------

  
 Reference Oxygen % 

0
---

 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m <sup>3</sup>	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	1.8	1.9	1.8
Measured concentration	mg/m <sup>3</sup>	2.9	3.0	2.9
Concentration at O <sub>2</sub> ref. concentration	mg/m <sup>3</sup>	N/A	N/A	N/A

Calibration gas	ppm	74.7	74.7	74.7
Calibration gas	mg/m <sup>3</sup>	120.1	120.1	120.1
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m <sup>3</sup>	15.0	15.0	15.0

Correction of Lack of Fit

Lack of fit	% range	2.0	2.0	2.0
	u(Corr <sub>lof</sub> )	0.11	0.11	0.11

Corrections of Zero and Span Drift (\*All drift is calculated for ∴ the residual is assumed to be < 5% u(max) )

Zero Drift	% range	0.00	0.00	0.00
	u(Corr <sub>zdrift</sub> )	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr <sub>sdrift</sub> )	0.00	0.00	0.00

Correction of Repeatability of Measurement

Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr <sub>rep</sub> )	0.00	0.00	0.00

Correction of adjustment

losses in the line	% range	0.27	0.27	0.27
	u(Corr <sub>loss</sub> )	0.00	0.00	0.00
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr <sub>cal</sub> )	0.02	0.02	0.02

Correction of Influence of Interferents

N <sub>2</sub> O	% range			
	u(Corr <sub>N2O</sub> )	0.00	0.00	0.00
CO <sub>2</sub>	% range			
	u(Corr <sub>CO2</sub> )	0.00	0.00	0.00
CH <sub>4</sub>	% range			
	u(Corr <sub>CH4</sub> )	0.00	0.00	0.00
Total of interferent influences u(ΣCorr <sub>int</sub> ) = max{Σ <sub>int, p</sub> u <sub>int, p</sub> }	% range	2.50	2.50	2.50
	u(ΣCorr <sub>int</sub> )	0.16	0.16	0.16

Correction of Influence Quantities

Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr <sub>flow</sub> )	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr <sub>press</sub> )	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr <sub>tempo</sub> )	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr <sub>volt</sub> )	0.10	0.10	0.10

Maximum standard uncertainty	u(Corr <sub>max</sub> )	0.11	0.11	0.11
5% of maximum standard uncertainty	u(Corr <sub>5%</sub> )	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH <sub>4</sub> range	0	10	0	50	mg/m <sup>3</sup>
N <sub>2</sub> O range	0	0	0	20	mg/m <sup>3</sup>
CO <sub>2</sub> range	8	12	0	15	mg/m <sup>3</sup>
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m <sup>3</sup>

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty		Test 1	Test 2	Test 3
Combined uncertainty	ppm	0.37	0.37	0.37
Combined uncertainty	mg/m <sup>3</sup>	0.59	0.59	0.59
Combined uncertainty at oxygen reference	mg/m <sup>3</sup>	0.59	0.59	0.59

Expanded uncertainty expressed with a level of confidence of 95%, k=2

Overall uncertainty	ppm	0.7	0.7	0.7
Overall uncertainty	mg/m <sup>3</sup>	1.2	1.2	1.2
Overall uncertainty relative to measured value	%	39.9	39.0	40.7
Overall uncertainty relative to range	%	7.8	7.8	7.8
Overall uncertainty relative to ELV	%	1.0	1.0	1.0

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



**Client** Linx Printing Technologies Limited  
Linx House  
8 Stocks Bridge Way  
St Ives  
Cambridgeshire  
PE27 5JL

**Part 1: Executive Summary**

**Report for the Periodic Monitoring of Emissions to Air.**

<i>Site</i>	<b>St Ives</b>
<i>Plant</i>	<b>Environmental Chamber Room 1</b>
<i>Sampling Date</i>	<b>4th November 2015</b>
<i>Report Date</i>	<b>2nd December 2015</b>
<i>Job Number</i>	<b>EM-2112</b>
<i>Permit Number</i>	<b>B18/14</b>

<b>Report Prepared by:</b>	<i>Print</i>	<b>Harpreet Badwal</b>	
	<i>MCERTS No.</i>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<i>Sign</i>		
	<i>Print</i>	<b>Derek Myers</b>	
	<i>MCERTS No.</i>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832



## Contents

Page 1	<b>Part 1: Executive Summary</b>
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results
Page 5	Summary Of Results, Exhaust Gases
Page 6	Operating Information
Page 6	Comments On Monitoring Procedures
Page 7	<b>Part 2: Supporting Information</b>
Page 8	<b>Appendix 1</b>
Page 9	Emission Monitoring Procedures and Instrumentation
Page 10	Sampling Personnel
Page 10	Equipment References
Page 11	<b>Appendix 2</b>
Page 12	Preliminary Velocity Traverse Data
Page 13	Exhaust Gases - Continuous Analysis Data
Page 14	Chart 1 - VOC Emissions Data
Page 15	<b>Appendix 3</b>
Page 16	Diagram of Sampling Location
Page 17	Generic Calculations
Page 18	Flow Calculations
Page 19	Concentration Calculation
Page 20	Uncertainty Estimate Calculations - Instrumental Techniques
Page 21	<b>Appendix 4</b>
Page 22	Uncertainty Estimates:- TOC

## Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
Environmental Chamber Room 1	Total organic carbon

## Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

## Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow TOC	TPM/01A TPM/13	BS EN ISO 16911-1:2013 BS EN 12619 : 2013

## Summary Of Results

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**  
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives Environmental Chamber Room 1	Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
	Date	Start	End					
TOC	04/11/15	16:15	17:45	7.6	75	1.2	0.2	3.2

* at reference conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
---------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
 \*\* Analysis not required # - UKAS accredited only  
 ND Non detectable ## - Not Accredited  
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated.  
 Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



### Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**. The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives		Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
		Date	Start	End					
Environmental Chamber Room 1									
TOC	Test 1	04/11/15	16:15	16:45	8.3	75	1.2	0.2	3.5
TOC	Test 2	04/11/15	16:45	17:15	11.1	75	1.2	0.2	4.7
TOC	Test 3	04/11/15	17:15	17:45	3.4	75	1.2	0.2	1.5

* at ref Conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
 \*\* Analysis not required # - UKAS accredited only  
 ND Non detectable ## - Not Accredited  
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



## Operating Information

The table below shows details of the operating information on each sampling date for: **Environmental Chamber Room 1**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
04/11/2015	Environmental Test Chamber	Continuous	N/A	Methyl Ethyl Ketone	None	1 printer tested at 5°C

There are no CEM's available on this process.

## Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-  
The homogeneity test is not applicable to non-combustion processes.  
The homogeneity test is not applicable to duct areas less than 1m<sup>2</sup>.

All monitoring was performed in accordance with the relevant procedures.

The sampling location is a vertical duct.

Only one sample port was available on the vertical duct.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



**Part 2: Supporting Information**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Client</b>	Linx Printing Technologies Limited
<b>Site</b>	St Ives
<b>Plant</b>	Environmental Chamber Room 1
<b>Sampling Date</b>	4th November 2015
<b>Report Date</b>	2nd December 2015
<b>Job Number</b>	EM-2112
<b>Permit Number</b>	B18/14

<b>Report Prepared by:</b>	<b>Print</b>	<b>Harpreet Badwal</b>	
	<b>MCERTS No.</b>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	<b>Derek Myers</b>	
	<b>MCERTS No.</b>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832



## APPENDIX 1

## **Emission Monitoring Procedures And Instrumentation**

### **Gas velocity and temperature**

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013. Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

### **Total organic carbon**

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013. Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

### Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Report authorised by:	Derek Myers	MM02 115	-	30/09/2017	31/05/2018	30/11/2018	30/11/2018	30/11/2018
Team leader:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Team leader:	Aidan Wrynnne	MM08 921	-	31/05/2017	31/05/2017	31/11/2018	30/11/2017	30/06/2018

### Equipment References

Equipment	Reference Number
FID	AQ271
Heated Line	HL40
Heated Filter	Sintered
Stack Thermocouple	PTTS97
Timer / Stopwatch	ST41
Barometer	WS03
Pitot	PT129
Thermometer	TK28
Manometer	PI03

## APPENDIX 2

Date	04/11/2015
Time	12:02
Pitot Cp	1.01

Barometric pressure	101.0	kPa
Duct static pressure	0.01	kPa
Stack Area	0.031	m <sup>2</sup>

Stack Diameter (circular)	0.20	m
---------------------------	------	---

Traverse Point	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s
1	A						B					
2	A						B					
3	A						B					
4	A						B					
5	A	5.0	1.0	7	<15	4.0	B					
6	A	7.1	0.7	7	<15	3.4	B					
7	A	12.9	0.8	7	<15	3.6	B					
8	A	15.0	1.2	7	<15	4.4	B					
9	A						B					
10	A						B					
11	A						B					
12	A						B					

Average Pitot DP	0.93	mmH <sub>2</sub> O
Average Temperature	280.2	K
Average Velocity	3.9	m/s
Average volumetric flow rate	0.12	m <sup>3</sup> /s at stack conditions
Average volumetric flow rate	0.12	m <sup>3</sup> /s (wet STP)

**Sampling plane requirements Re: BS EN 13284-1:2001 5.2**

a	Angle of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	3.4
	Maximum local gas velocity	4.4
	Ratio of highest to lowest local gas velocity	1.31

**Preliminary Velocity Traverse Data**

Date 04/11/2015

From 16:15 to 16:45 30 minute mean

Volatile organic compounds	vppm, wet	5.14	mg/m <sup>3</sup> *	8.26
----------------------------	-----------	------	---------------------	------

From 16:45 to 17:15 30 minute mean

Volatile organic compounds	vppm, wet	6.89	mg/m <sup>3</sup> *	11.07
----------------------------	-----------	------	---------------------	-------

From 17:15 to 17:45 30 minute mean

Volatile organic compounds	vppm, wet	2.14	mg/m <sup>3</sup> *	3.45
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m <sup>3</sup> *	0.16
----------------------------	------	------	---------------------	------

Reference Gas Details


Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VCK01959	-	± 2
Volatile organic compounds	vppm	74.7	VC59841	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	08:54	Final Time	17:55
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	74.70	0.12	75.08

**Exhaust Gas Continuous Analysis Data**

Chart 1 - VOC Emissions Data - Environmental Chamber Room 1, 04/11/2015




## APPENDIX 3

## Diagram Of The Sampling Location

Diagram of sampling points across the cross section of the duct (not to scale).

Traverse length = 0.20 m

Point	% of D	Location cm
1	50.0	10.0



## General Calculations

### Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)  
 $\pi = 3.142$

### Pressure conversion:

1mmH2O = 0.00980665 kPa  
 1mmH2O = 9.80665 Pa  
 1 mar = 0.1 kPa

### Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m<sup>3</sup> of water vapour in m<sup>3</sup> of wet gas)  
 Vm(std) = Dry gas volume measured, corrected to standard conditions (m<sup>3</sup>)  
 mWC = Mass of water collected in the impingers (g)  
 Mw = Molecular weight of water, 18.01534 rounded to 18 (g/mol)  
 Vmol(std) = Molar volume of water at standard conditions = 0.0224 (m<sup>3</sup>/mol)

### Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

Vm(std) = Dry gas meter volume at standard conditions (m<sup>3</sup>)  
 yd = Gas meter calibration coefficient  
 (V2-V1) = Dry gas meter volume at actual conditions (m<sup>3</sup>)  
 Tm = Actual Temperature (K)  
 Tstd = Standard temperature (273 K)  
 pm = Absolute pressure at the gas meter (kPa)  
 pstd = Standard gas pressure (101.3 kPa)

### Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

### Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

## Flow Calculations

### Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

$\bar{v}$  = Average velocity (m/s)

$C$  = velocity calculation constant = 129

$T_s$  = Average stack temperature (K)

$M_s$  = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

$K$  = Pitot calibration coefficient

$p_e$  = Absolute gas pressure (kPa)

$\Delta p$  = Average pitot tube pressure differential (kPa)

### Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

$q_{va}$  = Average flow rate (m<sup>3</sup>/s)

$\bar{v}$  = Average velocity (m/s)

$A$  = Stack cross-sectional area (m<sup>2</sup>)

### Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$H_a$  = Moisture at actual conditions (%volume)

$H_m$  = Reference moisture (%volume)

### Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$T_a$  = Temperature at actual conditions (K)

$T_m$  = Reference Temperature (K)

$p_a$  = Absolute gas pressure at actual conditions (kPa)

$p_m$  = Reference pressure (kPa)

### Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$O_{2,m}$  = Actual oxygen concentration (%)

$O_{2,ref}$  = Reference oxygen concentration (%)

## Concentration Calculations

### Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

$c$  = Concentration  
 $m$  = Mass of substance  
 $V$  = Volume sampled

### Mass Emission

$$\text{Mass emission} = c \times q_m$$

$c$  = Concentration  
 $q$  = Volume flow rate

### Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

$c_m$  = Concentration at reference conditions  
 $c_a$  = Actual concentration  
 $O_{2, ref}$  = Reference oxygen (%)  
 $O_{2, a}$  = Actual Oxygen (%)

### Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

$c_{wet}$  = Concentration wet gas  
 $c_{dry}$  = Concentration dry gas  
 $H_a$  = Water vapour content (%vol)

### Conversion of parts per million (ppm) to mg/m<sup>3</sup>

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

### When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

## Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

### Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

$C_{ppm}$	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

### Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left( \frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$  is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:  
 $S_{r,0}$  is the standard uncertainty at zero level  
 $S_{r,s}$  is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:  
 $u(Corr_{loss})$  is the uncertainty due to losses in sample line  
 $u(Corr_{cal})$  is the uncertainty due to losses in sample line  
 $c_{j,loss}$  is the concentration of sample loss at span level  
 $U_{cal}$  is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:  
 $c_j$  is the sensitivity coefficient of the influence quantity  
 $x_{j,min}$  is the minimum value of the influence quantity during monitoring  
 $x_{j,max}$  is the maximum value of the influence quantity during monitoring  
 $x_{j,adj}$  is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:  
 $c_j$  is the sensitivity coefficient of the interferent j  
 $Int_{j,test}$  is the concentration of the interferent j used to determine  $c_j$   
 $Int_{j,min}$  is the minimum value of the interferent j quantity during monitoring  
 $Int_{j,max}$  is the maximum value of the interferent j quantity during monitoring  
 $Int_{j,adj}$  is the concentration of the interferent j in the cal gas used to adjust the analyser  
 $S_{int,p}$  is the sum of interferences with positive impact  
 $S_{int,n}$  is the sum of interferences with negative impact

### Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2)  $U(C_m) = u(C_m) \times k$

### Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:  
 $C_{NOx}$  is the concentration of NOx measured by the analyser  
 $R$  is the ratio of NO:Nox in the stack gas  
 $\eta$  is the NOx converter efficiency

### Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

### Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left( \frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O <sub>2</sub> ref. concentration	in	mg/m <sup>3</sup>
$C_{O_2,ref}$	=	mass concentration at O <sub>2</sub> reference concentration	in	mg/m <sup>3</sup>
$O_{2,meas}$	=	O <sub>2</sub> measured concentration	in	% volume
$u(O_{2,meas,dry})$	=	uncertainty associated to the measured O <sub>2</sub> concentration	in	%(relative to O <sub>2,meas</sub> )

## APPENDIX 4

### Uncertainty Estimate For The Measurement Of Total Organic Carbon

Analyser Type/Model 

Sick Maihak
-------------

  
 Reference Oxygen % 

0
---

 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m <sup>3</sup>	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	5.1	6.9	2.1
Measured concentration	mg/m <sup>3</sup>	8.3	11.1	3.4
Concentration at O <sub>2</sub> ref. concentration	mg/m <sup>3</sup>	N/A	N/A	N/A

Calibration gas	ppm	74.7	74.7	74.7
Calibration gas	mg/m <sup>3</sup>	120.1	120.1	120.1
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m <sup>3</sup>	15.0	15.0	15.0

**Correction of Lack of Fit**

Lack of fit	% range	2.0	2.0	2.0
	u(Corr <sub>lof</sub> )	0.11	0.11	0.11

**Corrections of Zero and Span Drift**

(\*All drift is calculated for ∴ the residual is assumed to be < 5% u(max) )

Zero Drift	% range	0.00	0.00	0.00
	u(Corr <sub>zdr</sub> )	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr <sub>spd</sub> )	0.00	0.00	0.00

**Correction of Repeatability of Measurement**

Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr <sub>rep</sub> )	0.00	0.00	0.00

**Correction of adjustment**

losses in the line	% range	0.27	0.27	0.27
	u(Corr <sub>loss</sub> )	0.01	0.01	0.00
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr <sub>cal</sub> )	0.05	0.07	0.02

**Correction of Influence of Interferents**

N <sub>2</sub> O	% range			
	u(Corr <sub>N2O</sub> )	0.00	0.00	0.00
CO <sub>2</sub>	% range			
	u(Corr <sub>CO2</sub> )	0.00	0.00	0.00
CH <sub>4</sub>	% range			
	u(Corr <sub>CH4</sub> )	0.00	0.00	0.00
Total of interferent influences u(ΣCorr <sub>int</sub> ) = max{Σ <sub>int,p</sub> ; Σ <sub>int,s</sub> }	% range	2.50	2.50	2.50
	u(ΣCorr <sub>int</sub> )	0.16	0.16	0.16

**Correction of Influence Quantities**

Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr <sub>flow</sub> )	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr <sub>press</sub> )	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr <sub>temp</sub> )	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr <sub>volt</sub> )	0.10	0.10	0.10
Maximum standard uncertainty	u(Corr <sub>max</sub> )	0.11	0.11	0.11
5% of maximum standard uncertainty	u(Corr <sub>5%</sub> )	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH <sub>4</sub> range	0	10	0	50	mg/m <sup>3</sup>
N <sub>2</sub> O range	0	0	0	20	mg/m <sup>3</sup>
CO <sub>2</sub> range	8	12	0	15	mg/m <sup>3</sup>
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m <sup>3</sup>

**Influence Quantity Variations**

	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

**Measurement uncertainty**

		Test 1	Test 2	Test 3
Combined uncertainty	ppm	0.37	0.37	0.37
Combined uncertainty	mg/m <sup>3</sup>	0.59	0.60	0.59
Combined uncertainty at oxygen reference	mg/m <sup>3</sup>	0.59	0.60	0.59

**Expanded uncertainty expressed with a level of confidence of 95%, k=2**

Overall uncertainty	ppm	0.7	0.7	0.7
Overall uncertainty	mg/m <sup>3</sup>	1.2	1.2	1.2
Overall uncertainty relative to measured value	%	14.3	10.8	34.1
Overall uncertainty relative to range	%	7.9	8.0	7.8
Overall uncertainty relative to ELV	%	1.0	1.0	1.0

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



**Client** Linx Printing Technologies Limited  
 Linx House  
 8 Stocks Bridge Way  
 St Ives  
 Cambridgeshire  
 PE27 5JL

**Part 1: Executive Summary**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Site</b>	<b>St Ives</b>
<b>Plant</b>	<b>Wet Test Stack 1 (Room Extract)</b>
<b>Sampling Date</b>	<b>2nd &amp; 3rd November 2015</b>
<b>Report Date</b>	<b>7th December 2015</b>
<b>Job Number</b>	<b>EM-2112</b>
<b>Permit Number</b>	<b>B18/14</b>

<b>Report Prepared by:</b>	<b>Print</b>	<b>Harpreet Badwal</b>	
	<b>MCERTS No.</b>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	<b>Derek Myers</b>	
	<b>MCERTS No.</b>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
 Unit 19  
 Bordesley Green Trading Estate  
 Bordesley Green Road  
 Birmingham  
 B8 1BZ

Tel: 0845 676 9303  
 Company Registration No 03133832



## Contents

Page 1	<b>Part 1: Executive Summary</b>
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results
Page 5	Summary Of Results, Exhaust Gases
Page 6	Operating Information
Page 6	Comments On Monitoring Procedures
Page 7	<b>Part 2: Supporting Information</b>
Page 8	<b>Appendix 1</b>
Page 9	Emission Monitoring Procedures and Instrumentation
Page 10	Sampling Personnel
Page 10	Equipment References
Page 11	<b>Appendix 2</b>
Page 12	Preliminary Velocity Traverse Data
Page 13	Exhaust Gases - Continuous Analysis Data
Page 14	Exhaust Gases - Continuous Analysis Data, Continued
Page 15	Chart 1 - VOC Emissions Data, 02/11/2015
Page 16	Chart 2 - VOC Emissions Data Cont, 03/11/2015
Page 17	<b>Appendix 3</b>
Page 18	Diagram of Sampling Location
Page 19	Generic Calculations
Page 20	Flow Calculations
Page 21	Concentration Calculation
Page 22	Uncertainty Estimate Calculations - Instrumental Techniques
Page 23	<b>Appendix 4</b>
Page 24	Uncertainty Estimates:- TOC
Page 25	Uncertainty Estimates:- TOC

## Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
Wet Test Stack 1 (Room Extract)	Total organic carbon

## Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

## Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow TOC	TPM/01A TPM/13	BS EN ISO 16911-1:2013 BS EN 12619 : 2013

## Summary Of Results

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**  
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives Wet Test Stack 1 (Room Extract)	Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
	Date	Start	End	mg/m <sup>3</sup> *	mg/m <sup>3</sup> *	mg/m <sup>3</sup> *	mg/m <sup>3</sup> *	g/h
TOC	02/11/15	16:50	17:50	30.8	75	1.3	0.2	131.7
TOC	03/11/15	08:30	09:00	17.5	75	1.2	0.2	74.9

* at reference conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
---------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
 \*\* Analysis not required # - UKAS accredited only  
 ND Non detectable ## - Not Accredited  
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated.  
 Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



### Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**  
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives		Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
		Date	Start	End					
Wet Test Stack 1 (Room Extract)									
TOC	Test 1	02/11/15	16:50	17:20	41.5	75	1.4	0.2	177.5
TOC	Test 2	02/11/15	17:20	17:50	20.1	75	1.2	0.2	85.9
TOC	Test 3	03/11/15	08:30	09:00	17.5	75	1.2	0.2	74.9

* at ref	Stack Gas Weight	0 °C	Without correction for moisture
Conditions	29.00 Kg/kmol	101.3 kPa	Oxygen No Correction %

Where applicable

Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report:

- \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa
- \*\* Analysis not required # - UKAS accredited only
- ND Non detectable ## - Not Accredited
- s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



## Operating Information

The table below shows details of the operating information on each sampling date for: **Wet Test Stack 1 (Room Extract)**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
2nd & 3rd November 2015	LEV From Ink Printer Testing Room	Continuous	Natural Gas	Methyl - Ethyl Ketone, Acetone & Ethanol	Bag Filter	Normal Operation

There are no CEM's available on this process.

## Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-  
The homogeneity test is not applicable to non-combustion processes.  
The homogeneity test is not applicable to duct areas less than 1m<sup>2</sup>.

All monitoring was performed in accordance with the relevant procedures.

The sampling location is a vertical rectangular duct.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



**Part 2: Supporting Information**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Client</b>	Linx Printing Technologies Limited
<b>Site</b>	St Ives
<b>Plant</b>	Wet Test Stack 1 (Room Extract)
<b>Sampling Date</b>	2nd & 3rd November 2015
<b>Report Date</b>	7th December 2015
<b>Job Number</b>	EM-2112
<b>Permit Number</b>	B18/14

<b>Report Prepared by:</b>	<b>Print</b>	<b>Harpreet Badwal</b>	
	<b>MCERTS No.</b>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>



<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	<b>Derek Myers</b>	
	<b>MCERTS No.</b>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832

 a CONCEPT LIFE SCIENCES company



## APPENDIX 1

## **Emission Monitoring Procedures And Instrumentation**

### **Gas velocity and temperature**

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013. Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

### **Total organic carbon**

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013. Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

### Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Report authorised by:	Derek Myers	MM02 115	-	30/09/2017	31/05/2018	30/11/2018	30/11/2018	30/11/2018
Team leader:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Team leader:	Aidan Wrynne	MM08 921	-	31/05/2017	31/05/2017	31/11/2018	30/11/2017	30/06/2018

### Equipment References

Equipment	Reference Number
FID	AQ271
Heated Line	HL40
Heated Filter	Sintered
Stack Thermocouple	PTTS97
Timer / Stopwatch	ST41
Barometer	WS03
Pitot	PT129
Thermometer	TK28
Manometer	PI03

## APPENDIX 2

Date	02/11/2015
Time	16:43
Pitot Cp	1.01

Barometric pressure	102.3	kPa
Duct static pressure	0.00	kPa
Stack Area	0.665	m <sup>2</sup>

Stack Depth (rectangular)	0.70	m
Stack Depth (rectangular)	0.95	m

Traverse Point	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s
1	A						B					
2	A	5.0	0.1	14	<15	1.3	B					
3	A	10.5	0.1	14	<15	1.3	B					
4	A	17.5	0.1	14	<15	1.3	B					
5	A	24.5	0.3	14	<15	2.2	B					
6	A	31.5	0.2	14	<15	1.8	B					
7	A	38.5	0.2	14	<15	1.8	B					
8	A	45.5	0.1	14	<15	1.3	B					
9	A	52.5	0.3	14	<15	2.2	B					
10	A	59.5	0.5	14	<15	2.9	B					
11	A	65.0	0.4	14	<15	2.6	B					
12	A						B					

Average Pitot DP	0.22	mmH <sub>2</sub> O
Average Temperature	287.2	K
Average Velocity	1.9	m/s
Average volumetric flow rate	1.24	m <sup>3</sup> /s at stack conditions
Average volumetric flow rate	1.19	m <sup>3</sup> /s (wet STP)

**Sampling plane requirements Re: BS EN 13284-1:2001 5.2**

a	Angle of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	NO
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	1.3
	Maximum local gas velocity	2.9
	Ratio of highest to lowest local gas velocity	2.24

**Preliminary Velocity Traverse Data**

Date 02/11/2015

From 16:50 to 17:20 30 minute mean

Volatile organic compounds	vppm, wet	25.80	mg/m <sup>3</sup> *	41.46
----------------------------	-----------	-------	---------------------	-------

From 17:20 to 17:50 30 minute mean

Volatile organic compounds	vppm, wet	12.48	mg/m <sup>3</sup> *	20.06
----------------------------	-----------	-------	---------------------	-------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m <sup>3</sup> *	0.16
----------------------------	------	------	---------------------	------

Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VCK01959	-	± 2
Volatile organic compounds	vppm	74.7	VC59841	10	± 2

Zero And Span Gas Details

Species	units	Initial Time	15:23	Final Time	18:08
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	74.70	-0.39	74.10

**Exhaust Gases Continuous Analysis Data**

Date 03/11/2015

From 08:30 to 09:00 30 minute mean

Volatile organic compounds	vppm, wet	10.88	mg/m <sup>3</sup> *	17.48
----------------------------	-----------	-------	---------------------	-------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m <sup>3</sup> *	0.16
----------------------------	------	------	---------------------	------

Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VCK01959	-	± 2
Volatile organic compounds	vppm	74.7	VC59841	10	± 2

Zero And Span Gas Details

Species	units	Initial Time	08:19	Final Time	10:10
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	74.70	-0.21	74.14

**Exhaust Gases Continuous Analysis Data, Continued**

Chart 1 - VOC Emissions Data - Wet Test Stack 1 (Room Extract), 02/11/2015





Chart 2 - VOC Emissions Data, Cont - Wet Test Stack 1 (Room Extract), 03/11/2015




## APPENDIX 3

## Diagram Of The Sampling Location

Diagram of sampling points across the cross section of the duct (not to scale).

Traverse length =  m x 0.95m



## General Calculations

### Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

$\pi$  = 3.142

### Pressure conversion:

1mmH<sub>2</sub>O = 0.00980665 kPa

1mmH<sub>2</sub>O = 9.80665 Pa

1 mar = 0.1 kPa

### Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m<sup>3</sup> of water vapour in m<sup>3</sup> of wet gas)

V<sub>m(std)</sub> = Dry gas volume measured, corrected to standard conditions (m<sup>3</sup>)

m<sub>WC</sub> = Mass of water collected in the impingers (g)

M<sub>w</sub> = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

V<sub>mol(std)</sub> = Molar volume of water at standard conditions = 0.0224 (m<sup>3</sup>/mol)

### Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

V<sub>m(std)</sub> = Dry gas meter volume at standard conditions (m<sup>3</sup>)

y<sub>d</sub> = Gas meter calibration coefficient

(V<sub>2</sub>-V<sub>1</sub>) = Dry gas meter volume at actual conditions (m<sup>3</sup>)

T<sub>m</sub> = Actual Temperature (K)

T<sub>std</sub> = Standard temperature (273 K)

p<sub>m</sub> = Absolute pressure at the gas meter (kPa)

p<sub>std</sub> = Standard gas pressure (101.3 kPa)

### Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

### Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

## Flow Calculations

### Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

$\bar{v}$  = Average velocity (m/s)

$C$  = velocity calculation constant = 129

$T_s$  = Average stack temperature (K)

$M_s$  = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

$K$  = Pitot calibration coefficient

$p_e$  = Absolute gas pressure (kPa)

$\Delta p$  = Average pitot tube pressure differential (kPa)

### Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

$q_{va}$  = Average flow rate (m<sup>3</sup>/s)

$\bar{v}$  = Average velocity (m/s)

$A$  = Stack cross-sectional area (m<sup>2</sup>)

### Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$H_a$  = Moisture at actual conditions (%volume)

$H_m$  = Reference moisture (%volume)

### Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$T_a$  = Temperature at actual conditions (K)

$T_m$  = Reference Temperature (K)

$p_a$  = Absolute gas pressure at actual conditions (kPa)

$p_m$  = Reference pressure (kPa)

### Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$O_{2,m}$  = Actual oxygen concentration (%)

$O_{2,ref}$  = Reference oxygen concentration (%)

## Concentration Calculations

### Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

$c$  = Concentration  
 $m$  = Mass of substance  
 $V$  = Volume sampled

### Mass Emission

$$\text{Mass emission} = c \times q_m$$

$c$  = Concentration  
 $q$  = Volume flow rate

### Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

$c_m$  = Concentration at reference conditions  
 $c_a$  = Actual concentration  
 $O_{2, ref}$  = Reference oxygen (%)  
 $O_{2, a}$  = Actual Oxygen (%)

### Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

$c_{wet}$  = Concentration wet gas  
 $c_{dry}$  = Concentration dry gas  
 $H_a$  = Water vapour content (%vol)

### Conversion of parts per million (ppm) to mg/m<sup>3</sup>

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

### When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

## Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

### Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

$C_{ppm}$	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

### Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left( \frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$  is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:  
 $S_{r,0}$  is the standard uncertainty at zero level  
 $S_{r,s}$  is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:  
 $u(Corr_{loss})$  is the uncertainty due to losses in sample line  
 $u(Corr_{cal})$  is the uncertainty due to losses in sample line  
 $c_{j,loss}$  is the concentration of sample loss at span level  
 $U_{cal}$  is the expanded uncertainty of the calibration gas

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:  
 $c_j$  is the sensitivity coefficient of the influence quantity  
 $x_{j,min}$  is the minimum value of the influence quantity during monitoring  
 $x_{j,max}$  is the maximum value of the influence quantity during monitoring  
 $x_{j,adj}$  is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:  
 $c_j$  is the sensitivity coefficient of the interferent j  
 $Int_{j,test}$  is the concentration of the interferent j used to determine  $c_j$   
 $Int_{j,min}$  is the minimum value of the interferent j quantity during monitoring  
 $Int_{j,max}$  is the maximum value of the interferent j quantity during monitoring  
 $Int_{j,adj}$  is the concentration of the interferent j in the cal gas used to adjust the analyser  
 $S_{int,p}$  is the sum of interferences with positive impact  
 $S_{int,n}$  is the sum of interferences with negative impact

### Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2)  $U(C_m) = u(C_m) \times k$

### Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:  
 $C_{NOx}$  is the concentration of NOx measured by the analyser  
 $R$  is the ratio of NO:Nox in the stack gas  
 $\eta$  is the NOx converter efficiency

### Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

### Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left( \frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O <sub>2</sub> ref. concentration	in	mg/m <sup>3</sup>
$C_{O_2,ref}$	=	mass concentration at O <sub>2</sub> reference concentration	in	mg/m <sup>3</sup>
$O_{2,meas}$	=	O <sub>2</sub> measured concentration	in	% volume
$u(O_{2,meas,dry})$	=	uncertainty associated to the measured O <sub>2</sub> concentration	in	% (relative to O <sub>2,meas</sub> )

## APPENDIX 4

### Uncertainty Estimate For The Measurement Of Total Organic Carbon

Analyser Type/Model 

Sick Maihak
-------------

  
 Reference Oxygen % 

0
---

 (0 = No correction)

		Test 1	Test 2
Limit value	mg/m <sup>3</sup>	75	75
Limit value	ppm	46.7	46.7
Measured concentration	ppm	25.8	12.5
Measured concentration	mg/m <sup>3</sup>	41.5	20.1
Concentration at O <sub>2</sub> ref. concentration	mg/m <sup>3</sup>	N/A	N/A

Calibration gas	ppm	74.7	74.7
Calibration gas	mg/m <sup>3</sup>	120.1	120.1
Analyser range	ppm	9.3	9.3
Analyser range	mg/m <sup>3</sup>	15.0	15.0

Correction of Lack of Fit

Lack of fit	% range	2.0	2.0
	u(Corr <sub>lof</sub> )	0.11	0.11

Corrections of Zero and Span Drift (\*All drift is calculated for ∴ the residual is assumed to be < 5% u(max) )

Zero Drift	% range	0.00	0.00
	u(Corr <sub>zdrift</sub> )	0.00	0.00
Span Drift	% range	0.00	0.00
	u(Corr <sub>sprd</sub> )	0.00	0.00

Correction of Repeatability of Measurement

Repeatability SD at span level (Not reported)	% range	0.0	0.0
	u(Corr <sub>rep</sub> )	0.00	0.00

Correction of adjustment

losses in the line	% range	0.09	0.09
	u(Corr <sub>loss</sub> )	0.01	0.01
Uncertainty of calibration gas	% range	2.0	2.0
	u(Corr <sub>cal</sub> )	0.26	0.12

Correction of Influence of Interferents

N <sub>2</sub> O	% range		
	u(Corr <sub>N2O</sub> )	0.00	0.00
CO <sub>2</sub>	% range		
	u(Corr <sub>CO2</sub> )	0.00	0.00
CH <sub>4</sub>	% range		
	u(Corr <sub>CH4</sub> )	0.00	0.00
Total of interferent influences u(ΣCorr <sub>int</sub> ) = max{Σ <sub>int,p</sub> ; Σ <sub>int,x</sub> }	% range	2.50	2.50
	u(ΣCorr <sub>int</sub> )	0.16	0.16

Correction of Influence Quantities

Sensitivity to sample volume flow	% range	1.60	1.60
	u(Corr <sub>flow</sub> )	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range		
	u(Corr <sub>press</sub> )	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40
	u(Corr <sub>tempo</sub> )	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50
	u(Corr <sub>volt</sub> )	0.10	0.10

Hide		0.00	0.00
Maximum standard uncertainty	u(Corr <sub>max</sub> )	0.26	0.12
5% of maximum standard uncertainty	u(Corr <sub>5%</sub> )	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH <sub>4</sub> range	0	10	0	50	mg/m <sup>3</sup>
N <sub>2</sub> O range	0	0	0	20	mg/m <sup>3</sup>
CO <sub>2</sub> range	8	12	0	15	mg/m <sup>3</sup>
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m <sup>3</sup>

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty

		Test 1	Test 2
Combined uncertainty	ppm	0.45	0.39
Combined uncertainty	mg/m <sup>3</sup>	0.72	0.62
Combined uncertainty at oxygen reference	mg/m <sup>3</sup>	0.72	0.62

Expanded uncertainty expressed with a level of confidence of 95%, k=2

Overall uncertainty	ppm	0.9	0.8
Overall uncertainty	mg/m <sup>3</sup>	1.4	1.2
Overall uncertainty relative to measured value	%	3.5	6.2
Overall uncertainty relative to range	%	9.6	8.3
Overall uncertainty relative to ELV	%	1.2	1.0

The uncertainty evaluation has been carried out in accordance with UKAS requirements.

**Uncertainty Estimate For The Measurement Of Total Organic Carbon**

Analyser Type/Model	Sick Maihak
Reference Oxygen %	0 (0 = No correction)

		Test 1
Limit value	mg/m <sup>3</sup>	75
Limit value	ppm	46.7
Measured concentration	ppm	10.9
Measured concentration	mg/m <sup>3</sup>	17.5
Concentration at O <sub>2</sub> ref. concentration	mg/m <sup>3</sup>	N/A

Calibration gas	ppm	74.7
Calibration gas	mg/m <sup>3</sup>	120.1
Analyser range	ppm	9.3
Analyser range	mg/m <sup>3</sup>	15.0

Correction of Lack of Fit		
Lack of fit	% range	2.0
	u(Corr <sub>lof</sub> )	0.11

Corrections of Zero and Span Drift (*All drift is calculated for ∴ the residual is assumed to be < 5% u(max) )		
Zero Drift	% range	0.00
	u(Corr <sub>zdr</sub> )	0.00
Span Drift	% range	0.00
	u(Corr <sub>spd</sub> )	0.00

Correction of Repeatability of Measurement		
Repeatability SD at span level (Not reported)	% range	0.0
	u(Corr <sub>rep</sub> )	0.00

Correction of adjustment		
losses in the line	% range	0.15
	u(Corr <sub>loss</sub> )	0.01
Uncertainty of calibration gas	% range	2.0
	u(Corr <sub>cal</sub> )	0.11

Correction of Influence of Interferents		
N <sub>2</sub> O	% range	
	u(Corr <sub>N2O</sub> )	0.00
CO <sub>2</sub>	% range	
	u(Corr <sub>CO2</sub> )	0.00
CH <sub>4</sub>	% range	
	u(Corr <sub>CH4</sub> )	0.00
Total of interferent influences $u(\Sigma Corr_{int}) = \max\{S_{int,p}^2 + S_{int,s}\}$	% range	2.50
	u(ΣCorr <sub>int</sub> )	0.16

Correction of Influence Quantities		
Sensitivity to sample volume flow	% range	1.60
	u(Corr <sub>flow</sub> )	0.09
Sensitivity to atmospheric pressure (Not reported)	% range	
	u(Corr <sub>press</sub> )	0.00
Sensitivity to ambient temperature	% range	-2.40
	u(Corr <sub>tempo</sub> )	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50
	u(Corr <sub>volt</sub> )	0.10

Maximum standard uncertainty	u(Corr <sub>max</sub> )	0.11
5% of maximum standard uncertainty	u(Corr <sub>5%</sub> )	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH <sub>4</sub> range	0	10	0	50	mg/m <sup>3</sup>
N <sub>2</sub> O range	0	0	0	20	mg/m <sup>3</sup>
CO <sub>2</sub> range	8	12	0	15	mg/m <sup>3</sup>
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m <sup>3</sup>

Influence Quantity Variations					
	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty		Test 1
Combined uncertainty	ppm	0.38
Combined uncertainty	mg/m <sup>3</sup>	0.61
Combined uncertainty at oxygen reference	mg/m <sup>3</sup>	0.61

Expanded uncertainty expressed with a level of confidence of 95%, k=2		
Overall uncertainty	ppm	0.8
Overall uncertainty	mg/m <sup>3</sup>	1.2
Overall uncertainty relative to measured value	%	7.0
Overall uncertainty relative to range	%	8.2
Overall uncertainty relative to ELV	%	1.0

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



**Client** Linx Printing Technologies Limited  
Linx House  
8 Stocks Bridge Way  
St Ives  
Cambridgeshire  
PE27 5JL

**Part 1: Executive Summary**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Site</b>	St Ives
<b>Plant</b>	Wet Test Stack 2 (Individual Test Rig Extract)
<b>Sampling Date</b>	2nd & 3rd November 2015
<b>Report Date</b>	7th December 2015
<b>Job Number</b>	EM-2112
<b>Permit Number</b>	B18/14

<b>Report Prepared by:</b>	<b>Print</b>	Harpreet Badwal	
	<b>MCERTS No.</b>	MM03 149	Level 2 TE: 1,2,3,4

<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	Derek Myers	
	<b>MCERTS No.</b>	MM02 115	Level 2 TE: 1,2,3,4

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832

 a CONCEPT LIFE SCIENCES company



1783

## Contents

Page 1	<b>Part 1: Executive Summary</b>
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results
Page 5	Summary Of Results, Exhaust Gases
Page 6	Operating Information
Page 6	Comments On Monitoring Procedures
Page 7	<b>Part 2: Supporting Information</b>
Page 8	<b>Appendix 1</b>
Page 9	Emission Monitoring Procedures and Instrumentation
Page 10	Sampling Personnel
Page 10	Equipment References
Page 11	<b>Appendix 2</b>
Page 12	Preliminary Velocity Traverse Data
Page 13	Exhaust Gases - Continuous Analysis Data
Page 14	Exhaust Gases - Continuous Analysis Data, Continued
Page 15	Chart 1 - VOCs Emissions Data, 02/11/2015
Page 16	Chart 2 - VOCs Emissions Data Cont, 03/11/2015
Page 17	<b>Appendix 3</b>
Page 18	Diagram of Sampling Location
Page 19	Generic Calculations
Page 20	Flow Calculations
Page 21	Concentration Calculation
Page 22	Uncertainty Estimate Calculations - Instrumental Techniques
Page 23	<b>Appendix 4</b>
Page 24	Uncertainty Estimates:- TOC
Page 25	Uncertainty Estimates:- TOC

## Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
Wet Test Stack 2 (Individual Test Rig Extract)	Total organic carbon

## Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

## Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow	TPM/01A	BS EN ISO 16911-1:2013
TOC	TPM/13	BS EN 12619 : 2013

### Summary Of Results

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**  
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives Wet Test Stack 2 (Individual Test Rig Extract)	Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
	Date	Start	End					
TOC	02/11/15	16:00	16:30	446.4	75	9.0	0.2	1360.6
TOC	03/11/15	09:05	10:05	521.5	75	10.5	0.2	1589.5

* at reference conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
---------------------------	-----------------------------------	-------------------	---

Where applicable

Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report:

\* Reference conditions (see above)  
 \*\* Analysis not required  
 ND Non detectable  
 s - Subcontracted laboratory analysis

Nm<sup>3</sup> 273 K, 101.3 kPa  
 # - UKAS accredited only  
 ## - Not Accredited  
 N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated.  
 Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



### Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Linx Printing Technologies Limited**  
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at St Ives Wet Test Stack 2 (Individual Test Rig Extract)		Sampling Time			Emission Result mg/m <sup>3</sup> *	Authorised Limit mg/m <sup>3</sup> *	Uncertainty +/- mg/m <sup>3</sup> *	Detection Limit mg/m <sup>3</sup> *	Mass Emission g/h
		Date	Start	End					
TOC	Test 1	02/11/15	16:00	16:30	446.4	75	9.0	0.2	1360.6
TOC	Test 2	03/11/15	09:05	09:35	504.2	75	10.2	0.2	1536.7
TOC	Test 3	03/11/15	09:35	10:05	538.8	75	10.9	0.2	1642.2

* at ref Conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kPa	Without correction for moisture Oxygen No Correction %
------------------------	-----------------------------------	-------------------	---

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide  
 TOC results are expressed as total carbon

Throughout Report: \* Reference conditions (see above) Nm<sup>3</sup> 273 K, 101.3 kPa  
 \*\* Analysis not required # - UKAS accredited only  
 ND Non detectable ## - Not Accredited  
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated.  
 Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



## Operating Information

The table below shows details of the operating information on each sampling date for: **Wet Test Stack 2 (Individual Test Rig Extract)**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
2nd & 3rd November 2015	Ink Printer Testing Individual Rig Extraction	Continuous	N/A	Methyl - Ethyl Ketone & Acetone	None	Normal Operation

There are no CEM's available on this process.

## Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-  
The homogeneity test is not applicable to non-combustion processes.  
The homogeneity test is not applicable to duct areas less than 1m<sup>2</sup>.

All monitoring was performed in accordance with the relevant procedures.

The sampling location is a vertical duct.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.




**Part 2: Supporting Information**

**Report for the Periodic Monitoring of Emissions to Air.**

<b>Client</b>	Linx Printing Technologies Limited
<b>Site</b>	St Ives
<b>Plant</b>	Wet Test Stack 2 (Individual Test Rig Extract)
<b>Sampling Date</b>	2nd & 3rd November 2015
<b>Report Date</b>	7th December 2015
<b>Job Number</b>	EM-2112
<b>Permit Number</b>	B18/14

<b>Report Prepared by:</b>	<b>Print</b>	<b>Harpreet Badwal</b>	
	<b>MCERTS No.</b>	<b>MM03 149</b>	<b>Level 2 TE: 1,2,3,4</b>

<b>Report Approved by:</b>	<b>Sign</b>		
	<b>Print</b>	<b>Derek Myers</b>	
	<b>MCERTS No.</b>	<b>MM02 115</b>	<b>Level 2 TE: 1,2,3,4</b>

**REC Ltd Environmental Monitoring**  
Unit 19  
Bordesley Green Trading Estate  
Bordesley Green Road  
Birmingham  
B8 1BZ

Tel: 0845 676 9303  
Company Registration No 03133832

 a CONCEPT LIFE SCIENCES company



## APPENDIX 1

## **Emission Monitoring Procedures And Instrumentation**

### **Gas velocity and temperature**

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013. Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

### **Total organic carbon**

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013. Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

### Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Report authorised by:	Derek Myers	MM02 115	-	30/09/2017	31/05/2018	30/11/2018	30/11/2018	30/11/2018
Team leader:	Harpreet Badwal	MM03 149	-	30/09/2018	30/09/2018	30/04/2019	31/10/2019	31/10/2019
Team leader:	Aidan Wrynne	MM08 921	-	31/05/2017	31/05/2017	31/11/2018	30/11/2017	30/06/2018

### Equipment References

Equipment	Reference Number
FID	AQ271
Heated Line	HL40
Heated Filter	Sintered
Stack Thermocouple	PTTS97
Timer / Stopwatch	ST41
Barometer	WS03
Pitot	PT129
Thermometer	TK19
Manometer	PI03

## APPENDIX 2

Date	02/11/2015
Time	16:00
Pitot Cp	1.01

Barometric pressure	102.3	kPa
Duct static pressure	-1.02	kPa
Stack Area	0.071	m <sup>2</sup>

Stack Diameter (circular)	0.30	m
---------------------------	------	---

Traverse Point	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH <sub>2</sub> O	T °C	Angle °	velocity m/s
1	A						B					
2	A						B					
3	A	5.0	8.8	17	<15	12.0	B	5.0	7.4	17	<15	11.1
4	A	5.3	12.2	17	<15	14.2	B	5.3	8.3	17	<15	11.7
5	A	7.5	12.4	17	<15	14.3	B	7.5	8.1	17	<15	11.5
6	A	10.7	11.0	17	<15	13.5	B	10.7	8.9	17	<15	12.1
7	A	19.3	10.1	17	<15	12.9	B	19.3	10.5	17	<15	13.1
8	A	22.5	8.8	17	<15	12.0	B	22.5	12.1	17	<15	14.1
9	A	24.7	8.1	17	<15	11.5	B	24.7	13.5	17	<15	14.9
10	A	25.0	7.3	17	<15	11.0	B	25.0	11.6	17	<15	13.8
11	A						B					
12	A						B					

Average Pitot DP	9.85	mmH <sub>2</sub> O
Average Temperature	290.2	K
Average Velocity	12.7	m/s
Average volumetric flow rate	0.90	m <sup>3</sup> /s at stack conditions
Average volumetric flow rate	0.85	m <sup>3</sup> /s (wet STP)

**Sampling plane requirements Re: BS EN 13284-1:2001 5.2**

a	Angle of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	11.0
	Maximum local gas velocity	14.9
	Ratio of highest to lowest local gas velocity	1.35

**Preliminary Velocity Traverse Data**

Date 02/11/2015

From 16:00 to 16:30 30 minute mean

Volatile organic compounds	vppm, wet	277.78	mg/m <sup>3</sup> *	446.44
----------------------------	-----------	--------	---------------------	--------

## Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m <sup>3</sup> *	0.16
----------------------------	------	------	---------------------	------

## Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VCK01959	-	± 2
Volatile organic compounds	vppm	74.7	VC59841	10	± 2

## Zero And Span Gas Details

Species	units	Initial Time	15:23	Final Time	18:08
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	74.70	-0.39	74.10

**Exhaust Gases Continuous Analysis Data**

Date 03/11/2015

From 09:05 to 09:35 30 minute mean

Volatile organic compounds	vppm, wet	313.73	mg/m <sup>3</sup> *	504.21
----------------------------	-----------	--------	---------------------	--------

From 09:35 to 10:05 30 minute mean

Volatile organic compounds	vppm, wet	335.28	mg/m <sup>3</sup> *	538.84
----------------------------	-----------	--------	---------------------	--------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m <sup>3</sup> *	0.16
----------------------------	------	------	---------------------	------

Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VCK01959	-	± 2
Volatile organic compounds	vppm	74.7	VC59841	10	± 2

Zero And Span Gas Details

Species	units	Initial Time	16:05	Final Time	10:10
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	74.70	-0.21	74.14

**Exhaust Gases Continuous Analysis Data, Continued**

Chart 1 - VOC Emissions Data - Wet Test Stack 2 (Individual Test Rig Extract), 02/11/2015





Chart 2 - VOC Emissions Data Cont. - Wet Test Stack 2 (Individual Test Rig Extract) , 03/11/2015




## APPENDIX 3

## Diagram Of The Sampling Location

Diagram of sampling points across the cross section of the duct (not to scale).

Traverse length = 0.30 m

Point	% of D	Location cm
1	50.0	15.0



## General Calculations

### Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

$\pi$  = 3.142

### Pressure conversion:

1mmH<sub>2</sub>O = 0.00980665 kPa

1mmH<sub>2</sub>O = 9.80665 Pa

1 mar = 0.1 kPa

### Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m<sup>3</sup> of water vapour in m<sup>3</sup> of wet gas)

V<sub>m(std)</sub> = Dry gas volume measured, corrected to standard conditions (m<sup>3</sup>)

m<sub>WC</sub> = Mass of water collected in the impingers (g)

M<sub>w</sub> = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

V<sub>mol(std)</sub> = Molar volume of water at standard conditions = 0.0224 (m<sup>3</sup>/mol)

### Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

V<sub>m(std)</sub> = Dry gas meter volume at standard conditions (m<sup>3</sup>)

y<sub>d</sub> = Gas meter calibration coefficient

(V<sub>2</sub>-V<sub>1</sub>) = Dry gas meter volume at actual conditions (m<sup>3</sup>)

T<sub>m</sub> = Actual Temperature (K)

T<sub>std</sub> = Standard temperature (273 K)

p<sub>m</sub> = Absolute pressure at the gas meter (kPa)

p<sub>std</sub> = Standard gas pressure (101.3 kPa)

### Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

### Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

## Flow Calculations

### Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

$\bar{v}$  = Average velocity (m/s)

$C$  = velocity calculation constant = 129

$T_s$  = Average stack temperature (K)

$M_s$  = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

$K$  = Pitot calibration coefficient

$p_e$  = Absolute gas pressure (kPa)

$\Delta p$  = Average pitot tube pressure differential (kPa)

### Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

$q_{va}$  = Average flow rate (m<sup>3</sup>/s)

$\bar{v}$  = Average velocity (m/s)

$A$  = Stack cross-sectional area (m<sup>2</sup>)

### Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$H_a$  = Moisture at actual conditions (%volume)

$H_m$  = Reference moisture (%volume)

### Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$T_a$  = Temperature at actual conditions (K)

$T_m$  = Reference Temperature (K)

$p_a$  = Absolute gas pressure at actual conditions (kPa)

$p_m$  = Reference pressure (kPa)

### Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

$q_m$  = Corrected volume flowrate (m<sup>3</sup>/s)

$q_{va}$  = Volume flow rate at actual conditions (m<sup>3</sup>/s)

$O_{2,m}$  = Actual oxygen concentration (%)

$O_{2,ref}$  = Reference oxygen concentration (%)

## Concentration Calculations

### Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

$c$  = Concentration  
 $m$  = Mass of substance  
 $V$  = Volume sampled

### Mass Emission

$$\text{Mass emission} = c \times q_m$$

$c$  = Concentration  
 $q$  = Volume flow rate

### Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

$c_m$  = Concentration at reference conditions  
 $c_a$  = Actual concentration  
 $O_{2, ref}$  = Reference oxygen (%)  
 $O_{2, a}$  = Actual Oxygen (%)

### Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

$c_{wet}$  = Concentration wet gas  
 $c_{dry}$  = Concentration dry gas  
 $H_a$  = Water vapour content (%vol)

### Conversion of parts per million (ppm) to mg/m<sup>3</sup>

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

### When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

## Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

### Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

$C_{ppm}$	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

### Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left( \frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$  is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:  
 $S_{r,0}$  is the standard uncertainty at zero level  
 $S_{r,s}$  is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:  
 $u(Corr_{loss})$  is the uncertainty due to losses in sample line  
 $u(Corr_{cal})$  is the uncertainty due to losses in sample line  
 $c_{j,loss}$  is the concentration of sample loss at span level  
 $U_{cal}$  is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:  
 $c_j$  is the sensitivity coefficient of the influence quantity  
 $x_{j,min}$  is the minimum value of the influence quantity during monitoring  
 $x_{j,max}$  is the maximum value of the influence quantity during monitoring  
 $x_{j,adj}$  is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{Int,p}; S_{Int,n}]$$

Where:  
 $c_j$  is the sensitivity coefficient of the interferent j  
 $Int_{j,test}$  is the concentration of the interferent j used to determine  $c_j$   
 $Int_{j,min}$  is the minimum value of the interferent j quantity during monitoring  
 $Int_{j,max}$  is the maximum value of the interferent j quantity during monitoring  
 $Int_{j,adj}$  is the concentration of the interferent j in the cal gas used to adjust the analyser  
 $S_{Int,p}$  is the sum of interferences with positive impact  
 $S_{Int,n}$  is the sum of interferences with negative impact

### Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{Int}^2}$$

Overall expanded uncertainty (k = 2)  $U(C_m) = u(C_m) \times k$

### Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:  
 $C_{NOx}$  is the concentration of NOx measured by the analyser  
 $R$  is the ratio of NO:Nox in the stack gas  
 $\eta$  is the NOx converter efficiency

### Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{Int}^2 + u^2(Corr_{NOx,conv})}$$

### Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,df}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{Int}^2 + \left( \frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O <sub>2</sub> ref. concentration	in	mg/m <sup>3</sup>
$C_{O_2,ref}$	=	mass concentration at O <sub>2</sub> reference concentration	in	mg/m <sup>3</sup>
$O_{2,meas}$	=	O <sub>2</sub> measured concentration	in	% volume
$u(O_{2,meas,dry})$	=	uncertainty associated to the measured O <sub>2</sub> concentration	in	% (relative to O <sub>2,meas</sub> )

## APPENDIX 4

**Uncertainty Estimate For The Measurement Of Total Organic Carbon**

Analyser Type/Model	Sick Maihak
Reference Oxygen %	0 (0 = No correction)

		Test 1
Limit value	mg/m <sup>3</sup>	75
Limit value	ppm	46.7
Measured concentration	ppm	277.8
Measured concentration	mg/m <sup>3</sup>	446.4
Concentration at O <sub>2</sub> ref. concentration	mg/m <sup>3</sup>	N/A

Calibration gas	ppm	74.7
Calibration gas	mg/m <sup>3</sup>	120.1
Analyser range	ppm	9.3
Analyser range	mg/m <sup>3</sup>	15.0

Correction of Lack of Fit		
Lack of fit	% range	2.0
	u(Corr <sub>lof</sub> )	0.11

Corrections of Zero and Span Drift (*All drift is calculated for ∴ the residual is assumed to be < 5% u(max) )		
Zero Drift	% range	0.00
	u(Corr <sub>zdr</sub> )	0.00
Span Drift	% range	0.00
	u(Corr <sub>spd</sub> )	0.00

Correction of Repeatability of Measurement		
Repeatability SD at span level (Not reported)	% range	0.0
	u(Corr <sub>rep</sub> )	0.00

Correction of adjustment		
losses in the line	% range	0.09
	u(Corr <sub>loss</sub> )	0.15
Uncertainty of calibration gas	% range	2.0
	u(Corr <sub>cal</sub> )	2.78

Correction of Influence of Interferents		
N <sub>2</sub> O	% range	
	u(Corr <sub>N2O</sub> )	0.00
CO <sub>2</sub>	% range	
	u(Corr <sub>CO2</sub> )	0.00
CH <sub>4</sub>	% range	
	u(Corr <sub>CH4</sub> )	0.00
Total of interferent influences $u(\Sigma Corr_{int}) = \max\{S_{int,p}^2 + S_{int,s}\}$	% range	2.50
	u(Σ Corr <sub>int</sub> )	0.16

Correction of Influence Quantities		
Sensitivity to sample volume flow	% range	1.60
	u(Corr <sub>flow</sub> )	0.09
Sensitivity to atmospheric pressure (Not reported)	% range	
	u(Corr <sub>press</sub> )	0.00
Sensitivity to ambient temperature	% range	-2.40
	u(Corr <sub>tempo</sub> )	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50
	u(Corr <sub>volt</sub> )	0.10

Maximum standard uncertainty	u(Corr <sub>max</sub> )	2.78
5% of maximum standard uncertainty	u(Corr <sub>5%</sub> )	0.14

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH <sub>4</sub> range	0	10	0	50	mg/m <sup>3</sup>
N <sub>2</sub> O range	0	0	0	20	mg/m <sup>3</sup>
CO <sub>2</sub> range	8	12	0	15	mg/m <sup>3</sup>
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m <sup>3</sup>

Influence Quantity Variations					
	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty		Test 1
Combined uncertainty	ppm	2.80
Combined uncertainty	mg/m <sup>3</sup>	4.50
Combined uncertainty at oxygen reference	mg/m <sup>3</sup>	4.50

Expanded uncertainty expressed with a level of confidence of 95%, k=2		
Overall uncertainty	ppm	5.6
Overall uncertainty	mg/m <sup>3</sup>	9.0
Overall uncertainty relative to measured value	%	2.0
Overall uncertainty relative to range	%	60.0
Overall uncertainty relative to ELV	%	7.5

The uncertainty evaluation has been carried out in accordance with UKAS requirements.

### Uncertainty Estimate For The Measurement Of Total Organic Carbon

Analyser Type/Model 

Sick Maihak
-------------

  
 Reference Oxygen % 

0
---

 (0 = No correction)

		Test 1	Test 2
Limit value	mg/m <sup>3</sup>	75	75
Limit value	ppm	46.7	46.7
Measured concentration	ppm	313.7	335.3
Measured concentration	mg/m <sup>3</sup>	504.2	538.8
Concentration at O <sub>2</sub> ref. concentration	mg/m <sup>3</sup>	N/A	N/A

Calibration gas	ppm	74.7	74.7
Calibration gas	mg/m <sup>3</sup>	120.1	120.1
Analyser range	ppm	9.3	9.3
Analyser range	mg/m <sup>3</sup>	15.0	15.0

**Correction of Lack of Fit**

Lack of fit	% range	2.0	2.0
	u(Corr <sub>lof</sub> )	0.11	0.11

**Corrections of Zero and Span Drift**

(\*All drift is calculated for ∴ the residual is assumed to be < 5% u(max) )

Zero Drift	% range	0.00	0.00
	u(Corr <sub>zdr</sub> )	0.00	0.00
Span Drift	% range	0.00	0.00
	u(Corr <sub>sdr</sub> )	0.00	0.00

**Correction of Repeatability of Measurement**

Repeatability SD at span level (Not reported)	% range	0.0	0.0
	u(Corr <sub>rep</sub> )	0.00	0.00

**Correction of adjustment**

losses in the line	% range	0.15	0.15
	u(Corr <sub>loss</sub> )	0.27	0.29
Uncertainty of calibration gas	% range	2.0	2.0
	u(Corr <sub>cal</sub> )	3.14	3.35

**Correction of Influence of Interferents**

N <sub>2</sub> O	% range		
	u(Corr <sub>N2O</sub> )	0.00	0.00
CO <sub>2</sub>	% range		
	u(Corr <sub>CO2</sub> )	0.00	0.00
CH <sub>4</sub>	% range		
	u(Corr <sub>CH4</sub> )	0.00	0.00
Total of interferent influences $u(\Sigma Corr_{int}) = \max\{S_{int,p}^2 + S_{int,s}^2\}$	% range	2.50	2.50
	u(Σ Corr <sub>int</sub> )	0.16	0.16

**Correction of Influence Quantities**

Sensitivity to sample volume flow	% range	1.60	1.60
	u(Corr <sub>flow</sub> )	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range		
	u(Corr <sub>press</sub> )	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40
	u(Corr <sub>tempo</sub> )	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50
	u(Corr <sub>volt</sub> )	0.10	0.10

Maximum standard uncertainty	u(Corr <sub>max</sub> )	3.14	3.35
5% of maximum standard uncertainty	u(Corr <sub>5%</sub> )	0.16	0.17

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH <sub>4</sub> range	0	10	0	50	mg/m <sup>3</sup>
N <sub>2</sub> O range	0	0	0	20	mg/m <sup>3</sup>
CO <sub>2</sub> range	8	12	0	15	mg/m <sup>3</sup>
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m <sup>3</sup>

**Influence Quantity Variations**

	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty		Test 1	Test 2
Combined uncertainty	ppm	3.16	3.38
Combined uncertainty	mg/m <sup>3</sup>	5.08	5.43
Combined uncertainty at oxygen reference	mg/m <sup>3</sup>	5.08	5.43

**Expanded uncertainty expressed with a level of confidence of 95%, k=2**

Overall uncertainty	ppm	6.3	6.8
Overall uncertainty	mg/m <sup>3</sup>	10.2	10.9
Overall uncertainty relative to measured value	%	2.0	2.0
Overall uncertainty relative to range	%	67.7	72.4
Overall uncertainty relative to ELV	%	8.5	9.0

The uncertainty evaluation has been carried out in accordance with UKAS requirements.