

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

Premises BROADWAY GARAGE

Person Seen TONY SCOTT

Address TAXLET

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N

Satisfactory Y/N

Notes:

NO INCIDENTS
DOCUMENTED

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected Y/N

Satisfactory Y/N

Notes:

EVERY 3 YEARS

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N

Satisfactory Y/N

Notes:

NOTHING DOCUMENTED

d) STAFF COMPETENCE & TRAINING

No of Staff

4

No Questioned

1

Inspected Y/N

Satisfactory Y/N

Notes:

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/N

Satisfactory Y/N

Notes:

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

SMALL SITE
RECORDS SATISFACTORY

Are procedures in place adequate in the event of any leaks
or spillages? Y/N

Notes:

STAFF AWARE VIA TRAINING
RECORDS & RISK ASSESSMENT

Signed [Signature]

Tel /Email 01954 284 641

Received by [Signature]

Date/Time 21/8/15

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.