

**ENVIRONMENTAL PROTECTION  
REPORT – VAPOUR RECOVERY**

Premises TESCO S.S Person Seen C. HOESTED  
Address ABBOTS RIFTON RD, HUNTINGDON

**OBSERVATIONS, ADVICE AND RECOMMENDATIONS:**

As a result of the inspection of your premises your attention is drawn to the following matters:

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS  
AND ASSOCIATED LOG BOOK**

Inspected Y/N Satisfactory Y/N

Notes: DAILY LOG BOOK  
CHECKS.  
NO ISSUES RECORDED

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF  
VALVES**

Inspected Y/N Satisfactory Y/N

Notes: CERT DATED 22/06/15

**c) LOG BOOK DETAILING MAINTENANCE,  
EXAMINATION & TESTING, INVENTORY  
CHECKING, INSTALLATION & REPAIR WORK  
(SITE REGISTER)**

Inspected Y/N Satisfactory Y/N

Notes: SATISFACTORY

**d) STAFF COMPETENCE & TRAINING**

No of Staff 9 No Questioned 1

Inspected Y/N Satisfactory Y/N

Notes: COMPREHENSIVE  
STAFF TRAINING MANUAL

**e) VAPOUR RECOVERY CONNECTIONS &  
SIGNS**

Inspected Y/N Satisfactory Y/N

Notes: REQUIRE CLEANING

**f) SITE MANAGEMENT & OTHER COMMENTS**

Satisfactory Y/N

Notes: GOOD

Does the site have stage II vapour recovery? Y/N

Notes:

Are procedures in place adequate in the event of any leaks  
or spillages? Y/N

Notes: STAFF TRAINING

Signed [Signature]

Tel /Email 01954 286 641

Received by [Signature]

Date/Time 30/6/15

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.