

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Premises Sheel Kunhigden

Person Seen Mr Adnan Judd

Address Stakeley Road Kunhigden

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

Vapour recovery inspection conducted by H. Shepherd a Cambridge City Council on behalf of Kunhigden District Council.

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N

Satisfactory Y/N

Notes:

No incidents

b) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES

Inspected Y/N

Satisfactory Y/N

Notes:

Date of next test 17/11/14
2 valves replaced.

c) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N

Satisfactory Y/N

Notes:

Johnn controls annual inspections

d) STAFF COMPETENCE & TRAINING

No of Staff

7

No Questioned

1

Inspected Y/N

Satisfactory Y/N

Notes:

7 staff on competency register.
VR training to be updated
(recorded on separate register)
RNI received done

e) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N

Satisfactory Y/N

Notes:

Vent pipe 3 requires
label. Rectification notice
received 21/08/13 - done.

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Risk assessment to be renewed
cert for interceptor not seen
RNI received done

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes:

Signed A Judd

Tel /Email henry.h.shpherd@

Received by ADMAN JUD

Cambridgeshire.gov.uk

Date/Time

31/07/13

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.