

ENVIRONMENTAL PROTECTION  
REPORT - VAPOUR RECOVERY

Premises May 2 Plus

Person Seen Bala

Address Cambridge Street A Neath

**OBSERVATIONS, ADVICE AND RECOMMENDATIONS:**

As a result of the inspection of your premises your attention is drawn to the following matters:

Vapour recovery inspection conducted by H Shepherd  
Tracing standards on behalf of Haverford District Council  
Tel call / text message all works completed

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK**

Inspected Y/N Satisfactory Y/N

Notes:

Nothing documented

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES**

Inspected Y/N Satisfactory Y/N

Notes:

Not available

**c) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)**

Inspected Y/N Satisfactory Y/N

Notes:

Section to be made in  
register to document any  
incidents.

**d) STAFF COMPETENCE & TRAINING**

No of Staff 4 No Questioned 1

Inspected Y/N

Satisfactory Y/N

Notes:

**e) VAPOUR RECOVERY CONNECTIONS & SIGNS**

Inspected Y/N Satisfactory Y/N

Notes:

Does the site have stage II vapour recovery? Y/N

Notes:

**f) SITE MANAGEMENT & OTHER COMMENTS**

Satisfactory Y/N

Notes:

Rectification advice issued.  
Site under new management /  
ownership.

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes:

Risk assessment not seen

Signed [Signature]

Tel / Email 01484 284 628

Received by \_\_\_\_\_

Date/Time 20/12/13

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.

Fax received 11/4/14 with copy of VR cert.