

**ENVIRONMENTAL PROTECTION  
REPORT – VAPOUR RECOVERY**

MR SACA

6/4/2017  
14:30

Premises TOTAL SERVICE STATION Person Seen RAMISH

Address CAMBRIDGE RD  
ST NEOTS

**OBSERVATIONS, ADVICE AND RECOMMENDATIONS:**

As a result of the inspection of your premises your attention is drawn to the following matters:

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS  
AND ASSOCIATED LOG BOOK**

Inspected Y/~~N~~ Satisfactory Y/N

Notes:  
REGISTER NOT AVAILABLE  
AS WITH MR BOLA  
WHO IS NOT WORK

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF  
VALVES**

Inspected Y/N Satisfactory Y/N

Notes:

**c) LOG BOOK DETAILING MAINTENANCE,  
EXAMINATION & TESTING, INVENTORY  
CHECKING, INSTALLATION & REPAIR WORK  
(SITE REGISTER)**

Inspected Y/N Satisfactory Y/N

Notes:

**d) STAFF COMPETENCE & TRAINING**

No of Staff  No Questioned

Inspected Y/~~N~~ Satisfactory Y/N

Notes:  
MR RAMISH SEEN CONFIDENT WITH  
ALL ASPECTS OF SITE.

**e) VAPOUR RECOVERY CONNECTIONS &  
SIGNS**

Inspected Y/~~N~~ Satisfactory Y/N

Notes:  
FADED BUT LEGIBLE  
LOCKED + SECURE

Does the site have stage II vapour recovery? ~~Y~~/N

Notes:  
ADVISED.

**f) SITE MANAGEMENT & OTHER COMMENTS**

Satisfactory Y/N

Notes:

Are procedures in place adequate in the event of any leaks  
or spillages? Y/N

Notes:

Signed [Signature]

Tel /Email alan.posey@cambridgeshire.gov.uk

Received by X

Date/Time 28/3/2017.

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.