



**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Name Total UK Limited

Person Seen Mr Bishop

Address Hamlyn Lane, Boreham, London Rd, St Ives

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

Visited premises on site date - March 10. Visited 02/03/11

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N

Satisfactory Y/N

Notes

No incidents reported

d) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES (Annual)

Inspected Y/N

Satisfactory Y/N

Notes

Expired

b) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N

Satisfactory Y/N

Notes

relevant section in site register -

e) STAFF COMPETENCE & TRAINING

No of Staff ☐

No Questioned ☐

Inspected Y/N

Satisfactory Y/N

Notes

c) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N

Satisfactory Y/N

Notes

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes

OK

Signed Bishop

Tel / Email

Received by

Date/Time 01/09/10

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.