

ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY

Premises MRH Hemmingsford Person Seen Wimmer
Address London Road Hemmingsford

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

Conducted on behalf of the District Council

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N

Satisfactory Y/N

Notes:

Nothing documented

b) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES

Inspected Y/N

Satisfactory Y/N

Notes:

E&S PASS
Dated next test 31/10/16

c) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N

Satisfactory Y/N

Notes:

Nothing documented

d) STAFF COMPETENCE & TRAINING

No of Staff 4

No Questioned 1

LCD

Inspected Y/N

Satisfactory Y/N

Notes:

only 1 competent person Another due to be sent on training

e) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N

Satisfactory Y/N

Notes:

All hough tops not fitted

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes:

Signed [Signature]

Tel /Email 01954 284 628

Received by [Signature]

Date/Time 21/6/16

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.