

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

APPENDIX 1

Premise Rainbow Service St. Person Seen Mr Chris Gordon.
Address Newton Road, Ramsey, Huntingdon, PE26 1EJ

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N Satisfactory Y/N

Notes: No incidents recorded. Delivery driver does on faults kept.

d) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES (Annual)

Inspected Y/N Satisfactory Y/N

Notes: cert expired 31/03/10 no new certificate seen

b) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N Satisfactory Y/N

Notes: No incidents recorded.

e) STAFF COMPETENCE & TRAINING

No of Staff ☒ No Questioned ☐

Inspected Y/N Satisfactory Y/N

Notes: DGD box. VR explained. All incidents recorded by driver and reported to skel.

c) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected ☒ Y/N Satisfactory Y/N

Notes: High Water in tanks enable to see labels.

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory ☒ Y/N

Notes:

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes:

Inspector Deborah

Date 15th 16th Sept 2010.

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.

Contract for the conduct of process permits: HDC & CCC

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

APPENDIX 1

Premise Rainbow Service St Person Seen _____
Address Newtown rd, Ramsey, Huntingdon, PE26 1ES

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

copy of VR cert received, VR inspection completed

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N _____ Satisfactory Y/N _____

Notes:

**d) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES (Annual)**

Inspected Y/N _____ Satisfactory Y/N _____

Notes:

Date of test 22/03/10

Date of next test 22/03/11

**b) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N _____ Satisfactory Y/N _____

Notes:

e) STAFF COMPETENCE & TRAINING

No of Staff ☐ No Questioned ☐

Inspected Y/N _____ Satisfactory Y/N _____

Notes:

**c) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/N _____ Satisfactory Y/N _____

Notes:

Does the site have stage II vapour recovery? Y/N _____

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N _____

Notes:

Are procedures in place adequate in the event of any leaks or spillages? Y/N _____

Notes:

Inspector CRP Date 24/09/10

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation

Original VR inspection conducted on the 14/09/10

Vapour Recovery Inspection Test Certificate for Stage 1&2

Test Details					
Site Name	Co-op Ramsey				
Site Address	Newtown Road, Ramsey, Huntingdon				
Oil Company	Shell	Inspected By		D.Peacock	
Date of Test	22/03/10	Certificate No	DP220310D	Test kit no	70503

Test Results			
	Pass/Fail/NA		Yes/No/NA
System Integrity	Pass	Type of Manifold (High/Low, Underground)	Low
P&V Valve Pressure test	Pass	Clean Flame Arrestor	Yes
P&V Valve Vacuum test	Pass	System Drain Down	N/a
P&V Valve Leak test	Pass	Petrol Tank Numbers	1,2,3
Number of P&V Valves	1	Diesel Tank Numbers	4,5
New P&V Valves fitted (Y/N)	No	Diesel Vents in manifold (Y/N)	No
Caps, Seals & Signage	Pass	If applicable which tank	N/a
Test Notes			
Overall Test Result Pass/Fail		Pass	
Type of Test	Full	Date of next test	22/03/11

We declare that on the date shown above the vapour recovery system was examined and tested in accordance with E&S's test protocol and procedures for periodic examination and testing. Subject to any conditions recorded above, certify that the vapour recovery system meet all legislation and recommendations.

Company Seal:

Note: This certificate is invalid unless correctly stamped with the E&S validation Mark and may not be reproduced without the express approval of E&S.

Signed:



Dated: 22/03/2010

Mark Willis Operations Manager