

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Premises Ramsay Sewage Station

Person Seen Mr Miles Hales

Address Ramsay PE16 1EJ

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

Concluded on behalf of Humberley

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N

Satisfactory Y/N

Notes:

Nothing reported

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected Y/N

Satisfactory Y/N

Notes:

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N

Satisfactory Y/N

Notes:

Nothing reported

d) STAFF COMPETENCE & TRAINING

No of Staff

7

No Questioned

1

Inspected Y/N

Satisfactory Y/N

Notes:

Dcd site

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/N

Satisfactory Y/N

Notes:

Tank 1 requires UN label
Tank 3 dirty - can't read
labels please ensure labelled
correctly

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Discussed Wetstock.

Are procedures in place adequate in the event of any leaks
or spillages? Y/N

Notes:

Signed [Signature]

Tel /Email 01954 284 628

Received by [Signature]

Date/Time 28/05/10

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.