

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Premises Texaco service st Person Seen May Lord
Address 21 Henry Road Ramsey

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

Inspection conducted by H. Shepherd Trading Standards
Officer on behalf of Fenland District Council

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N Satisfactory Y/N
Notes:

No incidents

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected ☒ Y/N Satisfactory ☒ Y/N
Notes:

July 2012

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N Satisfactory Y/N
Notes:

No whistle test -> All faults
Not recorded
Recorded in generic log book

d) STAFF COMPETENCE & TRAINING
No of Staff No Questioned

Inspected ☒ Y/N Satisfactory ☒ Y/N
Notes:

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected ☒ Y/N Satisfactory ☒ Y/N
Notes:

Does the site have stage II vapour recovery? ☒ Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory ☒ Y/N

Notes:

Are procedures in place adequate in the event of any leaks
or spillages? ☒ Y/N

Notes:

RA

Signed [Signature]

Tel / Email 01954284621

Received by [Signature]

Date/Time 2/10/2012

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.