

ENVIRONMENTAL PROTECTION REPORT – VAPOUR RECOVERY

Premises Matthurst Kunhyden Person Seen Jay Jayarajah
Address Kunhyden Watten Trosses March Hertford Kunhyden
PE28 2DN

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

conducted on behalf of Kunhyden District Council.

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N

Satisfactory Y/N

Notes:

Nothing recorded

b) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES

Inspected Y/N

Satisfactory ☒ Y/N

Notes:

Eds

c) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N

Satisfactory Y/N

Notes:

Nothing recorded
VR fault recorded now in
place!

d) STAFF COMPETENCE & TRAINING

No of Staff

7

No Questioned

1

Inspected Y/N

Satisfactory Y/N

Notes:

4 trained as SMTs competent
according to training matrix.

e) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N

Satisfactory Y/N

Notes:

Had green bag - did not lift
hairs tips. Pte.

Does the site have stage II vapour recovery? ☒ Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory ☒ Y/N

Notes:

Spoke to Jay first time has
been questioned in relation to
VR.

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes:

Signed

[Signature]

Tel /Email

01954 284 628

Received by

J. Flyn

Date/Time

24/05/13