

Premise BP Little Hampton Servo Person Seen Mr Jones Townsend  
Address 23-25 London Road, Yaxley, Peterborough PE7 3NQ

**OBSERVATIONS, ADVICE AND RECOMMENDATIONS:**

As a result of the inspection of your premises your attention is drawn to the following matters:

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK**

Inspected ☒ Y ☐ N Satisfactory ☒ Y ☐ N

Notes:

*No incidents*

**d) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES (Annual)**

Inspected Y ☒ N Satisfactory ☒ Y ☐ N

Notes:

*20/08/09 - certificate not seen  
Invoice for works seen, requalification  
notice issued.*

**b) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)**

Inspected ☒ Y ☐ N Satisfactory ☒ Y ☐ N

Notes:

*No incidents*

**e) STAFF COMPETENCE & TRAINING**

No of Staff  No Questioned

Inspected ☒ Y ☐ N Satisfactory ☒ Y ☐ N

Notes:

*3 people take deliveries.*

**c) VAPOUR RECOVERY CONNECTIONS & SIGNS**

Inspected ☒ Y ☐ N Satisfactory ☒ Y ☐ N

Notes:

*Tank tops full of water enable  
to see all signage.*

Does the site have stage II vapour recovery? ☒ Y ☐ N

Notes:

**f) SITE MANAGEMENT & OTHER COMMENTS**

Satisfactory ☒ Y ☐ N

Notes:

Are procedures in place adequate in the event of any leaks or spillages? ☒ Y ☐ N

Notes:

Inspector:

*W. P. Trading Standards*

Date:

*09/12/09. 16:01*

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.

Contract for the conduct of process permits: HDC & CCC