

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Premises KINGS CANE GARAGE Person Seen RAS.

Address KINGS CANE
ST NEORS.

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/~~N~~ Satisfactory Y/~~N~~

Notes:

NEW VAPOUR SO REGISTER
IS NOW NO ENTRY
AT PRESENT.

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected Y/~~N~~ Satisfactory Y/~~N~~

Notes:

10/01/07 STAGE 1B ONLY.

T. HANSHAW.

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/~~N~~ Satisfactory Y/~~N~~

Notes:

SITE REGISTER NOW
IN PLACE

d) STAFF COMPETENCE & TRAINING

No of Staff 3 No Questioned 1

Inspected Y/~~N~~

Satisfactory Y/~~N~~

Notes:

ALL OK

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/~~N~~ Satisfactory Y/~~N~~

Notes:

FADED BUT IN PLACE
+ LEGIBLE.

Does the site have stage II vapour recovery? ~~Y~~/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/~~N~~

Notes:

NEW VAPOUR ADVICE GIVEN
IN PROGRESS.

Are procedures in place adequate in the event of any leaks
or spillages? Y/~~N~~

Notes:

Signed ORF.

Tel /Email alan.eusey@manbridge.co.uk 01907 284621

Received by X E. Coad

Date/Time 7/3/2017

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.