



7 East Bank Road, Sheffield, S2 3PT, UK
Tel: +44 (0)114 272 8647
Fax: +44 (0)114 273 0852

UKAS Testing Laboratory No 0144

REPORT OF PERIODIC MONITORING OF EMISSIONS TO AIR

Part A2 Process: A09/09: A09/09

East Anglian Galvanizing Ltd.

Old North Road
Sawtry
Cambridgeshire
PE28 5XN

Monitoring Date: 25th March 2015

Cti Ref: E50917

Customer Ref: PE8981

Report Written By: Neil Adshead
MCERTS Registration No.: SIRA MM 04 554
Function: Monitoring Technician

Report Approved By: Trevor Halliday
MCERTS Registration No.: SIRA MM 05 656
Function: Monitoring Consultant

Signed: Neil Adshead

Signed: T Halliday

Date: 17/04/15

CONTENTS

EXECUTIVE SUMMARY REPORT

- 1.0 Monitoring Objectives
- 2.0 Monitoring Results
- 3.0 Operating Information
- 4.0 Monitoring Deviations

SUPPORTING INFORMATION

- APPENDIX I General Information
 - A) Monitoring Organisation Staff Details
 - B) Monitoring Organisation Method Details
 - C) Monitoring Organisation Equipment Check List References
- APPENDIX II EAG 1 Galvanizing Bath

Note: Results from any sampling or analysis activity that are designated with an asterisk are not accredited by UKAS within our current schedule of accreditation.

EXECUTIVE SUMMARY REPORT

1.0 MONITORING OBJECTIVES

Sampling of emissions at East Anglian Galvanizing was undertaken at the request of Mr Robert Duxbury

The aim of the monitoring campaign was to:

- undertake annual compliance monitoring

in accordance with the Site Specific Protocol issued on 16th February 2015 (Cti Ref: E50917SSP).

The company is regulated as a Part A2 Process. The available guidance notes applicable to the process are:

Sector Guidance Note IPPC SG5 Secretary of State's Guidance for the A2 Galvanising Sector

Emission limits given in the results tables are taken from the requirements given in Permit No. A09/09.

Tests were performed to quantify the levels of emissions from the following process:

Stack Ref	Emission Source	Substances Monitored
EAG 1	Galvanizing Bath	Particulates

There were no special requirements applicable to the monitoring.

2.0 MONITORING RESULTS

Note: Uncertainty figures quote in this section represent the uncertainty at the 95% confidence level

Stack Ref.: EAG 1 Galvanizing Bath

Particulates	Test 1	Test 2	Emission Limit Value
Concentration:	4.1 mg m ⁻³	7.0 mg m ⁻³	< 15 mg m ⁻³
Mass Release:	27 g hr ⁻¹	52 g hr ⁻¹	-
Uncertainty:	± 0.66 mg m ⁻³	± 0.64 mg m ⁻³	-
Reference Conditions:	273K and 101.3kPa, without correction for water vapour content		
Date:	25/03/15	25/03/15	-
Test Period:	09:57 to 10:13 10:34 to 10:50	11:00 to 11:16 11:19 to 11:35	-
Duration:	32 mins	32 mins	-
Velocity:	3.6 m s ⁻¹	4.0 m s ⁻¹	-
Process Status:	Normal operations	Normal operations	-
Visibility:	Periodic blue/grey visible emission		Free from persistent visible emission
Monitoring Method:	BS EN 13284-1:2002 Determination of low range mass concentrations of dust		
Isokinetic Rate:	100%	101%	95 % to 115 %
Blank Value:	-0.35 mg m ⁻³		< 10 % ELV
Cti Accreditation for Use of Method:	MCERTS	MCERTS	-
Accreditation Status of Test:	MCERTS	MCERTS	-

3.0 OPERATING INFORMATION

Stack Ref.	Date	Process Type	Fuel	Feedstock	Abatement Type & operational status if abnormal	Load	Substance	Periodic Monitoring Result	Units
EAG 1	25/03/15	Continuous	N/a	Molten zinc	None	Normal	Particulates ^M	5.5	mg m ⁻³

Accreditation Status of test – (M) MCERTS

4.0 MONITORING DEVIATIONS

There were no deviations from planned monitoring methods

SUPPORTING INFORMATION

CONTENTS

APPENDIX I	General Information
A)	Monitoring Organisation Staff Details
B)	Monitoring Organisation Method Details
C)	Monitoring Organisation Equipment Check List References
APPENDIX II	EAG 1 Galvanizing Bath

APPENDIX I

GENERAL INFORMATION

A) Monitoring Organisation Staff Details

The following Cti staff were involved in the monitoring work reported:

Name	MCERTS Registration	Personnel Competency				Function	
			TE1	TE2	TE3		TE4
Trevor Halliday	SIRA MM 05 656	L2	✓	✓	✓	✓	Monitoring Consultant

B) Monitoring Organisation Method Details

The following methods were used for the monitoring work reported:

Substance	Standard Method	Cti OP	Accreditation
All	-	300, 303, 310	-
Moisture (Water Vapour)	BS EN 14790:2005	334	MCERTS
Velocity, Temperature & Pressure	BS EN ISO 16911-1:2013	311, 331 – 336, 361, 396	MCERTS
Particulates	BS EN 13284-1:2002	311, 331 – 336, 361	MCERTS

C) Monitoring Organisation Equipment Check List References

Specific equipment items used were recorded on site sampling datasheets during the monitoring campaign which are held in the Cti environmental monitoring files alongside the associated report

APPENDIX II


Stack Ref.: EAG 1 Galvanizing Bath

Emission Source EAG 1 Galvanizing Bath

Substances monitored: Particulates

Arrestment: None

Emission Point Description:			13284 Compliant
Duct dimensions:	0.855 m diameter		-
Location of sampling plane:	In vertical outlet stack		✓
Type of sampling port:	2 x 4 " BSP		✓
Number of sample lines:	Two		✓
Arrangement of sample lines:	90°		✓
Orientation of sample lines:	Horizontal		✓
Gas flow parameters	Flow: angle < 15°, > 5Pa, Ratio < 3:1, no -ve flow		✓



PARTICULATES											
Template Version 4 / Feb15 / TH											
VELOCITY CALCULATION											
Site: East Anglian Galvanizing		Plant: EAG 1 Galvanizing Bath			Date: 25/03/2015						
Units											
Stack diameter(Ds):	m	0.86									
Stack dimensions(L,W):	m			0.00							
Stack area(As):	m ²	0.574									
Reference temp(Tr):	K	273									
Reference Pressure (Pr):	Pa	101300									
Barometric Pressure (Pb):	mb	1012	101200	Pa							
Static Pressure (Ps):	*H ₂ O	0.09	22	Pa							
	mmH ₂ O		0	Pa							
Pitot coefficient(Cp):		0.83	Note: Use 1 if raw data corrected								
TEST ONE:											
										STP	
	Delta Hs (mm)	Pitot mm H ₂ O	Pa	Stack Temp, °C	DGM in	DGM out	V(m/s)	Vol Flow m ³ /s	V(m/s)	Vol Flow m ³ /s	Vol Flow m ³ /min
	64	1.0	6.8	34	20	18	3.6	2.069	3.2	1.854	111
	64	1.0	6.8	36	20	19					
	71	1.1	7.4	37	21	19					
	71	1.1	7.4	38	23	19		Vol Flow		Vol Flow	
	71	1.1	7.4	21	21	21		cfm		cfm	
	71	1.1	7.4	28	20	20					
	83	1.3	8.8	34	20	20		4383		3929	
	83	1.3	8.8	23	21	20					
		Mean	8	31.4		20.1					
		Std	0.74	6.1							
			Pa	Temp, °C		DGM					
TEST TWO:											
Barometric Pressure (Pb): mb 1012 101200 Pa											
Static Pressure (Ps): *H ₂ O 0.09 22 Pa											
mmH ₂ O 0 Pa											
Pitot coefficient(Cp): 0.83											
										STP	
	Delta Hs (mm)	Pitot mm H ₂ O	Pa	Temp, °C	DGM in	DGM out	V(m/s)	Vol Flow m ³ /s	V(m/s)	Vol Flow m ³ /s	Vol Flow m ³ /min
	86	1.3	8.8	28	22	20	4.0	2.288	3.6	2.064	124
	86	1.3	8.8	25	24	21					
	106	1.6	10.8	28	25	21					
	106	1.6	10.8	22	25	22		Vol Flow		Vol Flow	
	79	1.2	8.1	34	23	22		cfm		cfm	
	79	1.2	8.1	29	24	22					
	106	1.6	10.8	27	25	22		4849		4374	
	86	1.3	8.8	42	24	22					
		Mean	9	29		22.8					
		Std	1.14	5.7							
			Pa	Temp, °C		DGM					
EFFLUX VELOCITY CALCULATIONS											
Performed in accordance with HMP Technical Guidance Note D1											
				Heat Release	Momentum	Minimum Velocity					
Stack area (As)			0.57								
Efflux velocity			4.0	m/s							
Discharge gas temperature			304.4	°K	0.1	10	10				
Vol discharge rate of gases			2.29	m ³ /s	0.2	20	11				
Ambient temperature(K)			283	°K	0.3	30	11	Use max of either Q or M			
					0.4	40	12				
					0.5	50	12				
Heat release.					0.6	60	13				
	Q=	0.06	MW		0.7	70	13				
					0.8	80	14				
Momentum.					0.9	90	14				
	M=	8			1	100	15				

PARTICULATES		Template Version 4 / Feb15 / TH														
Site: East Anglian Galvanizing		Plant: EAG 1 Galvanizing Bath		Date: 25-Mar-15												
Units																
Stack diameter(Ds):	m	0.86	0.43													
Stack dimensions(Ds):	m	0.00	0.00													
Stack area(As):	m ²	0.574														
Standard 9096 or 13284:		13284														
Filter ID:		599	600	601												
Filter Size 37, 47, 110 or 4:		47	47	47												
Sample Ref:		EAG 1-1	EAG 1-2	EAG 1-B												
Filter weights:																
Tare Test One:		0.14612	Tare Test Two:	0.14546	Blank											
Gross Test One:		0.14886	Gross Test Two:	0.15147	0.14582											
mass collected:		0.00284		0.00501	0.00008											
Wash Out Weights:					Blank											
Tare Test One:		47.70765	Tare Test Two:	48.29205	61.17943											
Gross Test One:		47.70772	Gross Test Two:	48.29195	61.17772											
mass collected:		0.0001		-0.0001	-0.0007											
Control Weights:		Test 1	Test 2	Blank												
Mass Change:	Filter:	0.00001	0.00001	0.00001												
Mass Change:	Beaker:	-0.00037	-0.00037	-0.00037												
DGM Cal factor(Yd):		1.0353	1.0341													
Avg Delta H(DH):	Pa	708	698													
Barometric pressure(Pba):	Pa	101200	101200													
Reference pressure(Pr):	Pa	101325														
Avg DGM temp(Tm):	K	293.1	295.8													
Reference temp (Tr):	K	273														
Duct O2(Od):	%															
Ref O2(Or):	%															
Moisture(Bws):	%	0.68	0.45													
Gas vol sampled(Vm):	m ³	0.82	0.93													
Gas vol corrected(Vc):	m ³	0.80	0.89													
Moles Dry Gas(MDg):	M	36	40													
Particulates collected (Mass):	mg	3.3	6.3													
Concentration at STP dry(Cm):	mg/m ³	4.1	5.6	7.0												
Concentration at STP wet(Cw):	mg/m ³	4.1	5.5	7.0												
Concentration at ref O2(C-O2):	mg/m ³	4.1		7.0												
Minus Blank:	mg	3.6	6.6													
	mg/m ³	4.5	5.9	7.4												
	mg/m ³	4.4	5.9	7.3												
	mg/m ³	4.5	7.4													
Overall Test Blank	mg	-0.30	-0.30													
	mg/m ³	-0.37	-0.35	-0.33	-2.5%	-2.2%										
	mg/m ³	-0.37	-0.35	-0.33	-2.5%	-2.2%										
	mg/m ³	-0.37	-0.33	-0.33	-2.5%	-2.2%										
Acetone Blank	mg	-0.36	-0.36													
	mg/m ³	-0.45	-0.43	-0.40												
	mg/m ³	-0.45	-0.43	-0.40												
	mg/m ³	-0.45	-0.40													
Emission Limit:	mg/m ³	15														
Test Detection limit:																
Particulates collected (Mass):	mg	0.29	0.29													
Concentration at STP dry(Cm):	mg/m ³	0.36	0.32													
Concentration at STP wet(Cw):	mg/m ³	0.36	0.32													
Concentration at ref O2(C-O2):	mg/m ³	0.36	0.32													
Impinger weights:	g	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6									
Before Test One:		587.4														
After Test One:		591.8														
H2O collected:		4.4	Moles H ₂ O:	0.24												
Before Test Two:		Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6									
After Test Two:		591.8														
H2O collected:		3.2	Moles H ₂ O:	0.18												
Test DGM readings:	l	1732.360	Before Test Two:	2557.925	Metric Millerium Inst											
After Test One:		2552.820	After Test Two:	3483.160	Meter											
Sampled vol :		820.460		925.235												
% Isokinetic	Test One:		Test Two:													
Nozzle Dia:	"	0.5038	0.5038													
Sample time / point	mins	8	8													
Sample Duration:	mins	32	32													
Theoretical vol @ STP:	m ³	0.797	0.688													
% Isokinetic:		100	In Range	101	In Range											
Number of traverses:		2	2													
Theoretical Number of Traverses:		2	2													
Theoretical Points / Traverse		2	2													
Actual Points / Traverse		2	2													
Standard Uncertainty	+/-	0.33	mg/m3	0.32												
Expanded Uncertainty:	+/-	0.66	mg/m ³	0.64												
% of ELV		4.4		4.3												

Mass Emission with or without blank correction

With = Y Without = N: n

Mass Emission		
Test One	Test Two	
8	14	mg/s
27	52	g/hr
218	417	g/8 hr day
1.1	2.1	kg/5 day week
52	100	kg/48 week year