

REPORT OF PERIODIC MONITORING OF EMISSIONS TO AIR

Part A2 Process: A09/09

EAST ANGLIAN GALVANIZING LTD.

Old North Road
Sawtry
Cambridgeshire
PE28 5XN

Monitoring Date: 18th January 2018

Cti Ref: E62981

Customer Ref: PE13718

Report Written By: Peter Holdsworth
MCERTS Registration No.: SIRA MM 04 563
Function: Monitoring Consultant

Report Approved By: Trevor Halliday
MCERTS Registration No.: SIRA MM 05 656
Function: Monitoring Consultant

Signed: Peter Holdsworth

Signed: T Halliday

Date: 14th February 2018



Advanced Manufacturing Research Centre



0144

CONTENTS

EXECUTIVE SUMMARY REPORT

- 1.0 Monitoring Objectives
- 2.0 Monitoring Results
- 3.0 Operating Information
- 4.0 Monitoring Deviations

SUPPORTING INFORMATION

- APPENDIX I General Information
 - A) Monitoring Organisation Staff Details
 - B) Monitoring Organisation Method Details
 - C) Monitoring Organisation Equipment Check List References
 - D) Sub-contract Analysis Details

APPENDIX II EAG 1 Galvanizing Bath

EXECUTIVE SUMMARY REPORT

1.0 MONITORING OBJECTIVES

Sampling of emissions at East Anglian Galvanizing was undertaken at the request of Mr Mark Hammond.

The aim of the monitoring campaign was to:

- undertake periodic compliance monitoring.

in accordance with the Site Specific Protocol issued in January 2018 (Cti Ref: E62981SSP).

The company is regulated as a Part A2 Process. The available guidance note applicable to the process is:

Sector Guidance Note IPPC SG5 Secretary of State's Guidance for the A2 Galvanising Sector

Emission limits given in the results tables are taken from the requirements given in permit number A09/09.

Tests were performed to quantify the levels of emissions from the following process:

Stack Ref	Emission Source	Substances Monitored
EAG 1	Galvanizing Bath	Particulates

There were no special requirements applicable to the monitoring.

2.0 MONITORING RESULTS

Note: Uncertainty figures quote in this section represent the uncertainty at the 95% confidence level

Stack Ref.: EAG 1 Galvanizing Bath

Particulates	Test 1	Test 2	Emission Limit Value
Concentration:	21 mg m ⁻³	13 mg m ⁻³	< 15 mg m ⁻³
Mass Release:	340 g hr ⁻¹	210 g hr ⁻¹	-
Uncertainty:	± 1.2 mg m ⁻³	± 0.92 mg m ⁻³	-
Reference Conditions:	273K and 101.3kPa, without correction for water vapour content		
Date:	18/01/18	18/01/18	-
Test Period:	11:20 to 11:36 11:38 to 11:54	12:48 to 13:04 13:05 to 13:21	-
Duration:	32 mins	32 mins	-
Velocity:	7.7 m s ⁻¹	7.7 m s ⁻¹	-
Process Status:	Dipping as normal	Dipping as normal	-
Visibility:	Faint white emission on occasion	Faint white emission on occasion	Free from persistent visible emission
Monitoring Method:	BS EN 13284-1:2002 Determination of low range mass concentrations of dust		
Isokinetic Rate:	103 %	104 %	95 to 115 %
Blank Value:	- 0.41 mg m ⁻³		< 10 % ELV
Cti Accreditation for Use of Method:	MCERTS	MCERTS	-
Accreditation Status of Test:	MCERTS	MCERTS	-

3.0 OPERATING INFORMATION

Stack Ref.	Date	Process Type	Fuel	Feedstock	Abatement Type & operational status if abnormal	Load	Substance	Periodic Monitoring Result	Units
EAG 1	18/01/18	Continuous	Not applicable	Molten Zinc	None	Normal	Particulates ^M	17	mg m ⁻³

Accreditation Status of test – (M) MCERTS

4.0 MONITORING DEVIATIONS

There were no deviations from the planned monitoring methods.

SUPPORTING INFORMATION CONTENTS

APPENDIX I	General Information
A)	Monitoring Organisation Staff Details
B)	Monitoring Organisation Method Details
C)	Monitoring Organisation Equipment Check List References
D)	Sub-contract Analysis Details
APPENDIX II	EAG 1 Galvanizing Bath

APPENDIX I

GENERAL INFORMATION

A) Monitoring Organisation Staff Details

The following Cti staff were involved in the monitoring work reported:

Name	MCERTS Registration	Personnel Competency					Function
			TE1	TE2	TE3	TE4	
Peter Holdsworth	SIRA MM 04 563	L2	✓	✓	✓	✓	Monitoring Consultant

B) Monitoring Organisation Method Details

The following methods were used for the monitoring work reported:

Substance	Standard Method	Cti OP	Accreditation
All	-	300, 303, 310	-
Moisture (Water Vapour)	BS EN 14790:2017	334	MCERTS
Velocity, Temperature & Pressure	BS EN ISO 16911-1:2013	311, 331 – 336, 361, 396	MCERTS
Particulates	BS EN 13284-1:2002	311, 331 – 336, 361	MCERTS

C) Monitoring Organisation Equipment Check List References

Specific equipment items used were recorded on site sampling datasheets during the monitoring campaign which are held in the Cti environmental monitoring files alongside the associated report.

D) Sub-contract Analysis Details

There is no sub-contract analysis applicable to this report.

APPENDIX II

Stack Ref.: EAG 1 Galvanizing Bath

PARTICULATES											
OAF 462: Template Version 2 / Sep17 / TH											
VELOCITY CALCULATION											
Site: East Anglian Galvanizing Plant: EAG 1 Galvanizing extraction Date: 18/01/2018											
Stack diameter(Ds):	Units	m	0.90								
Stack dimensions(L,W):	m				0.00						
Stack area(As):	m ²		0.636								
Reference temp(Tr):	K		273								
Reference Pressure (Pr):	Pa		101300								
Barometric Pressure (Pb):	mb		1000		100000	Pa					
Static Pressure (Ps):	"H ₂ O				0	Pa					
	mmH ₂ O				44	Pa					
Pitot coefficient(Cp):			0.809	Note: Use 1 if raw data corrected							
TEST ONE:											
	Delta Hs (mm)	Pitot mm H ₂ O	Pa	Stack Temp, °C	DGM in	DGM out	V(m/s)	Vol Flow m ³ /s	STP V(m/s)	Vol Flow m ³ /s	Vol Flow m ³ /min
✓	92.1	9.0	57.8	17	19	19	7.7	4.9	7.0	4.5	268
✓	92.1	9.0	57.8	23	20	19					
✓	20.5	2.0	12.8	17	20	19					
✓	20.5	2.0	12.8	23	20	19					
✓	43.5	4.4	28.2	26	18	19		Vol Flow cfm		Vol Flow cfm	
✓	42.5	4.3	27.6	18	18	18					
✓	82.1	8.3	53.3	23	19	18		10325		9457	
✓	84.1	8.5	54.6	24	19	18					
	Mean		38.1	21.4		18.9					
	Std		18.6	3.3							
			Pa	Temp, °C		DGM					
TEST TWO:											
Barometric Pressure (Pb):	mb		1000		100000	Pa					
Static Pressure (Ps):	"H ₂ O				0	Pa					
	mmH ₂ O				44	Pa					
Pitot coefficient(Cp):			0.809								
TEST TWO:											
	Delta Hs (mm)	Pitot mm H ₂ O	Pa	Temp, °C	DGM in	DGM out	V(m/s)	Vol Flow m ³ /s	STP V(m/s)	Vol Flow m ³ /s	Vol Flow m ³ /min
	43.7	4.5	28.9	26	13	13	7.7	4.9	7.1	4.5	270
	49.8	5.0	32.1	19	14	13					
	75.8	7.8	50.1	26	15	13					
	79.7	8.0	51.3	18	15	13		Vol Flow cfm		Vol Flow cfm	
	97.6	9.8	62.9	19	16	13					
	85.5	8.8	56.5	26	16	13					
	20.9	2.1	13.5	18	16	13		10436		9534	
	20.4	2.1	13.5	25	16	13					
	Mean		38.6	22.1		14.1					
	Std		18.0	3.7							
			Pa	Temp, °C		DGM					

PARTICULATES		Template Version 4 / Feb15 / TH		
Site: East Anglian Galvanizing		Plant:	EAG 1 Galvanizing extraction	Date: 18-Jan-18
Stack diameter(Ds):	Units	0.90	0.45	
Stack dimensions(Ds):	m	0.00	0.00	
Stack area(As):	m ²	0.636		
Standard 9096 or 13284:		13284		
Filter ID:		2621	2622	2623
Filter Size 37, 47, 110 or 4:		47	47	47
Sample Ref:		EAG 1-1	EAG 1-2	EAG 1-B
Filter weights:				Blank
Tare Test One:		0.14666	Tare Test Two: 0.14717	0.14784
Gross Test One:		0.16123	Gross Test Two: 0.15633	0.14787
mass collected:		0.0146	0.00915	0.00003
Wash Out Weights:				Blank
Tare Test One:		66.48002	Tare Test Two: 47.40167	48.37610
Gross Test One:		66.47948	Gross Test Two: 47.40138	48.37542
mass collected:		-0.0005	-0.0003	-0.0007
Control Weights:		Test 1	Test 2	Blank
Mass Change:	Filter:	0.00000	0.00000	0.00000
Mass Change:	Beaker:	-0.00036	-0.00036	-0.00036
DGM Cal factor(Yd):		1.0090	1.0090	
Avg Delta H(DH):	Pa	585	580	
Barometric pressure(Pba):	Pa	100000	100000	
Reference pressure(Pr):	Pa	101325		
Avg DGM temp(Tm):	K	291.9	287.1	
Reference temp (Tr):	K	273		
Duct O2(Od):	%			
Ref O2(Or):	%			
Moisture(Bws):	%	0.69	0.62	
Gas vol sampled(Vm):	m ³	0.73	0.73	
Gas vol corrected(Vc):	m ³	0.68	0.69	
Moles Dry Gas(Mdg):	M	30	31	
Particulates collected, (Mass):	mg	14	9	
Concentration at STP dry(Cm):	mg/m ³	21	17	13
Concentration at STP wet(Cw):	mg/m ³	21	17	13
Concentration at ref O2(C-O2):	mg/m ³	21	13	13
Minus Blank:	mg	15	10	
	mg/m ³	22	18	14
	mg/m ³	21	18	14
	mg/m ³	22	14	
Overall Test Blank	mg	-0.28	-0.28	
	mg/m ³	-0.41	-0.41	-0.41
	mg/m ³	-0.41	-0.41	-0.40
	mg/m ³	-0.41	-0.41	-0.41
				% of limit Value
Acetone Blank	mg	-0.32	-0.32	
	mg/m ³	-0.46	-0.46	-0.46
	mg/m ³	-0.46	-0.46	-0.45
	mg/m ³	-0.46	-0.46	-0.46
Emission Limit:	mg/m ³	15		
Test Detection limit:				
Particulates collected, (Mass):	mg	0.29	0.29	
Concentration at STP dry(Cm):	mg/m ³	0.42	0.41	
Concentration at STP wet(Cw):	mg/m ³	0.42	0.41	
Concentration at ref O2(C-O2):	mg/m ³	0.42	0.41	
Impinger weights:	g	Imp 1		
Before Test One:		585.1		
After Test One:		588.9		
H2O collected:		3.8	Moles H ₂ O: 0.21	
Before Test Two:		Imp 1		
After Test Two:		588.9		
H2O collected:		592.4	Moles H ₂ O: 0.19	
Test DGM readings:	I			
Before Test One:		4837.15	Before Test Two: 5605.72	Metric Millenium Inst
After Test One:		5564.46	After Test Two: 6332.90	Meter
Sampled vol :		727.31	727.18	
% Isokinetic	Test One:		Test Two:	
Nozzle Dia:	"	0.3125	0.3125	
Sampl time / point	mins	8	8	
Sample Duration:	mins	32	32	
Theoretical vol @ STP:	m ³	0.667	0.672	
% Isokinetic:		103	In Range	104
			In Range	
Number of traverses:		2	2	
Theoretical Number of Traverses:		2	2	
Theoretical Points / Traverse		2	2	
Actual Points / Traverse		2	2	
Standard Uncertainty	+/-	0.58	mg/m ³	0.46
Expanded Uncertainty:	+/-	1.2	mg/m ³	0.92
% of ELV		7.7		6.2

Mass Emission without blank correction	
Test One	Test Two
21	13
94	60
337	215
2696	1716
13	8.6
647	412