

## REPORT OF PERIODIC MONITORING OF EMISSIONS TO AIR

Part A2 Process: A09/09

### EAST ANGLIAN GALVANIZING LTD.

Old North Road  
Sawtry  
Cambridgeshire  
PE28 5XN

**Monitoring Date:** 11<sup>th</sup> April 2019

**Cti Ref:** E70745-2

**Customer Ref:** PE15996

Report Written By: Peter Holdsworth  
MCERTS Registration No.: SIRA MM 04 563  
Function: Monitoring Consultant

Report Approved By: Trevor Halliday  
MCERTS Registration No.: SIRA MM 05 656  
Function: Senior Environmental Consultant

Signed: *Peter Holdsworth*

Signed: *T Halliday*

Date: 20<sup>th</sup> May 2019



Advanced Manufacturing Research Centre



0144

## CONTENTS

### EXECUTIVE SUMMARY REPORT

- 1.0 Monitoring Objectives
- 2.0 Monitoring Results
- 3.0 Operating Information
- 4.0 Monitoring Deviations

### SUPPORTING INFORMATION

- APPENDIX I General Information
  - A) Monitoring Organisation Staff Details
  - B) Monitoring Organisation Method Details
  - C) Monitoring Organisation Equipment Check List References
  - D) Sub-contract Analysis Details

APPENDIX II EAG 1 Galvanizing Bath

## EXECUTIVE SUMMARY REPORT

### 1.0 MONITORING OBJECTIVES

Sampling of emissions at East Anglian Galvanizing was undertaken at the request of Mr Mark Hammond.

The aim of the monitoring campaign was to:

- undertake annual compliance monitoring.

in accordance with the Site Specific Protocol issued in April 2019 (Cti Ref: E70745-2SSP).

The company is regulated as a Part A2 Process. The available guidance note applicable to the process is:

Sector Guidance Note IPPC SG5 Secretary of State's Guidance for the A2 Galvanising Sector

Emission limits given in the results tables are taken from the requirements given in permit number A09/09.

Tests were performed to quantify the levels of emissions from the following process:

<b>Stack Ref</b>	<b>Emission Source</b>	<b>Substances Monitored</b>
EAG 1	Galvanizing Bath	Particulates

There were no special requirements applicable to the monitoring.

## 2.0 MONITORING RESULTS

Note: Uncertainty figures quote in this section represent the uncertainty at the 95% confidence level

Stack Ref.: EAG 1 Galvanizing Bath

Particulates	Test 1	Test 2	Emission Limit Value
<b>Concentration:</b>	6.4 mg m <sup>-3</sup>	7.0 mg m <sup>-3</sup>	< 15 mg m <sup>-3</sup>
<b>Mass Release:</b>	89 g hr <sup>-1</sup>	94 g hr <sup>-1</sup>	-
<b>Uncertainty:</b>	± 0.93 mg m <sup>-3</sup>	± 0.97 mg m <sup>-3</sup>	-
<b>Reference Conditions:</b>	273K and 101.3kPa, without correction for water vapour content		
<b>Date:</b>	11/04/19	11/04/19	-
<b>Test Period:</b>	11:04 to 11:20 11:22 to 11:38	13:00 to 13:16 13:19 to 13:35	-
<b>Duration:</b>	32 mins	32 mins	-
<b>Velocity:</b>	6.6 m s <sup>-1</sup>	6.3 m s <sup>-1</sup>	-
<b>Process Status:</b>	Dipping as normal	Dipping as normal	-
<b>Visibility:</b>	No visible emission	No visible emission	Free from persistent visible emission
<b>Monitoring Method:</b>	BS EN 13284-1:2017 Determination of low range mass concentrations of dust		
<b>Isokinetic Rate:</b>	101 %	102 %	95 to 115 %
<b>Blank Value:</b>	0.42 mg m <sup>-3</sup>	0.43 mg m <sup>-3</sup>	< 10 % ELV
<b>Cti Accreditation for Use of Method:</b>	MCERTS	MCERTS	-
<b>Accreditation Status of Test:</b>	MCERTS	MCERTS	-

### 3.0 OPERATING INFORMATION

Stack Ref.	Date	Process Type	Fuel	Feedstock	Abatement Type & operational status if abnormal	Load	Substance	Periodic Monitoring Result	Units
EAG 1	11/04/19	Semi-continuous	Not applicable	Molten Zinc	None	Normal	Particulates <sup>M</sup>	6.7	mg m <sup>-3</sup>

Accreditation Status of test – (M) MCERTS (U) UKAS (N) None

### 4.0 MONITORING DEVIATIONS

There were no deviations from the planned monitoring methods.

## SUPPORTING INFORMATION

### CONTENTS

APPENDIX I	General Information
A)	Monitoring Organisation Staff Details
B)	Monitoring Organisation Method Details
C)	Monitoring Organisation Equipment Check List References
D)	Sub-contract Analysis Details
APPENDIX II	EAG 1 Galvanizing Bath

# **APPENDIX I**

## **GENERAL INFORMATION**

## A) Monitoring Organisation Staff Details

The following Cti staff were involved in the monitoring work reported:

Name	MCERTS Registration	Personnel Competency					Function
			TE1	TE2	TE3	TE4	
Peter Holdsworth	SIRA MM 04 563	L2	✓	✓	✓	✓	Monitoring Consultant
Lewis Pygott	SIRA MM 18 1510	Trainee	-	-	-	-	Monitoring Technician

## B) Monitoring Organisation Method Details

The following methods were used for the monitoring work reported:

Substance	Standard Method	Cti OP	Accreditation
All	-	300, 303, 310	-
Moisture (Water Vapour)	BS EN 14790:2017	334	MCERTS
Velocity, Temperature & Pressure	BS EN ISO 16911-1:2013	311, 331 – 336, 361, 396	MCERTS
Particulates	BS EN 13284-1:2017	311, 331 – 336, 361	MCERTS

## C) Monitoring Organisation Equipment Check List References

Specific equipment items used were recorded on site sampling datasheets during the monitoring campaign which are held in the Cti environmental monitoring files alongside the associated report.

## D) Sub-contract Analysis Details


There was no sub-contract analysis associated with the work reported.

## **APPENDIX II**

**Stack Ref.: EAG 1 Galvanizing Bath**

Emission Source            EAG 1            Galvanizing Bath  
 Substances monitored:    Particulates  
 Arrestment:                None

Emission Point Description:			13284 Compliant
Duct dimensions:	0.90 m diameter		-
Location of sampling plane:	In vertical outlet stack		✓
Type of sampling port:	2 x 4 " BSP		✓
Number of sample lines:	Two		✓
Arrangement of sample lines:	90°		✓
Orientation of sample lines:	Horizontal		✓
Gas flow parameters	Flow: angle < 15°, > 5Pa, Ratio < 3:1, no -ve flow		✓



PARTICULATES											
OAF 462: Template Version 6 / Jan19 / TH											
VELOCITY CALCULATION											
Site: East Anglian Galv. Sawtry		Plant: EAG 1, Galv Extraction			Date: 11/04/2019						
Stack diameter(Ds):	Units	m	0.90								
Stack dimensions(L,W):	m				0.00						
Stack area(As):	m <sup>2</sup>		0.636								
Reference temp(Tr):	K		273								
Reference Pressure (Pr):	Pa		101300								
Barometric Pressure (Pb):	mb		1025		102500	Pa					
Static Pressure (Ps):	"H <sub>2</sub> O		0.138		34	Pa					
	mmH <sub>2</sub> O				0	Pa					
Pitot coefficient(Cp):			0.831	Note: Use 1 if raw data corrected							
TEST ONE:											
	Delta Hs (mm)	Pitot mm H <sub>2</sub> O	Pa	Stack Temp, °C	DGM in	DGM out	V(m/s)	Vol Flow m <sup>3</sup> /s	STP V(m/s)	Vol Flow m <sup>3</sup> /s	Vol Flow m <sup>3</sup> /min
	52.3	5.5	37.2	20	10	10	6.6	4.2	6.1	3.9	233
	52.3	5.5	37.2	24	11	10					
	15.2	1.6	10.8	28	11	10					
	17.1	1.8	12.2	30	10	9					
	23.8	2.5	16.9	22	11	10		Vol Flow cfm		Vol Flow cfm	
	26.6	2.8	19.0	21	12	10					
	58.9	6.2	42.0	26	12	10		8834		8223	
	61.8	6.5	44.0	20	15	11					
		Mean	27	23.9		11					
		Std	13	3.6							
			Pa	Temp, °C		DGM					
TEST TWO:											
Barometric Pressure (Pb):	mb		1025.5		102500	Pa					
Static Pressure (Ps):	"H <sub>2</sub> O		0.138		34	Pa					
	mmH <sub>2</sub> O				0	Pa					
Pitot coefficient(Cp):			0.831								
TEST TWO:											
	Delta Hs (mm)	Pitot mm H <sub>2</sub> O	Pa	Temp, °C	DGM in	DGM out	V(m/s)	Vol Flow m <sup>3</sup> /s	STP V(m/s)	Vol Flow m <sup>3</sup> /s	Vol Flow m <sup>3</sup> /min
	19.5	2.0	13.5	22	15	13	6.3	4.0	5.9	3.7	225
	21.5	2.2	14.9	25	15	14					
	58.6	6.0	40.6	24	14	14					
	58.6	6.0	40.6	31	15	14					
	50.8	5.2	35.2	23	14	14		Vol Flow cfm		Vol Flow cfm	
	50.8	5.2	35.2	22	15	14					
	17.6	1.8	12.2	22	16	13		8521		7938	
	17.6	1.8	12.2	21	15	14					
		Mean	26	24		14					
		Std	13	3.0							
			Pa	Temp, °C		DGM					

PARTICULATES		Template Version 4 / Feb15 / TH							
Site: East Anglian Galv. Sawtry		Plant:	EAG 1, Galv Extraction	Date:	11-Apr-19				
Units									
Stack diameter(Ds):	m	0.90	0.45						
Stack dimensions(Ds):	m	0.00	0.00						
Stack area(As):	m <sup>2</sup>	0.636							
Standard 9096 or 13284:		13284							
Filter ID:		3346	3347	3348					
Filter Size (mm) 37, 47, 110 or 4:		47	47	47					
Filter type:		Quartz	Quartz	Quartz					
Filter Sampling temp:	°C	24	24	24					
Pre-sampling Conditioning temp:	°C	180	180	180					
Post-sampling Conditioning temp:	°C	160	160	160					
Sample Ref:		EAG 1-1	EAG 1-2	EAG 1-B					
Filter weights:									
Tare Test One:		0.14403	Tare Test Two: 0.14503	Blank 0.14399					
Gross Test One:		0.14770	Gross Test Two: 0.14881	0.14419					
mass collected:		0.00368	0.00378	0.00020					
Wash Out Weights:									
Tare Test One:		46.54342	Tare Test Two: 58.93688	Blank 47.97072					
Gross Test One:		46.54402	Gross Test Two: 58.93766	47.97088					
mass collected:		0.0006	0.0008	0.0002					
Control Weights:		Test 1	Test 2	Blank					
Mass Change:	Filter:	-0.00004	-0.00004	-0.00004					
Mass Change:	Beaker:	0.00067	0.00067	0.00067					
DGM Cal factor(Yd):		Test 1 1.0133	Test 2 1.0133						
Avg Delta H(DH):	Pa	377	382						
Barometric pressure(Pba):	Pa	102500	102550						
Reference pressure(Pr):	Pa	101325							
Avg DGM temp(Tm):	K	283.8	287.3						
Reference temp (Tr):	K	273							
Duct O2(Od):	%								
Ref O2(Or):	%								
Moisture(Bws):	%	1.0	1.1						
Gas vol sampled(Vm):	m <sup>3</sup>	0.58	0.57						
Gas vol corrected(Vc):	m <sup>3</sup>	0.57	0.55						
Moles Dry Gas(Mdg):	M	26	25						
Particulates collected, (Mass):	mg	3.7	3.9						
Concentration at STP dry(Cm):	mg/m <sup>3</sup>	6.5	7.1						
Concentration at STP wet(Cw):	mg/m <sup>3</sup>	6.4	7.0						
Concentration at ref O2(C-CO2):	mg/m <sup>3</sup>	6.5	7.1						
Minus Blank:	mg	3.5	3.7						
	mg/m <sup>3</sup>	6.0	6.6						
	mg/m <sup>3</sup>	6.0	6.3						
	mg/m <sup>3</sup>	6.0	6.6						
Overall Test Blank	mg	0.24	0.24						
	mg/m <sup>3</sup>	0.42	0.44	Blank Acceptable?					
	mg/m <sup>3</sup>	0.42	0.43	Yes	Yes				
	mg/m <sup>3</sup>	0.42	0.44	Yes	Yes				
Acceptability Limit	mg/m <sup>3</sup>	<1.50	<1.50						
Acetone Blank	mg	0.00	0.00						
	mg/m <sup>3</sup>	0.00	0.00						
	mg/m <sup>3</sup>	0.00	0.00						
	mg/m <sup>3</sup>	0.00	0.00						
Emission Limit:	mg/m <sup>3</sup>	15							
Test Detection limit:									
Particulates collected, (Mass):	mg	0.29	0.29						
Concentration at STP dry(Cm):	mg/m <sup>3</sup>	0.50	0.51						
Concentration at STP wet(Cw):	mg/m <sup>3</sup>	0.49	0.51						
Concentration at ref O2(C-CO2):	mg/m <sup>3</sup>	0.50	0.51						
Impinger weights:	g	Imp 1							
Before Test One:		580.0							
After Test One:		584.7							
H2O collected:		4.7	Moles H <sub>2</sub> O: 0.26						
Before Test Two:		584.7							
After Test Two:		589.8							
H2O collected:		5.1	Moles H <sub>2</sub> O: 0.28						
Test DGM readings:	l								
Before Test One:		235.62	Before Test Two: 822.16	Metric Millenium Inst					
After Test One:		815.63	After Test Two: 1388.34	Meter					
Sampled vol:		580.01	566.18						
% Isokinetic	Test One:		Test Two:						
Nozzle Dia:	"	0.3103	0.3103						
Nozzle >8mm Dia?		No	No						
Sampl time / point	mins	8	8						
Sample Duration:	mins	32	32						
Theoretical vol @ STP:	m <sup>3</sup>	0.571	0.552						
% Isokinetic:		101	In Range 102	In Range					
Number of traverses:		2	2						
Theoretical Number of Traverses:		2	2						
Theoretical Points / Traverse		2	2						
Acual Points / Traverse		2	2						
Standard Uncertainty	+/-	0.46	mg/m <sup>3</sup> 0.48						
Expanded Uncertainty:	+/-	0.93	mg/m <sup>3</sup> 0.97						
% of ELV		6.2	6.5						
Acceptable?		Yes	Yes						