

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Premises Shell Tankerton Person Seen Lu LIGBbe

Address 110 Cambridge Road Tankerton Hunstant

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

Tanks 5 has been Penum Filled tanks 6 & 7 no relabelled 5 and 6.

INSPECTION CONDUCTED ON BEHALF OF HUNTINGDON DISTRICT COUNCIL

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N _____ Satisfactory Y/N _____

Notes:
Nothing recorded
Schnorr controls did visual inspection 21/09/11. Adv annual maintenance (signs etc)

b) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES

Inspected Y/N _____ Satisfactory Y/N _____

Notes:
Not seen
EdS 17/05/2012 date of next test 17/05/15

c) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N _____ Satisfactory Y/N _____

Notes:
Nothing recorded
As stated previously please keep all VR docs together - file created at time of visit!

d) STAFF COMPETENCE & TRAINING

No of Staff No Questioned

Inspected Y/N _____ Satisfactory Y/N _____

Notes:
competent persons register to be updated
cashier was questioned.

e) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N _____ Satisfactory Y/N _____

Notes:
Two vents labelled as 4

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N _____

Notes:
Busy site

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes:
RA.

Signed [Signature]

Hannah. Slephed @ cambridgeshire.gov.uk
Tel /Email 01454 284628

Received by [Signature]

Date/Time 24/05/13 10:30

Reclassification notice issued. Two vents labelled as '4'

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.

Tel charging rect' notice letter to Ho sent 23/08/13 email to Ho /area manager sent 28/10/14. OFV 28/10/14