

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

129018-1

Premises KINGS CAME GARAGE Person Seen Vic.

Address CAMBRIDGE ROAD, ST NEOTS.

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:
As a result of the inspection of your premises your attention is drawn to the following matters:

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N _____ Satisfactory Y/N _____

Notes: SITE REGISTER

b) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES

Inspected Y/N _____ Satisfactory Y/N _____

Notes: 11/9/2014

c) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N _____ Satisfactory Y/N _____

Notes: MAINTENANCE RECORDS KEPT.

d) STAFF COMPETENCE & TRAINING

No of Staff 2 No Questioned 1

Inspected Y/N _____ Satisfactory Y/N _____

Notes: ALL OK AND CURRENT.

e) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N _____ Satisfactory Y/N _____

Notes: ALL OK AND TESTED 11/9/2014

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N _____

Notes: _____

Does the site have stage II vapour recovery? Y/N

Notes: —

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes: WILL RUN + MAINTAINED SITE

Signed [Signature]

Tel /Email alan.rose@cambridgeshire.gov.uk 01954 284621

Received by [Signature]

Date/Time 8/10/2014