


GRINDLE HOUSE,  
CHURCH LANE,  
CLYST ST MARY,  
EXETER, DEVON EX5 1AB  
TEL 01392 877770  
FAX 01392 874041



**AGGREGATE INDUSTRIES UK LIMITED  
A14 PROJECT  
ERMINE STREET  
GODMANCHESTER  
HUNTINGDON**



Environmental Protection Act  
Pollution Prevention & Control

**PARTICULATE EMISSION TEST  
(BS EN 13284-1:2017)**

on

**BENNINGHOVEN COATING PLANT  
BAG FILTER EXHAUST**

for

**AGGREGATE INDUSTRIES UK LIMITED  
A14 PROJECT  
ERMINE STREET  
GODMANCHESTER  
HUNTINGDON  
PE29 2NH**

**Report Prepared by:**

K Gough  
Company Principal

A Yelland  
Associate

Date Of Test : 02.12.19  
Date Of Report : 19.12.19  
Report No : 3175  
EPR No :

**CONTENTS**

<b>EXECUTIVE SUMMARY</b>	<b>4</b>
<b>1. BACKGROUND INFORMATION</b>	<b>5</b>
<b>2. MONITORING PROTOCOL</b>	<b>6</b>
2.1 Test method and references	6
2.2 Sampling procedure	6
2.3 Sampling equipment	6
2.4 Preparation for sampling	7
2.4.1 Filter preparation	7
2.4.2 Sampling location	7
2.5 Sample collection	8
2.6 Analysis of results	8
2.7 Calculation of results	9
2.8 Comments	9
<b>3. QUALITY ASSURANCE</b>	<b>10</b>
3.1 Location	10
3.2 Methods	11
3.3 Test team	12
<b>4. ON-SITE SUMMARY/MEASUREMENTS</b>	<b>13</b>
4.1 Preliminary stack survey	14
4.2 Leak check results	15
<b>5. SAMPLING RECORDS</b>	<b>16</b>
5.1 Process conditions	16
5.2 Sampling results	17
5.3 Calculations	18-21
5.4 Sample blank	22
5.5 Sampling Conditions	23
5.6 Weighing Results	24
<b>6. UNCERTAINTY CALCULATIONS</b>	<b>25-26</b>

## EXECUTIVE SUMMARY



EMISSIONS SUMMARY				
Determined	Units	Results	Uncertainty +/-	Limit
Particulate Concentration (STP)	mg/Nm <sup>3</sup>	36.54	1.11	50
Mass Emission (STP)	Kg/hr	1.55	0.05	-
Stack Temperature	°C	89	-	-
Gas Velocity	m/s	17.83	-	-
Stack Volume Flow Rate (Actual)	m <sup>3</sup> /hr	60996	-	-
Stack Volume Flow Rate (STP)	m <sup>3</sup> /hr	45503	-	-

All results are reported at reference conditions of 273K, 101.3kPa, wet gas.

MONITORING TIMES				
Determined	Sampling Date	Sampling Times	Sampling Duration	
Total Particulate Matter Run 1	02.12.19	13.32 - 14.04	32	minutes
Total Particulate Matter Run 2	02.12.19	14.10 - 14.42	32	minutes
Preliminary Stack Traverse	02.12.19	13.25	-	

PROCESS DETAILS	
Determined	Process Details
Process description	BENNINGHOVEN COATING PLANT
Continuous or Batch	Continuous - 20mm dense @ 150t.p.h.
Particulate type	Aggregate
Abatement	Bag Filter
Appearance of plume	Steam

MONITORING METHODS				
Determined	Method	Technical Procedure	Limit of Detection	Calculated MU +/-%
TPM	BS EN 13284-1	EL18	0.10	10.4%
Velocity	BS EN ISO 16911-1	EL20	-	-
Volumetric Flow	BS EN ISO 16911-1	EL20	-	-



## **1. BACKGROUND INFORMATION**

Particulate emission testing was undertaken by Advance Environmental Consulting Limited, on the roadstone coating plant dust collector exhaust at Aggregate Industries UK Limited, A14 Project, Godmanchester.

The purpose of the emission testing was to ensure compliance with the requirements of the permit issued by the Local Authority under The Environmental Permitting (England and Wales) Regulations 2010.



## 2. MONITORING PROTOCOL

### 2.1 Test Method and references

Isokinetic sampling of the contained emission sources was undertaken using the APEX Instruments Inc Method Five isokinetic sampling apparatus in accordance with the main procedural requirements within the following British Standards and Technical Guidance Notes:-

- \* BS EN 13284-1:2017 - Stationary source emissions. Determination of low range mass concentration of dust.
- \* Environment Agency - Technical Guidance Document (Monitoring) M1 Sampling requirements for monitoring stack emissions to air from industrial installations; and
- \* Environment Agency - Technical Guidance Document (Monitoring) M2 Monitoring of Stack Emissions to Air.

### 2.2 Sampling procedure

The work carried out was, as far as was reasonably practical, in accordance with BS EN 13284-1:2017.

Isokinetic flow means that sample gases laden with particulates are drawn off at the same velocity as the free stream velocity in the flue. Isokinetic sampling thus avoids possible inertial effects of particulates approaching the vicinity of the inlet nozzle which may result in significant


The Apex Instruments test equipment was designed to meet the sampling requirements of US EPA Method 5 and with a modified nozzle design, meets the sampling requirements of BS EN 13284-1.

The principle of the standard is to draw a known volume of dust laden gas isokinetically through a filter. The weight gain on the filter, after sampling, divided by the gas sample volume equates to the particulate concentration, which in turn can be used to calculate a mass emission.

### 2.3 Sampling equipment

The test equipment is inspected prior to use and its calibration status observed. This includes:-

- \* *Pitot Tube* - All pitot tubes are checked for damage, alignment and that there are no blockages;
- \* *Manometer* - Check of oil levels, connectors and orientation level



\* *Thermocouple* - Temperature is measured using k type thermocouples. Each thermocouple is inspected for calibration and damage. Digital temperature meters are used in conjunction with k type thermocouples which are also checked for calibration dates;

\* *Gas meter* - The calibration of the gas meter is checked before and after sampling using a critical orifice.

\* *Nozzles* - All nozzles used have been constructed in accordance with BS EN 13284-1. Each nozzle is checked for damaged and measured using a Vernier calliper on at least 3 planes. Non conforming nozzles will be rejected.

\* *Balance* - A Mettler Toledo balance is used to weigh filters. It is calibrated yearly by the manufacturer and checked daily by in-house weights.

\* *Filters* - Quartz membrane filters with a collection efficiency of >99.5% at 0.3micron:

## **2.4 Preparation for sampling**

### **2.4.1 Filter preparation**

Filters are pre-conditioned before arrival on site. The filters are dried in an oven at 180°C for a period of at least one hour and then placed to cool in a desiccator for at least four hours. The filters are then weighed on a five figure balance and placed in individual transport containers. Spare Filters are prepared to obtain blank values.

### **2.4.2 Sampling location**

No site visit was undertaken prior to undertaking the sampling procedure, as monitoring had previously been undertaken at the site, during which time the sampling position, working platform, sampling ports, access and safety precautions were found to be satisfactory.

The internal dimension of the flue was known from previous monitoring undertaken. However, further measurements were taken to check that the internal diameter had not changed.

Prior to sampling a pressure and temperature survey, using a pitot static tube, a micromanometer, a digital thermometer and a nickel-chromium/nickel-aluminium thermocouple, is carried out to check whether the flow conditions meet with the requirements of BS EN 16911. From this initial survey sample locations, isokinetic flow rates, nozzle size, and sample period can be worked out.



## 2.5 Sample collection

A leak check is carried out before and after sampling to confirm all the suction is drawn through the nozzle.

With the required isokinetic flow rates known the sample probe is inserted into the stack at 90° to the gas flow, this is to stop any particulate matter impinging on the filter before sampling.

The filter head and probe were allowed to obtain the stack gas temperature.

The initial gas meter reading was noted and the suction device and timer started. The correct flow rate for isokinetic sampling was set and the nozzle positioned to face parallel to the gas

Sampling was then carried out for the planned duration and number of sample points, recording all the necessary data for final calculations. On completion, the suction device and timer were stopped and the final gas meter volume recorded.

The probe was removed from the process stack and a further leak test carried out prior to removal of the filter, which was subsequently removed and placed in a storage container.

Any residual particulates upstream of the filter was washed with acetone into an appropriate beaker.\*In stack filter used no requirement for washing.

Repeat all of the above procedures to obtain duplicate samples.

At all times during the sampling procedure the sampling technicians were in contact with the process operator to ensure that the plant was in full production and there were no changes in the process that might affect the representative nature of the samples collected.

## 2.6 Analysis of samples

On returning to the laboratory, the used filters were dried in an oven at 160°C for a minimum of one hour and then desiccated and weighed as before. The water/acetone washings are first evaporated, without boiling, then dried and weighed as above. The total particulate mass is the sum of the differential filter weight added to the differential water/acetone rinsing's component.



## 2.7 Calculation of results

The calculations were made using the formula specified in BS EN 13284-1.

The recorded filter weights, velocity, temperature, sampling duration and internal flue dimensions were then used to calculate:-

- \* the mass rate of solids emission in kg/hr; and
- \* the solids concentration in  $\text{mg/m}^3$ .

## 2.8 Comments

On the completion of sampling, the data from the PCME 990 continuous emission monitor was interrogated and the average results, which were recorded during the measurement period, noted. A level of  $40.3\text{mg/m}^3$  was obtained together with an existing calibration factor of 1.0762. It can be concluded that the monitor would benefit from an adjustment of the current calibration factor to 0.9758.



### 3. QUALITY ASSURANCE

#### 3.1 Location

SAMPLING LOCATION					
Determined	Value	Units	Requirement	Compliant	Method
Lowest differential pressure	139	Pa	$\geq 5\text{Pa}$	Yes	BS EN 15259
Highest differential pressure	164	Pa	-	-	-
Ratio of gas pressures	1.2	Pa	$<9:1$	Yes	BS EN 15259
Mean gas velocity	17.8	m/s	-	-	-
Temperature deviation	3	K	$<10\%$	Yes	BS EN 13284
Max angle of flow	$<15$	$^{\circ}$	$<15^{\circ}$	Yes	BS EN 15259
No local negative flow	Yes	-	-	Yes	BS EN 15259

Duct Details		
	Value	Units
Shape	Circular	-
Depth	1.10	m
Width		m
Area	0.95	$\text{m}^2$
Port	0.09	m

Duct Details	
	Isokinetic
Sample port size	4" BSP
Number of lines used	2
Number of points/line	4
Duct orientation	Vertical
Filtration for TPM	In stack



### 3.2 Methods

MONITORING METHODS		
Determined	Method	Technical Procedure
TPM	Gravimetric	EL18
H2O	Gravimetric	EL5



### 3.3 Test Team

MONITORING TEAM						
Personnel	MCERTS Number	MCERTS		TE/H&S Qualifications		
		Level	Expiry	TE1	H&S	
Andrew Yelland	MM 02 130	MCERTS Level 2	Apr-23	Apr-23	Jul-24	



#### 4. ON-SITE SUMMARY/MEASUREMENTS

TOTAL PARTICULATE MATTER SUMMARY				
Determined	Sampling Times	Concentration mg/m <sup>3</sup>	Uncertainty mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>
Run 1	13.32 - 14.04	38.80	1.11	50
Run 2	14.10 - 14.42	34.28	0.97	50
Blank	-	0.10	-	-

FILTER SUMMARY					
Determined	Filter No	Filter Start Weight g	Filter Start Weight g	Acetone Rinse Weight g	Combined Mass Gained g
Run 1	1	0.05622	0.07497		0.01875
Run 2	2	0.05649	0.07280		0.01631
Blank	3	0.05616	0.05621		0.00005

STANDARD UNCERTAINTY SUMMARY				
Measured Quantities	Value	Standard uncertainty	Uncertainty %	Requirement of std
Sampled Volume - V <sub>m</sub>	0.5481	uV <sub>m</sub> 0.001 m <sup>3</sup>	0.18	<=2% Pass
Sampled gas Temp - T <sub>m</sub>	283	uT <sub>m</sub> 2 K	0.71	<=1% Pass
Sampled gas Pressure - p <sub>m</sub>	100.5	up <sub>m</sub> 0.5 kPa	0.50	<=1% Pass
Sampled gas Humidity - H <sub>m</sub>	6.41	uH <sub>m</sub> 1 % by vol	0.16	<=1% Pass
Oxygen content - O <sub>2,m</sub>	16.7	uO <sub>2,m</sub> 0.1 % by vol	0.60	<=5% Pass
Mass particulate - m	18.75	um 0.01 mg	0.05	0.04 <5% of limit val
Note - Sampled gas humidity, temperature and pressure are values at the gas meter				
Leak - L	0.48	%	0.48	<=2% Pass
Uncollected Mass - UCM (In stack filter - no rinse)	0.05	mg	0.27	<=10% Pass

MOISTURE SUMMARY					
RUN	Trap Start Weight g	Trap End Weight g	Difference g	Volume sampled m <sup>3</sup>	Bwo %
Run 1	538.4	565.1	26.7	0.4833	6.41
Run 2	540.3	566.7	26.4	0.4758	6.44



## 4.1 Preliminary stack survey

### On Site Velocity and Flow Data

Company	AGGREGATE INDUSTRIES UK LIMIT	Stack Diameter	1.10	m
Site	A14 PROJECT	Area	0.95	m <sup>2</sup>
Location	BENNINGHOVEN COATING PLANT	Sample points required	8	
Job No	3175	Barometric Pressure	100.4	kPa
Operators	AJY	Stack Pressure	0.06	kPa
		Pitot Tube Coefficient	0.997	

Preliminary readings taken before sampling				
	Pitot Traverse A		Pitot Traverse B	
Pitot Settings	D P pa	Temp °C	D P pa	Temp °C
1	149	90	139	89
2	153	91	145	89
3	156	91	151	90
4	158	91	154	90
5	161	91	157	90
6	163	91	159	90
7	160	90	162	89
8	157	90	164	89
9	154	90	157	89
10	148	90	144	88
Mean	156	91	153	89



## 4.2 Leak check results

PITOT LEAK CHECK						
Run	Pre traverse leak rate			Post traverse leak rate		
	Start value	End value	Difference	Start value	End value	Difference
	Pa	Pa	%	Pa	Pa	%
Run 1	250	250	Pass	250	250	Pass
Run 2	250	250	Pass	250	250	Pass

S-TYPE STAGNATION CHECK			
Run	Stagnation	Reference	Difference
	Pa	Pa	Permitted +/- 10 Pa
Run 1	43	43	Pass
Run 2	43	43	Pass

SAMPLE TRAIN LEAK CHECK					
Run	Mean Sampling	Pre-sampling	Post-sampling	Acceptable	Maximum
	Rate	Leak Rate	Leak Rate	Leak Rate	Leak Rate
	litres/min	litres/min	litres/min	litres/min	%
Run 1	20.91	0.10	0.10	0.42	Yes
Run 2	20.82	0.09	0.09	0.42	Yes

SAMPLE TRAIN LEAK CHECK				
Run	Blank	Emission Limit	Acceptable Blank	Blank Value
	Value	Value	Value	Acceptable
	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>	mg/m <sup>3</sup>
Blank 1	0.10	50	5	Yes



## 5. SAMPLING RECORDS

### 5.1 Process Conditions

Arrestment Plant:	Bag Filter
Particulate Type:	Aggregate
Plant Loading:	Continuous - 20mm dense @ 150t.p.h.
Appearance of plume:	Steam

## 5.2 Sampling Results

	Test Run No. 1.	Test Run No. 2.	Average
Time of Test:	13.32 - 14.04	14.10 - 14.42	
Sampling Duration: (mins)	32	32	
Gas Temperature (°C)	90	89	89
Mean Velocity at Sampling Points: (m/s)	17.75	17.67	17.71
Gas Flow Rate at STP (1): (m <sup>3</sup> /min)	707.0	705.5	706.2
Particulate Loading at STP (1): (mg/m <sup>3</sup> )	38.80	34.28	36.54
Particulate at Normalised Conditions (2): (mg/m <sup>3</sup> )	-----	-----	-----

(1) Particulate stated at 273K, 101.3kPa without correction for water vapour.

(2) State normalised conditions (e.g. 11% O<sub>2</sub> etc).

### 5.3 - Calculations Sample Run No. 1

#### On-site measurements

$$\begin{array}{lll} \text{O}_2 = & 16.7 \% & \text{CO}_2 = 2.4 \% & \text{N}_2 = 80.9 \% \\ \text{Bws} = & 0.05 & \text{Ps} = 100.5 \text{ kPa} & \text{Ts} = 362.6 \text{ K} \end{array}$$

$$\begin{aligned} \text{Md} &= \text{Molecular weight of gas at DGM (g/g mole)} \\ \text{Md} &= (0.44 \times \% \text{CO}_2) + (0.32 \times \% \text{O}_2) + (0.28 \times \% \text{N}_2) \\ &= 29.05 \text{ g/g mole} \end{aligned}$$

$$\begin{aligned} \text{Ms} &= \text{Molecular weight of gas wet (g/g mole)} \\ &= 28.50 \text{ g/g mole} \end{aligned}$$

#### Stack gas velocity at sample points

$$\begin{aligned} V &= K_p \times C_p \times \sqrt{(T_s \cdot DP / P_s \cdot M_s)} \\ &= 17.75 \text{ m/s} \end{aligned}$$

$$\begin{aligned} K_p &= 4.07 \\ DP &= 151.0 \text{ av. Dp at sample plane} \\ C_p &= 1.00 \text{ pitot tube coefficient} \end{aligned}$$

#### Stack gas volume at sample points

$$\begin{aligned} Q &= V \times A \times 60 \\ &= 1011.9 \text{ m}^3/\text{min} \end{aligned}$$

$$A = 0.95 \text{ area of stack m}^2$$

#### Volume of water vapour collected, standard conditions (m<sup>3</sup>)

$$\begin{aligned} V_{wstd} &= 0.00124 \times V_{lc} \\ &= 0.0331 \text{ m}^3 \end{aligned}$$

$$V_{lc} = 27 \text{ ml}$$

#### Volume of gas metered, standard conditions (m<sup>3</sup>)

$$\begin{aligned} V_{mstd} &= \frac{2.695 \times V_m \times (P_a + (DH/102)) \times Y_d}{(T + T_m)} \\ &= 0.4833 \text{ m}^3 \end{aligned}$$

$$\begin{aligned} T_m &= 10 \text{ }^\circ\text{C} \\ V_m &= 0.5481 \text{ m}^3 \\ P_a &= 100.4 \text{ kPa} \\ DH &= 24.9 \text{ mm H}_2\text{O} \\ Y_d &= 0.920 \end{aligned}$$

#### Moisture content

$$\begin{aligned} B_{wo} &= V_{wstd} / (V_{wstd} + V_{mstd}) \\ &= 0.0641 \end{aligned}$$

### 5.3 - Calculations Sample Run No. 1 Cont.

#### Dry total flow of stack gas, standard conditions (m<sup>3</sup>/min)

$$Q_{std} = \frac{Q \times P_s(2.695)(1 - B_{wo})}{T_s + 273}$$

$$= 707 \text{ m}^3/\text{min}$$

$$T_s = 89.6 \text{ }^\circ\text{C}$$

$$P_s = 100.5 \text{ kPa}$$

#### Percent isokinetic

$$\%I = \frac{(6.184 \times 10^5)(T_s + 273) \times V_{mstd}}{P_s \times V \times A_a \times t \times (1 - B_{wo})}$$

$$= 103.4 \%$$

$$A_a = 19.6 \text{ area of nozzle mm}^2$$

#### Filter & rinsing weights sample no. 1

$$\text{weight gain on filters} = 18.75 \text{ mg}$$

$$\text{weight of acetone wash} = \text{mg}$$

$$\text{total weight gain (M)} = 18.75 \text{ mg}$$

#### Particulate concentration (mg/m<sup>3</sup>)

$$C = M/V_{mstd}$$

$$= 38.80 \text{ mg/m}^3$$

$$M = 18.75 \text{ mg}$$

#### Particulate emission rate (kg/hr)

$$E = (C \times Q_{std} \times 60)/1000000$$

$$= 1.65 \text{ kg/hr}$$

#### 5.4 - Calculations Sample Run No. 2

##### On-site measurements

$$\begin{array}{lll} \text{O}_2 = & 16.7 \% & \text{CO}_2 = 2.4 \% & \text{N}_2 = 80.9 \% \\ \text{Bws} = & 0.06 & \text{Ps} = 100.5 \text{ kPa} & \text{Ts} = 361.8 \text{ K} \end{array}$$

$$\begin{aligned} \text{Md} &= \text{Molecular weight of gas at DGM (g/g mole)} \\ \text{Md} &= (0.44 \times \% \text{CO}_2) + (0.32 \times \% \text{O}_2) + (0.28 \times \% \text{N}_2) \\ &= 29.05 \text{ g/g mole} \end{aligned}$$

$$\begin{aligned} \text{Ms} &= \text{Molecular weight of gas wet (g/g mole)} \\ &= 28.34 \text{ g/g mole} \end{aligned}$$

##### Stack gas velocity at sample points

$$\begin{aligned} V &= K_p \times C_p \times \sqrt{(T_s \cdot DP / P_s \cdot M_s)} \\ &= 17.67 \text{ m/s} \end{aligned}$$

$$\begin{aligned} K_p &= 4.07 \\ DP &= 149.3 \text{ av. Dp at sample plane} \\ C_p &= 1.00 \text{ pitot tube coefficient} \end{aligned}$$

##### Stack gas volume at sample points

$$\begin{aligned} Q &= V \times A \times 60 \\ &= 1007.5 \text{ m}^3/\text{min} \end{aligned}$$

$$A = 0.95 \text{ area of stack m}^2$$

##### Volume of water vapour collected, standard conditions (m<sup>3</sup>)

$$\begin{aligned} V_{\text{wstd}} &= 0.00124 \times V_{\text{lc}} \\ &= 0.0327 \text{ m}^3 \end{aligned}$$

$$V_{\text{lc}} = 26 \text{ ml}$$

##### Volume of gas metered, standard conditions (m<sup>3</sup>)

$$V_{\text{mstd}} = \frac{2.695 \times V_{\text{m}} \times (P_{\text{a}} + (DH/102)) \times Y_{\text{d}}}{(T + T_{\text{m}})}$$

$$= 0.4758 \text{ m}^3$$

$$\begin{aligned} T_{\text{m}} &= 10 \text{ }^\circ\text{C} \\ V_{\text{m}} &= 0.5397 \text{ m}^3 \\ P_{\text{a}} &= 100.4 \text{ kPa} \\ DH &= 22 \text{ mm H}_2\text{O} \\ Y_{\text{d}} &= 0.920 \end{aligned}$$

##### Moisture content

$$\begin{aligned} B_{\text{wo}} &= V_{\text{wstd}} / (V_{\text{wstd}} + V_{\text{mstd}}) \\ &= 0.0644 \end{aligned}$$

#### 5.4 - Calculations Sample Run No. 2 Cont.

##### Dry total flow of stack gas, standard conditions (m<sup>3</sup>/min)

$$Q_{std} = \frac{Q \times P_s(2.695)(1 - B_{wo})}{T_s + 273}$$

$$= 705.5 \text{ m}^3/\text{min}$$

$$T_s = 88.8 \text{ }^\circ\text{C}$$

$$P_s = 100.5 \text{ kPa}$$

##### Percent isokinetic

$$\%I = \frac{(6.184 \times 10^5)(T_s + 273) \times V_{mstd}}{P_s \times V \times A_a \times t \times (1 - B_{wo})}$$

$$= 102.0 \%$$

$$A_a = 19.6 \text{ area of nozzle mm}^2$$

##### Filter & rinsing weights sample no. 2

$$\text{weight gain on filters} = 16.31 \text{ mg}$$

$$\text{weight of acetone wash} = \text{mg}$$

$$\text{total weight gain (M)} = 16.31 \text{ mg}$$

##### Particulate concentration (mg/m<sup>3</sup>)

$$C = M/V_{mstd}$$

$$= 34.28 \text{ mg/m}^3$$

$$M = 16.31 \text{ mg}$$

##### Particulate emission rate (kg/hr)

$$E = (C \times Q_{std} \times 60)/1000000$$

$$= 1.45 \text{ kg/hr}$$

## 5.5 - Sample Blank

An overall sample blank was taken after the measurement series, following the sampling procedure in the methodology without starting the suction device and keeping the blank in the duct for 15 minutes with the sampling nozzle 180° from the direction of flow. This leads to an estimation of the dispersion of results related to the whole procedure.

weight gain on filters = 0.00005 mg

weight of acetone wash = mg

total weight gain (M) = 0.00005 mg

### Particulate concentration (mg/m<sup>3</sup>)

$$C = M/V_{mstd}$$

$$M = 0.05 \text{ mg}$$

$$= 0.10 \text{ mg/m}^3$$



## 5.6 - Sampling Conditions

Sample Position	Sample Run No. 1			Sample Run No. 2		
	Stack Temp °C	Velocity Pressure DP (Pa)	Nozzle Area mm <sup>2</sup>	Stack Temp °C	Velocity Pressure DP (Pa)	Nozzle Area mm <sup>2</sup>
0.065D	90	149	19.6	89	146	19.6
0.25D	91	156	19.6	89	154	19.6
0.75D	90	157	19.6	90	155	19.6
0.935D	90	148	19.6	89	145	19.6
0.065D	89	139	19.6	89	141	19.6
0.25D	90	151	19.6	88	148	19.6
0.935D	89	164	19.6	88	163	19.6
0.935D	88	144	19.6	88	142	19.6

## 5.7 - Weighing Results

The below filters and acetone rinsing's were weighed on a balance in a temperature controlled room with corrections made for differences in atmospheric pressure. Control parts and blank filters are used to confirm accuracy of weighing's.

Sample Run No.1.	Ref No.	Weight gms			Sample time at each point (mins)	% weight gain
		Before	After	Collected		
Filter Acetone	1	0.05622	0.07497	0.01875	4.0	33.4%
<b>Total weight = 0.01875</b>						
Sample Run No.2.	Ref No.	Weight gms			Sample time at each point (mins)	
		Before	After	Collected		
Filter Acetone	2	0.05649	0.07280	0.01631	4.0	28.9%
<b>Total weight = 0.01631</b>						
Sample Blank	Ref No.	Weight gms			Sample time at each point (mins)	
		Before	After	Collected		
Filter Acetone	3	0.05616	0.05621	0.00005	n/a	0.1%
<b>Total weight = 0.00005</b>						

## 6. Uncertainty calculation for EN 13284-1:2017

Sample Run No. 1

Measurement Equation

Limit value	50	mg.m <sup>-3</sup>	O2 Ref	21	%
Measured conc.	38.80	mg.m <sup>-3</sup>			

$$c = \frac{m}{V} f_c$$

Measured Quantities	Symbol	Value	Standard uncertain	Units	Uncertainty %	Requirement of std
Sampled Volume	V <sub>m</sub>	0.5481	uV <sub>m</sub>	0.001 m <sup>3</sup>	0.18	<=2%
Sampled gas Tem	T <sub>m</sub>	283.0	uT <sub>m</sub>	2 K	0.71	<=1%
Sampled gas Pressure	p <sub>m</sub>	100.5	up <sub>m</sub>	0.5 kPa	0.50	<=1%
Sampled gas Humidity	H <sub>m</sub>	6.41	uH <sub>m</sub>	1 % by vol	0.16	<=1%
Oxygen content	O <sub>2,m</sub>	16.7	uO <sub>2,m</sub>	0.1 % by vol	0.60	<=5%
Mass particulate	m	18.75	um	0.01 mg	0	0.04 <5% of limit val
Note - Sampled gas humidity, temperature and pressure are values at the gas meter						
Leak	L	0.48		%	0.48	<=2%
Uncollected Mass (In stack filter - no rinse)	UCM	0.05		mg	0.27	<=10%

### Intermediate calculations

Factor for std conds	fs	0.88			
uncertainty components	symbol	sensitivity coeff	u (in units of fs)		
	p <sub>m</sub>	0.009	0.004		
	H <sub>m</sub>	0.009	0.009		
	T <sub>m</sub>	0.003	0.006		
	ufs		0.012		1.37
Corrected volume	V	0.48	uV	0.007 m <sup>3</sup>	V = V <sub>m</sub> f <sub>s</sub> 1.39
Factor for O2 correction	fc	1.00			
uncertainty components	symbol	sensitivity coeff	u		
	O <sub>2,m</sub>	0.23	0.023		
Factor for O2 Corr	ufc	1.00	0.023		1.00

Parameter	Uncertainty	Value	Units	ens coeff	Uncertainty in Resu	Uncertainty as %
Volume(stp)	V	0.48	m <sup>3</sup>	80.28	0.54 mg.m <sup>-3</sup>	1.39 %
Mass	m	18.75	mg	2.07	0.02 mg.m <sup>-3</sup>	0.05
Factor for O2 Correction	fc	1.00		0.00	0.00 mg.m <sup>-3</sup>	0.00 %
Leak	L	0.11	mg.m <sup>-3</sup>	1.00	0.11 mg.m <sup>-3</sup>	
Uncollected mass	UCM	0.03	mg	2.07	0.06 mg.m <sup>-3</sup>	
Combined uncertainty					0.55 mg.m <sup>-3</sup>	

Expanded uncertainty expressed with a level of confidence of 95%

2.85 %

Expanded uncertainty expressed with a level of confidence of 95%

1.11 mg.m<sup>-3</sup>

## 6. Uncertainty calculation for EN 13284-1:2017

Sample Run No. 2

Measurement Equation

Limit value	50	mg.m <sup>-3</sup>	O2 Ref	21	%
Measured conc.	34.28	mg.m <sup>-3</sup>			

$$c = \frac{m}{V} f_c$$

Measured Quantities	Symbol	Value	Standard uncertain	Units	Uncertainty %	Requirement of std
Sampled Volume	V <sub>m</sub>	0.5397	uV <sub>m</sub>	0.001 m <sup>3</sup>	0.19	<=2%
Sampled gas Tem	T <sub>m</sub>	283.0	uT <sub>m</sub>	2 K	0.71	<=1%
Sampled gas Pressure	p <sub>m</sub>	100.5	up <sub>m</sub>	0.5 kPa	0.50	<=1%
Sampled gas Humidity	H <sub>m</sub>	6.44	uH <sub>m</sub>	1 % by vol	0.16	<=1%
Oxygen content	O <sub>2,m</sub>	16.7	uO <sub>2,m</sub>	0.1 % by vol	0.60	<=5%
Mass particulate	m	16.31	um	0.01 mg	0	0.04 <5% of limit val
Note - Sampled gas humidity, temperature and pressure are values at the gas meter						
Leak	L	0.43		%	0.43	<=2%
Uncollected Mass	UCM	0.05		mg	0.31	<=10%
(In stack filter - no rinse)						

### Intermediate calculations

Factor for std conds	fs	0.88			
uncertainty components	symbol	sensitivity coeff	u (in units of fs)		
	p <sub>m</sub>	0.009	0.004		
	H <sub>m</sub>	0.009	0.009		
	T <sub>m</sub>	0.003	0.006		
	ufs		0.012		1.37
Corrected volume	V	0.48	uV	0.007 m <sup>3</sup>	V = V <sub>m</sub> f <sub>s</sub> 1.39
Factor for O2 correction	fc	1.00			
uncertainty components	symbol	sensitivity coeff	u		
	O <sub>2,m</sub>	0.23	0.023		
Factor for O2 Corr	ufc	1.00	0.023		1.00

$$f_s = \frac{(100 - H_m)}{100} \frac{273}{T_m} \frac{p_m}{101.3}$$

$$f_c = \frac{21 - O_{2,ref}}{21 - O_{2,m}}$$

Parameter	Uncertainty	Value	Units	ens coeff	Uncertainty in Resu	Uncertainty as %
Volume(stp)	V	0.48	m <sup>3</sup>	72.06	0.48 mg.m <sup>-3</sup>	1.39 %
Mass	m	16.31	mg	2.10	0.02 mg.m <sup>-3</sup>	0.06
Factor for O2 Correction	fc	1.00		0.00	0.00 mg.m <sup>-3</sup>	0.00 %
Leak	L	0.09	mg.m <sup>-3</sup>	1.00	0.09 mg.m <sup>-3</sup>	
Uncollected mass	UCM	0.00	mg	2.10	0.00 mg.m <sup>-3</sup>	
Combined uncertainty					0.48 mg.m <sup>-3</sup>	

Expanded uncertainty expressed with a level of confidence of 95%

2.83 %

Expanded uncertainty expressed with a level of confidence of 95%

0.97 mg.m<sup>-3</sup>

