



a division of Resource and Environmental Consultants Ltd

Client Xaarjet Ltd.
1 Hurricane Close
Ermine Business Park
Huntingdon
Cambridgeshire
PE29 6XX

Part 1: Executive Summary

Report for the Periodic Monitoring of Emissions to Air.

Site	Huntingdon
Plant	LEV 1
Sampling Date	15th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

Report Approved by:	Sign	
	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



1783

Tel: 0845 676 9303
Company Registration No 03133832



Contents

Page 1	Part 1: Executive Summary
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results, Exhaust Gases
Page 5	Operating Information
Page 5	Comments On Monitoring Procedures
Page 6	Part 2: Supporting Information
Page 7	Appendix 1
Page 8	Emission Monitoring Procedures and Instrumentation
Page 9	Sampling Personnel
Page 9	Equipment References
Page 10	Appendix 2
Page 11	Preliminary Velocity Traverse & Moisture Data
Page 12	Exhaust Gases - Continuous Analysis Data
Page 13	Chart 1 - Exhaust Gases
Page 14	Appendix 3
Page 15	Photograph of Sampling Location
Page 16	Generic Calculations
Page 17	Flow Calculations
Page 18	Concentration Calculation
Page 19	Uncertainty Estimate Calculations - Instrumental Techniques
Page 20	Appendix 4
Page 21	Uncertainty Estimates:- TOC

Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
LEV 1	Total organic carbon

Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow	TPM/01A	BS EN ISO 16911-1:2013
TOC	TPM/13	BS EN 12619 : 2013

Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Xaarjet Ltd.**
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at Huntingdon LEV 1		Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
		Date	Start	End	mg/m ³ *	mg/m ³ *	mg/m ³ *	mg/m ³ *	g/h
TOC	Test 1	15/01/15	11:30	12:00	53.0	75	1.70	0.16	154.8
TOC	Test 2	15/01/15	12:00	12:30	50.8	75	1.67	0.16	148.5
TOC	Test 3	15/01/15	12:30	13:00	41.8	75	1.52	0.16	121.9

* at ref	Stack Gas Weight	0 °C	Wet Gas
Conditions	29.00 Kg/kmol	101.3 kpa	Oxygen None %

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide
 TOC results are expressed as total carbon

Throughout Report: * Reference conditions (see above) Nm³ 273 K, 101.3 kPa
 ** Analysis not required # - UKAS accredited only
 ND Non detectable ## - Not Accredited
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



Operating Information

The tables below shows details of the operating information on each sampling date for: **LEV 1**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
15/01/2015	Production and cleaning of inkjet cartridges	Continuous	N/A	N/A	N/A	Normal

There are no CEMs present on this process

Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-
The homogeneity test is not applicable to non-combustion processes.

All monitoring was performed in accordance with the relevant procedures.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



a division of Resource and Environmental Consultants Ltd

Part 2: Supporting Information

Report for the Periodic Monitoring of Emissions to Air.

Client	Xaarjet Ltd.
Site	Huntingdon
Plant	LEV 1
Sampling Date	15th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

Report Approved by:	Sign		
	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



Tel: 0845 676 9303
Company Registration No 03133832

 a CONCEPT LIFE SCIENCES company

APPENDIX 1

Emission Monitoring Procedures And Instrumentation

Gas velocity and temperature

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013

Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

Total organic carbon

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013.

Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Report authorised by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Team leader:	Chris Rhodes	MM02 117	-	30/09/2017	28/02/2018	28/02/2018	31/08/2018	31/12/2018
Technician:	Tom Clarkson	MM02 120	-	-	-	-	-	-

Equipment References

Equipment	Reference Number
FID	VC09
Heated Line	HL24
Data Logger	DL14
Stack Thermocouple	PTTS138
Barometer	Met. Office
Pitot	PT138

APPENDIX 2

Date	15/01/2015
Time	10:30
Pitot Cp	1.02

Barometric pressure	98.5	kPa
Duct static pressure	-0.08	kPa
Stack Area	0.126	m ²
Oxygen		%

Stack Diameter (circular)	0.40	m
		m
		m
Carbon dioxide		%

Traverse Point	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s
1	A	5.0					B	5.0				
2	A	5.0					B	5.0				
3	A	5.0	5.5	21	<15	9.8	B	5.0				
4	A	7.1	3.5	21	<15	7.9	B	7.1				
5	A	10.0	2.9	21	<15	7.1	B	10.0				
6	A	14.2	3.4	21	<15	7.7	B	14.2				
7	A	25.8	3.0	21	<15	7.2	B	25.8				
8	A	30.0	1.9	21	<15	5.8	B	30.0				
9	A	32.9	2.0	21	<15	6.0	B	32.9				
10	A	35.0	1.9	21	<15	5.8	B	35.0				
11	A	35.0					B	35.0				
12	A	35.0					B	35.0				

Average Pitot DP	2.93	mmH ₂ O
Average Temperature	294.2	K
Average Velocity	7.2	m/s
Average volumetric flow rate	0.90	m ³ /s at stack conditions
Average volumetric flow rate	0.81	m ³ /s (wet STP)
Average volumetric flow rate		m ³ /s (dry STP)
Average volumetric flow rate		m ³ /s (dry, STP, reference oxygen concentraion)

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

a	Angel of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	5.8
	Maximum local gas velocity	9.8
	Ratio of highest to lowest local gas velocity	1.70

Date 15/01/2015

From 11:30 to 12:00 30 minute mean

Volatile organic compounds	vppm, wet	32.97	mg/m ³ *	52.99
----------------------------	-----------	-------	---------------------	-------

From 12:00 to 12:30 30 minute mean

Volatile organic compounds	vppm, wet	31.64	mg/m ³ *	50.84
----------------------------	-----------	-------	---------------------	-------

From 12:30 to 13:00 30 minute mean

Volatile organic compounds	vppm, wet	25.98	mg/m ³ *	41.75
----------------------------	-----------	-------	---------------------	-------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m ³ *	0.16
----------------------------	------	------	---------------------	------


Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VC174989	-	± 2
Volatile organic compounds	vppm	78.8	VC5MG4537	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	11:18	Final Time	13:08
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	78.80	-0.70	75.92

Chart 1 - Exhaust Gases, LEV 1, 15th January 2015



APPENDIX 3

Photograph Of The Sampling Location



LEV 1

General Calculations

Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

π = 3.142

Pressure conversion:

1mmH2O = 0.00980665 kPa

1mmH2O = 9.80665 Pa

1 mar = 0.1 kPa

Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m³ of water vapour in m³ of wet gas)

Vm(std) = Dry gas volume measured, corrected to standard conditions (m³)

mWC = Mass of water collected in the impingers (g)

Mw = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

Vmol(std) = Molar volume of water at standard conditions = 0.0224 (m³/mol)

Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

Vm(std) = Dry gas meter volume at standard conditions (m³)

yd = Gas meter calibration coefficient

(V2-V1) = Dry gas meter volume at actual conditions (m³)

Tm = Actual Temperature (K)

Tstd = Standard temperature (273 K)

pm = Absolute pressure at the gas meter (kPa)

pstd = Standard gas pressure (101.3 kPa)

Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

Flow Calculations

Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

\bar{v} = Average velocity (m/s)

C = velocity calculation constant = 129

T_s = Average stack temperature (K)

M_s = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

K = Pitot calibration coefficient

p_e = Absolute gas pressure (kPa)

Δp = Average pitot tube pressure differential (kPa)

Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

q_{va} = Average flow rate (m³/s)

\bar{v} = Average velocity (m/s)

A = Stack cross-sectional area (m²)

Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

H_a = Moisture at actual conditions (%volume)

H_m = Reference moisture (%volume)

Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

T_a = Temperature at actual conditions (K)

T_m = Reference Temperature (K)

p_a = Absolute gas pressure at actual conditions (kPa)

p_m = Reference pressure (kPa)

Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

$O_{2,m}$ = Actual oxygen concentration (%)

$O_{2,ref}$ = Reference oxygen concentration (%)

Concentration Calculations

Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

c = Concentration
 m = Mass of substance
 V = Volume sampled

Mass Emission

$$\text{Mass emission} = c \times q_m$$

c = Concentration
 q = Volume flow rate

Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

cm = Concentration at reference conditions
 ca = Actual concentration
 O_2, ref = Reference oxygen (%)
 O_2, a = Actual Oxygen (%)

Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

c_{wet} = Concentration wet gas
 c_{dry} = Concentration dry gas
 H_a = Water vapour content (%vol)

Conversion of parts per million (ppm) to mg/m³

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

C_{ppm}	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left(\frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$ is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:
 $S_{r,0}$ is the standard uncertainty at zero level
 $S_{r,s}$ is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:
 $u(Corr_{loss})$ is the uncertainty due to losses in sample line
 $u(Corr_{cal})$ is the uncertainty due to losses in sample line
 $C_{j,loss}$ is the concentration of sample loss at span level
 U_{cal} is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:
 c_j is the sensitivity coefficient of the influence quantity
 $x_{j,min}$ is the minimum value of the influence quantity during monitoring
 $x_{j,max}$ is the maximum value of the influence quantity during monitoring
 $x_{j,adj}$ is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:
 c_j is the sensitivity coefficient of the interferent j
 $Int_{j,test}$ is the concentration of the interferent j used to determine c_j
 $Int_{j,min}$ is the minimum value of the interferent j quantity during monitoring
 $Int_{j,max}$ is the maximum value of the interferent j quantity during monitoring
 $Int_{j,adj}$ is the concentration of the interferent j in the cal gas used to adjust the analyser
 $S_{int,p}$ is the sum of interferences with positive impact
 $S_{int,n}$ is the sum of interferences with negative impact

Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2) $U(C_m) = u(C_m) \times k$

Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:
 C_{NOx} is the concentration of NOx measured by the analyser
 R is the ratio of NO:Nox in the stack gas
 η is the NOx converter efficiency

Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left(\frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O ₂ ref. concentration	in	mg/m ³
$C_{O_2,ref}$	=	mass concentration at O ₂ reference concentration	in	mg/m ³
$O_{2,meas}$	=	O ₂ measured concentration	in	% volume
$u((O_{2,meas})_{dry})$	=	uncertainty associated to the measured O ₂ concentration	in	% (relative to O _{2,meas})

APPENDIX 4

Uncertainty Estimate For The Measurement Of Total Organic Carbon BS EN12619:2013

Analysers Type/Model Sick Maihak
 Reference Oxygen % 0 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m ³	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	33.0	31.6	26.0
Measured concentration	mg/m ³	53.0	50.8	41.8
Concentration at O ₂ ref. concentration	mg/m ³	N/A	N/A	N/A

Calibration gas	ppm	78.8	78.8	78.8
Calibration gas	mg/m ³	126.6	126.6	126.6
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m ³	15.0	15.0	15.0

Correction of Lack of Fit				
Lack of fit	% range	2.0	2.0	2.0
	u(Corr _{lof})	0.11	0.11	0.11

Corrections of Zero and Span Drift (*All drift is calculated for ∴ the residual is assumed to be < 5% u(max))				
Zero Drift	% range	0.00	0.00	0.00
	u(Corr _{zdr})	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr _{spd})	0.00	0.00	0.00

Correction of Repeatability of Measurement				
Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr _{rpb})	0.00	0.00	0.00

Correction of adjustment				
Losses in the line	% range	1.04	1.04	1.04
	u(Corr _{loss})	0.20	0.19	0.16
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr _{cbl})	0.33	0.32	0.26

Correction of Influence of Interferents				
N ₂ O	% range			
	u(Corr _{N2O})	0.00	0.00	0.00
CO ₂	% range			
	u(Corr _{CO2})	0.00	0.00	0.00
CH ₄	% range			
	u(Corr _{CH4})	0.00	0.00	0.00
Total of interferent influences u(ΣCorr _{int}) = max[S _{int,p} · S _{int,n}]	% range	2.50	2.50	2.50
	u(ΣCorr _{int})	0.16	0.16	0.16

Correction of Influence Quantities				
Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr _{flow})	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr _{press})	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr _{temp})	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr _{volt})	0.10	0.10	0.10

Oxygen reference concentration				
Measured oxygen	%	#DIV/0!	#DIV/0!	#DIV/0!
Overall uncertainty of O ₂ measurement	U(O _{2,meas})	#REF!	#REF!	#REF!
	u(Corr _{O2})	N/A	N/A	N/A

Maximum standard uncertainty	u(Corr _{max})	0.33	0.32	0.26
5% of maximum standard uncertainty	u(Corr _{5%})	0.02	0.02	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH ₄ range	0	10	0	50	mg/m ³
N ₂ O range	0	0	0	20	mg/m ³
CO ₂ range	8	12	0	15	mg/m ³
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m ³

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty		Test 1	Test 2	Test 3
Combined uncertainty	ppm	0.53	0.52	0.47
Combined uncertainty	mg/m ³	0.85	0.83	0.76
Combined uncertainty at oxygen reference	mg/m ³	0.85	0.83	0.76

Expanded uncertainty expressed with a level of confidence of 95%, k=2				
Overall uncertainty	ppm	1.1	1.0	0.9
Overall uncertainty	mg/m ³	1.7	1.7	1.5
Overall uncertainty relative to measured value	%	3.2	3.3	3.7
Overall uncertainty relative to range	%	11.4	11.1	10.2
Overall uncertainty relative to ELV	%	1.3	1.3	1.2

Expanded uncertainty at oxygen reference conditions expressed with a level of confidence of 95%, k=2				
Overall uncertainty	mg/m ³	N/A	N/A	N/A
Overall uncertainty relative to measured value	%	N/A	N/A	N/A
Overall uncertainty relative to range	%	N/A	N/A	N/A
Overall uncertainty relative to ELV	%	N/A	N/A	N/A

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



a division of Resource and Environmental Consultants Ltd

Client Xaarjet Ltd.
1 Hurricane Close
Ermine Business Park
Huntingdon
Cambridgeshire
PE29 6XX

Part 1: Executive Summary

Report for the Periodic Monitoring of Emissions to Air.

Site	Huntingdon
Plant	LEV 2
Sampling Date	15th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

Report Approved by:	Sign	
	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



1783

Tel: 0845 676 9303
Company Registration No 03133832



Contents

Page 1	Part 1: Executive Summary
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results, Exhaust Gases
Page 5	Operating Information
Page 5	Comments On Monitoring Procedures
Page 6	Part 2: Supporting Information
Page 7	Appendix 1
Page 8	Emission Monitoring Procedures and Instrumentation
Page 9	Sampling Personnel
Page 9	Equipment References
Page 10	Appendix 2
Page 11	Preliminary Velocity Traverse & Moisture Data
Page 12	Exhaust Gases - Continuous Analysis Data
Page 13	Chart 1 - Exhaust Gases
Page 14	Appendix 3
Page 15	Photograph of Sampling Location
Page 16	Generic Calculations
Page 17	Flow Calculations
Page 18	Concentration Calculation
Page 19	Uncertainty Estimate Calculations - Instrumental Techniques
Page 20	Appendix 4
Page 21	Uncertainty Estimates:- TOC

Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
LEV 2	Total organic carbon

Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow	TPM/01A	BS EN ISO 16911-1:2013
TOC	TPM/13	BS EN 12619 : 2013

Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Xaarjet Ltd.**
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at Huntingdon LEV 2		Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
		Date	Start	End	mg/m ³ *	mg/m ³ *	mg/m ³ *	mg/m ³ *	g/h
TOC	Test 1	15/01/15	11:30	12:00	11.9	75	1.23	0.16	16.8
TOC	Test 2	15/01/15	12:00	13:03	7.34	75	1.19	0.16	10.4
TOC	Test 3	15/01/15	13:03	13:33	5.54	75	1.18	0.16	7.85

* at ref Conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kpa	Wet Gas Oxygen None %
------------------------	-----------------------------------	-------------------	--------------------------

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide
 TOC results are expressed as total carbon

Throughout Report: * Reference conditions (see above) Nm³ 273 K, 101.3 kPa
 ** Analysis not required # - UKAS accredited only
 ND Non detectable ## - Not Accredited
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



Operating Information

The tables below shows details of the operating information on each sampling date for: **LEV 2**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
15/01/2015	Production and cleaning of inkjet cartridges	Continuous	N/A	N/A	N/A	Normal

There are no CEMs present on this process

Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-
The homogeneity test is not applicable to non-combustion processes.

All monitoring was performed in accordance with the relevant procedures.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.

The data logger lead was not working between 12:22 and 12:55, this data was removed from the test.



a division of Resource and Environmental Consultants Ltd

Part 2: Supporting Information

Report for the Periodic Monitoring of Emissions to Air.

Client	Xaarjet Ltd.
Site	Huntingdon
Plant	LEV 2
Sampling Date	15th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

Report Approved by:	Sign		
	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

REC Environmental Monitoring
 10 Broad Lane
 Moldgreen
 Huddersfield
 HD5 9BX



Tel: 0845 676 9303
 Company Registration No 03133832



APPENDIX 1

Emission Monitoring Procedures And Instrumentation

Gas velocity and temperature

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013
Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

Total organic carbon

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013.
Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Report authorised by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Team leader:	Chris Rhodes	MM02 117	-	30/09/2017	28/02/2018	28/02/2018	31/08/2018	31/12/2018
Technician:	Tom Clarkson	MM02 120	-	-	-	-	-	-

Equipment References

Equipment	Reference Number
FID	VC12
Heated Line	HL24
Data Logger	DL14
Stack Thermocouple	PTTS138
Barometer	Met. Office
Pitot	PT138

APPENDIX 2

Date	15/01/2015
Time	10:00
Pitot Cp	1.02

Barometric pressure	98.5	kPa
Duct static pressure	-0.14	kPa
Stack Area	0.073	m ²
Oxygen		%

Stack Diameter (circular)	0.305	m
		m
		m
Carbon dioxide		%

Traverse Point	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s
1	A	5.0					B	5.0				
2	A	5.0					B	5.0				
3	A	5.0	3.7	22	<15	8.0	B	5.0				
4	A	5.4	3.5	22	<15	7.9	B	5.4				
5	A	7.6	2.1	22	<15	6.0	B	7.6				
6	A	10.9	1.8	22	<15	5.6	B	10.9				
7	A	19.6	2.2	22	<15	6.2	B	19.6				
8	A	22.9	1.6	22	<15	5.2	B	22.9				
9	A	25.1	1.3	22	<15	4.8	B	25.1				
10	A	25.5	1.0	22	<15	4.2	B	25.5				
11	A	25.5					B	25.5				
12	A	25.5					B	25.5				

Average Pitot DP	2.04	mmH ₂ O
Average Temperature	295.2	K
Average Velocity	6.0	m/s
Average volumetric flow rate	0.44	m ³ /s at stack conditions
Average volumetric flow rate	0.39	m ³ /s (wet STP)
Average volumetric flow rate		m ³ /s (dry STP)
Average volumetric flow rate		m ³ /s (dry, STP, reference oxygen concentraion)

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

a	Angel of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	4.2
	Maximum local gas velocity	8.0
	Ratio of highest to lowest local gas velocity	1.93

Date 15/01/2015

From 11:30 to 12:00 30 minute mean

Volatile organic compounds	vppm, wet	7.41	mg/m ³ *	11.90
----------------------------	-----------	------	---------------------	-------

From 12:00 to 13:03 30 minute mean

Volatile organic compounds	vppm, wet	4.57	mg/m ³ *	7.34
----------------------------	-----------	------	---------------------	------

From 13:03 to 13:33 30 minute mean

Volatile organic compounds	vppm, wet	3.45	mg/m ³ *	5.54
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m ³ *	0.16
----------------------------	------	------	---------------------	------


Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VC174989	-	± 2
Volatile organic compounds	vppm	78.8	VCSMG4537	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	11:18	Final Time	13:39
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	78.79	-0.71	79.44

Chart 1 - Exhaust Gases, LEV 2, 15th January 2015



APPENDIX 3

Photograph Of The Sampling Location



LEV 2

General Calculations

Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

π = 3.142

Pressure conversion:

1mmH2O = 0.00980665 kPa

1mmH2O = 9.80665 Pa

1 mar = 0.1 kPa

Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m³ of water vapour in m³ of wet gas)

Vm(std) = Dry gas volume measured, corrected to standard conditions (m³)

mWC = Mass of water collected in the impingers (g)

Mw = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

Vmol(std) = Molar volume of water at standard conditions = 0.0224 (m³/mol)

Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

Vm(std) = Dry gas meter volume at standard conditions (m³)

yd = Gas meter calibration coefficient

(V2-V1) = Dry gas meter volume at actual conditions (m³)

Tm = Actual Temperature (K)

Tstd = Standard temperature (273 K)

pm = Absolute pressure at the gas meter (kPa)

pstd = Standard gas pressure (101.3 kPa)

Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

Flow Calculations

Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

\bar{v} = Average velocity (m/s)

C = velocity calculation constant = 129

T_s = Average stack temperature (K)

M_s = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

K = Pitot calibration coefficient

p_e = Absolute gas pressure (kPa)

Δp = Average pitot tube pressure differential (kPa)

Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

q_{va} = Average flow rate (m³/s)

\bar{v} = Average velocity (m/s)

A = Stack cross-sectional area (m²)

Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

H_a = Moisture at actual conditions (%volume)

H_m = Reference moisture (%volume)

Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

T_a = Temperature at actual conditions (K)

T_m = Reference Temperature (K)

p_a = Absolute gas pressure at actual conditions (kPa)

p_m = Reference pressure (kPa)

Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

$O_{2,m}$ = Actual oxygen concentration (%)

$O_{2,ref}$ = Reference oxygen concentration (%)

Concentration Calculations

Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

c = Concentration
 m = Mass of substance
 V = Volume sampled

Mass Emission

$$\text{Mass emission} = c \times q_m$$

c = Concentration
 q = Volume flow rate

Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

cm = Concentration at reference conditions
 ca = Actual concentration
 $O_{2, ref}$ = Reference oxygen (%)
 $O_{2, a}$ = Actual Oxygen (%)

Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

c_{wet} = Concentration wet gas
 c_{dry} = Concentration dry gas
 H_a = Water vapour content (%vol)

Conversion of parts per million (ppm) to mg/m³

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

C_{ppm}	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left(\frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$ is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:
 $S_{r,0}$ is the standard uncertainty at zero level
 $S_{r,s}$ is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:
 $u(Corr_{loss})$ is the uncertainty due to losses in sample line
 $u(Corr_{cal})$ is the uncertainty due to losses in sample line
 $C_{j,loss}$ is the concentration of sample loss at span level
 U_{cal} is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:
 c_j is the sensitivity coefficient of the influence quantity
 $x_{j,min}$ is the minimum value of the influence quantity during monitoring
 $x_{j,max}$ is the maximum value of the influence quantity during monitoring
 $x_{j,adj}$ is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:
 c_j is the sensitivity coefficient of the interferent j
 $Int_{j,test}$ is the concentration of the interferent j used to determine c_j
 $Int_{j,min}$ is the minimum value of the interferent j quantity during monitoring
 $Int_{j,max}$ is the maximum value of the interferent j quantity during monitoring
 $Int_{j,adj}$ is the concentration of the interferent j in the cal gas used to adjust the analyser
 $S_{int,p}$ is the sum of interferences with positive impact
 $S_{int,n}$ is the sum of interferences with negative impact

Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2) $U(C_m) = u(C_m) \times k$

Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:
 C_{NOx} is the concentration of NOx measured by the analyser
 R is the ratio of NO:Nox in the stack gas
 η is the NOx converter efficiency

Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left(\frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O ₂ ref. concentration	in	mg/m ³
$C_{O_2,ref}$	=	mass concentration at O ₂ reference concentration	in	mg/m ³
$O_{2,meas}$	=	O ₂ measured concentration	in	% volume
$u((O_{2,meas})_{dry})$	=	uncertainty associated to the measured O ₂ concentration	in	% (relative to O _{2,meas})

APPENDIX 4

Uncertainty Estimate For The Measurement Of Total Organic Carbon BS EN12619:2013

Analysers Type/Model Sick Maihak
 Reference Oxygen % 0 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m ³	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	7.4	4.6	3.4
Measured concentration	mg/m ³	11.9	7.3	5.5
Concentration at O ₂ ref. concentration	mg/m ³	N/A	N/A	N/A

Calibration gas	ppm	78.8	78.8	78.8
Calibration gas	mg/m ³	126.6	126.6	126.6
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m ³	15.0	15.0	15.0

Correction of Lack of Fit				
Lack of fit	% range	2.0	2.0	2.0
	u(Corr _{lof})	0.11	0.11	0.11

Corrections of Zero and Span Drift (*All drift is calculated for ∴ the residual is assumed to be < 5% u(max))				
Zero Drift	% range	0.00	0.00	0.00
	u(Corr _{zdr})	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr _{spd})	0.00	0.00	0.00

Correction of Repeatability of Measurement				
Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr _{rpb})	0.00	0.00	0.00

Correction of adjustment				
Losses in the line	% range	1.97	1.97	1.97
	u(Corr _{loss})	0.08	0.05	0.04
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr _{cbl})	0.07	0.05	0.03

Correction of Influence of Interferents				
N ₂ O	% range			
	u(Corr _{N2O})	0.00	0.00	0.00
CO ₂	% range			
	u(Corr _{CO2})	0.00	0.00	0.00
CH ₄	% range			
	u(Corr _{CH4})	0.00	0.00	0.00
Total of interferent influences u(ΣCorr _{int}) = max[S _{int,p} · S _{int,n}]	% range	2.50	2.50	2.50
	u(ΣCorr _{int})	0.16	0.16	0.16

Correction of Influence Quantities				
Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr _{flow})	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr _{press})	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr _{temp})	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr _{volt})	0.10	0.10	0.10

Oxygen reference concentration				
Measured oxygen	%	#DIV/0!	#DIV/0!	#DIV/0!
Overall uncertainty of O ₂ measurement	U(O _{2,meas})	#REF!	#REF!	#REF!
	u(Corr _{O2})	N/A	N/A	N/A

Maximum standard uncertainty	u(Corr _{max})	0.11	0.11	0.11
5% of maximum standard uncertainty	u(Corr _{5%})	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH ₄ range	0	10	0	50	mg/m ³
N ₂ O range	0	0	0	20	mg/m ³
CO ₂ range	8	12	0	15	mg/m ³
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m ³

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty				
Combined uncertainty	ppm	0.38	0.37	0.37
	mg/m ³	0.61	0.60	0.59
Combined uncertainty at oxygen reference	mg/m ³	0.61	0.60	0.59

Expanded uncertainty expressed with a level of confidence of 95%, k=2				
Overall uncertainty	ppm	0.8	0.7	0.7
Overall uncertainty	mg/m ³	1.2	1.2	1.2
Overall uncertainty relative to measured value	%	10.3	16.2	21.4
Overall uncertainty relative to range	%	8.2	8.0	7.9
Overall uncertainty relative to ELV	%	1.0	0.9	0.9

Expanded uncertainty at oxygen reference conditions expressed with a level of confidence of 95%, k=2				
Overall uncertainty	mg/m ³	N/A	N/A	N/A
Overall uncertainty relative to measured value	%	N/A	N/A	N/A
Overall uncertainty relative to range	%	N/A	N/A	N/A
Overall uncertainty relative to ELV	%	N/A	N/A	N/A

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



a division of Resource and Environmental Consultants Ltd

Client Xaarjet Ltd.
1 Hurricane Close
Ermine Business Park
Huntingdon
Cambridgeshire
PE29 6XX

Part 1: Executive Summary

Report for the Periodic Monitoring of Emissions to Air.

Site	Huntingdon
Plant	LEV 9
Sampling Date	16th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

Report Approved by:	Sign	
	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



1783

Tel: 0845 676 9303
Company Registration No 03133832



Contents

Page 1	Part 1: Executive Summary
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results, Exhaust Gases
Page 5	Operating Information
Page 5	Comments On Monitoring Procedures
Page 6	Part 2: Supporting Information
Page 7	Appendix 1
Page 8	Emission Monitoring Procedures and Instrumentation
Page 9	Sampling Personnel
Page 9	Equipment References
Page 10	Appendix 2
Page 11	Preliminary Velocity Traverse & Moisture Data
Page 12	Exhaust Gases - Continuous Analysis Data
Page 13	Chart 1 - Exhaust Gases
Page 14	Appendix 3
Page 15	Photograph of Sampling Location
Page 16	Generic Calculations
Page 17	Flow Calculations
Page 18	Concentration Calculation
Page 19	Uncertainty Estimate Calculations - Instrumental Techniques
Page 20	Appendix 4
Page 21	Uncertainty Estimates:- TOC

Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
LEV 9	Total organic carbon

Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow	TPM/01A	BS EN ISO 16911-1:2013
TOC	TPM/13	BS EN 12619 : 2013

Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Xaarjet Ltd.**
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at Huntingdon LEV 9		Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
		Date	Start	End	mg/m ³ *	mg/m ³ *	mg/m ³ *	mg/m ³ *	g/h
TOC	Test 1	16/01/15	09:50	10:20	31.2	75	1.36	0.16	68.7
TOC	Test 2	16/01/15	10:20	10:50	42.1	75	1.49	0.16	92.6
TOC	Test 3	16/01/15	11:35	12:05	77.6	75	2.07	0.16	170.8

* at ref	Stack Gas Weight	0 °C	Wet Gas
Conditions	29.00 Kg/kmol	101.3 kpa	Oxygen None %

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide
 TOC results are expressed as total carbon

Throughout Report: * Reference conditions (see above) Nm³ 273 K, 101.3 kPa
 ** Analysis not required # - UKAS accredited only
 ND Non detectable ## - Not Accredited
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



Operating Information

The tables below shows details of the operating information on each sampling date for: **LEV 9**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
16/01/2015	Production and cleaning of inkjet cartridges	Continuous	N/A	N/A	N/A	Normal

There are no CEMs present on this process

Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-
The homogeneity test is not applicable to non-combustion processes.

All monitoring was performed in accordance with the relevant procedures.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



a division of Resource and Environmental Consultants Ltd

Part 2: Supporting Information

Report for the Periodic Monitoring of Emissions to Air.

Client	Xaarjet Ltd.
Site	Huntingdon
Plant	LEV 9
Sampling Date	16th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

Report Approved by:	Sign	
	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

REC Environmental Monitoring
 10 Broad Lane
 Moldgreen
 Huddersfield
 HD5 9BX



Tel: 0845 676 9303
 Company Registration No 03133832



APPENDIX 1

Emission Monitoring Procedures And Instrumentation

Gas velocity and temperature

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013
Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

Total organic carbon

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013.
Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Report authorised by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Team leader:	Chris Rhodes	MM02 117	-	30/09/2017	28/02/2018	28/02/2018	31/08/2018	31/12/2018
Technician:	Tom Clarkson	MM02 120	-	-	-	-	-	-

Equipment References

Equipment	Reference Number
FID	VC09
Heated Line	HL24
Data Logger	DL14
Stack Thermocouple	PTTS138
Barometer	Met. Office
Pitot	PT138

APPENDIX 2

Date	16/01/2015
Time	09:00
Pitot Cp	1.02

Barometric pressure	100.4	kPa
Duct static pressure	0.97	kPa
Stack Area	0.071	m ²
Oxygen		%

Stack Diameter (circular)	0.30	m
		m
		m
Carbon dioxide		%

Traverse Point	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s
1	A	5.0					B	5.0				
2	A	5.0					B	5.0				
3	A	5.0					B	5.0				
4	A	5.3	2.7	20	<15	6.7	B	5.3				
5	A	7.5	3.7	20	<15	7.9	B	7.5				
6	A	10.7	4.9	20	<15	9.1	B	10.7				
7	A	19.3	6.0	20	<15	10.1	B	19.3				
8	A	22.5	6.3	20	<15	10.3	B	22.5				
9	A	24.7	7.8	20	<15	11.5	B	24.7				
10	A	25.0					B	25.0				
11	A	25.0					B	25.0				
12	A	25.0					B	25.0				

Average Pitot DP	5.08	mmH ₂ O
Average Temperature	293.2	K
Average Velocity	9.3	m/s
Average volumetric flow rate	0.66	m ³ /s at stack conditions
Average volumetric flow rate	0.61	m ³ /s (wet STP)
Average volumetric flow rate		m ³ /s (dry STP)
Average volumetric flow rate		m ³ /s (dry, STP, reference oxygen concentraion)

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

a	Angel of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	6.7
	Maximum local gas velocity	11.5
	Ratio of highest to lowest local gas velocity	1.72

Date 16/01/2015

From 09:50 to 10:20 30 minute mean

Volatile organic compounds	vppm, wet	19.43	mg/m ³ *	31.23
----------------------------	-----------	-------	---------------------	-------

From 10:20 to 10:50 30 minute mean

Volatile organic compounds	vppm, wet	26.19	mg/m ³ *	42.09
----------------------------	-----------	-------	---------------------	-------

From 11:35 to 12:05 30 minute mean

Volatile organic compounds	vppm, wet	48.30	mg/m ³ *	77.63
----------------------------	-----------	-------	---------------------	-------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m ³ *	0.16
----------------------------	------	------	---------------------	------


Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VC174989	-	± 2
Volatile organic compounds	vppm	78.8	VCSMG4537	100	± 2

Zero And Span Gas Details


Species	units	Initial Time	09:27	Final Time	12:30
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	78.80	-0.49	80.46

Chart 1 - Exhaust Gases, LEV 9, 16th January 2015



APPENDIX 3

Photograph Of The Sampling Location



General Calculations

Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

π = 3.142

Pressure conversion:

1mmH2O = 0.00980665 kPa

1mmH2O = 9.80665 Pa

1 mar = 0.1 kPa

Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m³ of water vapour in m³ of wet gas)

Vm(std) = Dry gas volume measured, corrected to standard conditions (m³)

mWC = Mass of water collected in the impingers (g)

Mw = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

Vmol(std) = Molar volume of water at standard conditions = 0.0224 (m³/mol)

Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

Vm(std) = Dry gas meter volume at standard conditions (m³)

yd = Gas meter calibration coefficient

(V2-V1) = Dry gas meter volume at actual conditions (m³)

Tm = Actual Temperature (K)

Tstd = Standard temperature (273 K)

pm = Absolute pressure at the gas meter (kPa)

pstd = Standard gas pressure (101.3 kPa)

Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

Flow Calculations

Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

\bar{v} = Average velocity (m/s)

C = velocity calculation constant = 129

T_s = Average stack temperature (K)

M_s = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

K = Pitot calibration coefficient

p_e = Absolute gas pressure (kPa)

Δp = Average pitot tube pressure differential (kPa)

Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

q_{va} = Average flow rate (m³/s)

\bar{v} = Average velocity (m/s)

A = Stack cross-sectional area (m²)

Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

H_a = Moisture at actual conditions (%volume)

H_m = Reference moisture (%volume)

Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

T_a = Temperature at actual conditions (K)

T_m = Reference Temperature (K)

p_a = Absolute gas pressure at actual conditions (kPa)

p_m = Reference pressure (kPa)

Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

$O_{2,m}$ = Actual oxygen concentration (%)

$O_{2,ref}$ = Reference oxygen concentration (%)

Concentration Calculations

Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

c = Concentration
 m = Mass of substance
 V = Volume sampled

Mass Emission

$$\text{Mass emission} = c \times q_m$$

c = Concentration
 q = Volume flow rate

Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

cm = Concentration at reference conditions
 ca = Actual concentration
 O_2, ref = Reference oxygen (%)
 O_2, a = Actual Oxygen (%)

Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

c_{wet} = Concentration wet gas
 c_{dry} = Concentration dry gas
 H_a = Water vapour content (%vol)

Conversion of parts per million (ppm) to mg/m³

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{k_{0,dr}} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

C_{ppm}	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left(\frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$ is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:
 $S_{r,0}$ is the standard uncertainty at zero level
 $S_{r,s}$ is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:
 $u(Corr_{loss})$ is the uncertainty due to losses in sample line
 $u(Corr_{cal})$ is the uncertainty due to losses in sample line
 $C_{j,loss}$ is the concentration of sample loss at span level
 U_{cal} is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:
 c_j is the sensitivity coefficient of the influence quantity
 $x_{j,min}$ is the minimum value of the influence quantity during monitoring
 $x_{j,max}$ is the maximum value of the influence quantity during monitoring
 $x_{j,adj}$ is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:
 c_j is the sensitivity coefficient of the interferent j
 $Int_{j,test}$ is the concentration of the interferent j used to determine c_j
 $Int_{j,min}$ is the minimum value of the interferent j quantity during monitoring
 $Int_{j,max}$ is the maximum value of the interferent j quantity during monitoring
 $Int_{j,adj}$ is the concentration of the interferent j in the cal gas used to adjust the analyser
 $S_{int,p}$ is the sum of interferences with positive impact
 $S_{int,n}$ is the sum of interferences with negative impact

Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2) $U(C_m) = u(C_m) \times k$

Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:
 C_{NOx} is the concentration of NOx measured by the analyser
 R is the ratio of NO:Nox in the stack gas
 η is the NOx converter efficiency

Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left(\frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O ₂ ref. concentration	in	mg/m ³
$C_{O_2,ref}$	=	mass concentration at O ₂ reference concentration	in	mg/m ³
$O_{2,meas}$	=	O ₂ measured concentration	in	% volume
$u((O_{2,meas})_{dry})$	=	uncertainty associated to the measured O ₂ concentration	in	% (relative to O _{2,meas})

APPENDIX 4

Uncertainty Estimate For The Measurement Of Total Organic Carbon BS EN12619:2013

Analysers Type/Model Sick Maihak
 Reference Oxygen % 0 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m ³	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	19.4	26.2	48.3
Measured concentration	mg/m ³	31.2	42.1	77.6
Concentration at O ₂ ref. concentration	mg/m ³	N/A	N/A	N/A

Calibration gas	ppm	78.8	78.8	78.8
Calibration gas	mg/m ³	126.6	126.6	126.6
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m ³	15.0	15.0	15.0

Correction of Lack of Fit				
Lack of fit	% range	2.0	2.0	2.0
	u(Corr _{lof})	0.11	0.11	0.11

Corrections of Zero and Span Drift (*All drift is calculated for ∴ the residual is assumed to be < 5% u(max))				
Zero Drift	% range	0.00	0.00	0.00
	u(Corr _{zdr})	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr _{spd})	0.00	0.00	0.00

Correction of Repeatability of Measurement				
Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr _{rsp})	0.00	0.00	0.00

Correction of adjustment				
Losses in the line	% range	0.80	0.80	0.80
	u(Corr _{loss})	0.09	0.12	0.22
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr _{cgl})	0.19	0.26	0.48

Correction of Influence of Interferents				
N ₂ O	% range			
	u(Corr _{N2O})	0.00	0.00	0.00
CO ₂	% range			
	u(Corr _{CO2})	0.00	0.00	0.00
CH ₄	% range			
	u(Corr _{CH4})	0.00	0.00	0.00
Total of interferent influences u(ΣCorr _{int}) = max[S _{int,p} · S _{int,r}]	% range	2.50	2.50	2.50
	u(ΣCorr _{int})	0.16	0.16	0.16

Correction of Influence Quantities				
Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr _{flow})	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr _{press})	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr _{temp})	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr _{volt})	0.10	0.10	0.10

Oxygen reference concentration				
Measured oxygen	%	#DIV/0!	#DIV/0!	#DIV/0!
Overall uncertainty of O ₂ measurement	U(O _{2,meas})	#REF!	#REF!	#REF!
	u(Corr _{O2})	N/A	N/A	N/A

Maximum standard uncertainty	u(Corr _{max})	0.19	0.26	0.48
5% of maximum standard uncertainty	u(Corr _{5%})	0.01	0.01	0.02

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH ₄ range	0	10	0	50	mg/m ³
N ₂ O range	0	0	0	20	mg/m ³
CO ₂ range	8	12	0	15	mg/m ³
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m ³

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty		Test 1	Test 2	Test 3
Combined uncertainty	ppm	0.42	0.47	0.65
Combined uncertainty	mg/m ³	0.68	0.75	1.04
Combined uncertainty at oxygen reference	mg/m ³	0.68	0.75	1.04

Expanded uncertainty expressed with a level of confidence of 95%, k=2				
Overall uncertainty	ppm	0.8	0.9	1.3
Overall uncertainty	mg/m ³	1.4	1.5	2.1
Overall uncertainty relative to measured value	%	4.4	3.6	2.7
Overall uncertainty relative to range	%	9.1	10.0	13.8
Overall uncertainty relative to ELV	%	1.1	1.2	1.6

Expanded uncertainty at oxygen reference conditions expressed with a level of confidence of 95%, k=2				
Overall uncertainty	mg/m ³	N/A	N/A	N/A
Overall uncertainty relative to measured value	%	N/A	N/A	N/A
Overall uncertainty relative to range	%	N/A	N/A	N/A
Overall uncertainty relative to ELV	%	N/A	N/A	N/A

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



a division of Resource and Environmental Consultants Ltd

Client Xaarjet Ltd.
1 Hurricane Close
Ermine Business Park
Huntingdon
Cambridgeshire
PE29 6XX

Part 1: Executive Summary

Report for the Periodic Monitoring of Emissions to Air.

Site	Huntingdon
Plant	LEV 13
Sampling Date	15th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

Report Approved by:	Sign	
	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



1783

Tel: 0845 676 9303
Company Registration No 03133832



Contents

Page 1	Part 1: Executive Summary
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results, Exhaust Gases
Page 5	Operating Information
Page 5	Comments On Monitoring Procedures
Page 6	Part 2: Supporting Information
Page 7	Appendix 1
Page 8	Emission Monitoring Procedures and Instrumentation
Page 9	Sampling Personnel
Page 9	Equipment References
Page 10	Appendix 2
Page 11	Preliminary Velocity Traverse & Moisture Data
Page 12	Exhaust Gases - Continuous Analysis Data
Page 13	Chart 1 - Exhaust Gases
Page 14	Appendix 3
Page 15	Photograph of Sampling Location
Page 16	Generic Calculations
Page 17	Flow Calculations
Page 18	Concentration Calculation
Page 19	Uncertainty Estimate Calculations - Instrumental Techniques
Page 20	Appendix 4
Page 21	Uncertainty Estimates:- TOC

Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
LEV 13	Total organic carbon

Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow	TPM/01A	BS EN ISO 16911-1:2013
TOC	TPM/13	BS EN 12619 : 2013

Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Xaarjet Ltd.**
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at Huntingdon LEV 13		Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
		Date	Start	End	mg/m ³ *	mg/m ³ *	mg/m ³ *	mg/m ³ *	g/h
TOC	Test 1	15/01/15	14:32	15:02	7.02	75	1.18	0.16	45.1
TOC	Test 2	15/01/15	15:02	15:32	5.84	75	1.18	0.16	37.5
TOC	Test 3	15/01/15	15:32	16:02	7.64	75	1.18	0.16	49.1

* at ref	Stack Gas Weight	0 °C	Wet Gas
Conditions	29.00 Kg/kmol	101.3 kpa	Oxygen None %

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide
 TOC results are expressed as total carbon

Throughout Report: * Reference conditions (see above) Nm³ 273 K, 101.3 kPa
 ** Analysis not required # - UKAS accredited only
 ND Non detectable ## - Not Accredited
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



Operating Information

The tables below shows details of the operating information on each sampling date for: **LEV 13**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
15/01/2015	Production and cleaning of inkjet cartridges	Continuous	N/A	N/A	N/A	Normal

There are no CEMs present on this process

Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-
The homogeneity test is not applicable to non-combustion processes.

All monitoring was performed in accordance with the relevant procedures.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



a division of Resource and Environmental Consultants Ltd

Part 2: Supporting Information

Report for the Periodic Monitoring of Emissions to Air.

Client	Xaarjet Ltd.
Site	Huntingdon
Plant	LEV 13
Sampling Date	15th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

Report Approved by:	Sign		
	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



Tel: 0845 676 9303
Company Registration No 03133832



APPENDIX 1

Emission Monitoring Procedures And Instrumentation

Gas velocity and temperature

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013
Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

Total organic carbon

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013.
Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Report authorised by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Team leader:	Chris Rhodes	MM02 117	-	30/09/2017	28/02/2018	28/02/2018	31/08/2018	31/12/2018
Technician:	Tom Clarkson	MM02 120	-	-	-	-	-	-

Equipment References

Equipment	Reference Number
FID	VC12
Heated Line	HL24
Data Logger	DL14
Stack Thermocouple	PTTS138
Barometer	Met. Office
Pitot	PT138

APPENDIX 2

Date	15/01/2015
Time	16:14
Pitot Cp	1.02

Barometric pressure	98.5	kPa
Duct static pressure	-0.24	kPa
Stack Area	0.283	m ²
Oxygen		%

Stack Diameter (circular)	0.60	m
		m
		m
Carbon dioxide		%

Traverse Point	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s
1	A	5.0					B	5.0				
2	A	5.0	1.9	24	<15	5.9	B	5.0				
3	A	7.1	2.2	24	<15	6.2	B	7.1				
4	A	10.6	2.5	24	<15	6.7	B	10.6				
5	A	15.0	3.2	24	<15	7.5	B	15.0				
6	A	21.4	3.4	24	<15	7.8	B	21.4				
7	A	38.6	3.4	24	<15	7.8	B	38.6				
8	A	45.0	3.8	24	<15	8.2	B	45.0				
9	A	49.4	5.7	24	<15	10.1	B	49.4				
10	A	52.9	1.3	24	<15	4.8	B	52.9				
11	A	55.0	2.0	24	<15	6.0	B	55.0				
12	A	55.0					B	55.0				

Average Pitot DP	2.83	mmH ₂ O
Average Temperature	297.2	K
Average Velocity	7.1	m/s
Average volumetric flow rate	2.00	m ³ /s at stack conditions
Average volumetric flow rate	1.79	m ³ /s (wet STP)
Average volumetric flow rate		m ³ /s (dry STP)
Average volumetric flow rate		m ³ /s (dry, STP, reference oxygen concentraion)

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

a	Angel of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	4.8
	Maximum local gas velocity	10.1
	Ratio of highest to lowest local gas velocity	2.08

Date 15/01/2015

From 14:32 to 15:02 30 minute mean

Volatile organic compounds	vppm, wet	4.37	mg/m ³ *	7.02
----------------------------	-----------	------	---------------------	------

From 15:02 to 15:32 30 minute mean

Volatile organic compounds	vppm, wet	3.63	mg/m ³ *	5.84
----------------------------	-----------	------	---------------------	------

From 15:32 to 16:02 30 minute mean

Volatile organic compounds	vppm, wet	4.75	mg/m ³ *	7.64
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m ³ *	0.16
----------------------------	------	------	---------------------	------


Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VC174989	-	± 2
Volatile organic compounds	vppm	78.8	VCSMG4537	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	14:24	Final Time	16:06
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	79.04	0.00	77.79

Chart 1 - Exhaust Gases, LEV 13, 15th January 2015



APPENDIX 3

Photograph Of The Sampling Location



Cleanroom 3 lasers

Cleanroom 3 VOC

LEV 13 - Room extract

General Calculations

Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

π = 3.142

Pressure conversion:

1mmH₂O = 0.00980665 kPa

1mmH₂O = 9.80665 Pa

1 mar = 0.1 kPa

Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m³ of water vapour in m³ of wet gas)

V_{m(std)} = Dry gas volume measured, corrected to standard conditions (m³)

m_{WC} = Mass of water collected in the impingers (g)

M_w = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

V_{mol(std)} = Molar volume of water at standard conditions = 0.0224 (m³/mol)

Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

V_{m(std)} = Dry gas meter volume at standard conditions (m³)

y_d = Gas meter calibration coefficient

(V₂-V₁) = Dry gas meter volume at actual conditions (m³)

T_m = Actual Temperature (K)

T_{std} = Standard temperature (273 K)

p_m = Absolute pressure at the gas meter (kPa)

p_{std} = Standard gas pressure (101.3 kPa)

Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

Flow Calculations

Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

- \bar{v} = Average velocity (m/s)
- C = velocity calculation constant = 129
- T_s = Average stack temperature (K)
- M_s = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol
- K = Pitot calibration coefficient
- p_e = Absolute gas pressure (kPa)
- Δp = Average pitot tube pressure differential (kPa)

Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

- q_{va} = Average flow rate (m³/s)
- \bar{v} = Average velocity (m/s)
- A = Stack cross-sectional area (m²)

Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

- q_m = Corrected volume flowrate (m³/s)
- q_{va} = Volume flow rate at actual conditions (m³/s)
- H_a = Moisture at actual conditions (%volume)
- H_m = Reference moisture (%volume)

Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

- q_m = Corrected volume flowrate (m³/s)
- q_{va} = Volume flow rate at actual conditions (m³/s)
- T_a = Temperature at actual conditions (K)
- T_m = Reference Temperature (K)
- p_a = Absolute gas pressure at actual conditions (kPa)
- p_m = Reference pressure (kPa)

Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

- q_m = Corrected volume flowrate (m³/s)
- q_{va} = Volume flow rate at actual conditions (m³/s)
- $O_{2,m}$ = Actual oxygen concentration (%)
- $O_{2,ref}$ = Reference oxygen concentration (%)

Concentration Calculations

Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

c = Concentration
 m = Mass of substance
 V = Volume sampled

Mass Emission

$$\text{Mass emission} = c \times q_m$$

c = Concentration
 q = Volume flow rate

Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

cm = Concentration at reference conditions
 ca = Actual concentration
 O_2, ref = Reference oxygen (%)
 O_2, a = Actual Oxygen (%)

Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

c_{wet} = Concentration wet gas
 c_{dry} = Concentration dry gas
 H_a = Water vapour content (%vol)

Conversion of parts per million (ppm) to mg/m³

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

C_{ppm}	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left(\frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$ is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:
 $S_{r,0}$ is the standard uncertainty at zero level
 $S_{r,s}$ is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:
 $u(Corr_{loss})$ is the uncertainty due to losses in sample line
 $u(Corr_{cal})$ is the uncertainty due to losses in sample line
 $C_{j,loss}$ is the concentration of sample loss at span level
 U_{cal} is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:
 c_j is the sensitivity coefficient of the influence quantity
 $x_{j,min}$ is the minimum value of the influence quantity during monitoring
 $x_{j,max}$ is the maximum value of the influence quantity during monitoring
 $x_{j,adj}$ is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\sum Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:
 c_j is the sensitivity coefficient of the interferent j
 $Int_{j,test}$ is the concentration of the interferent j used to determine c_j
 $Int_{j,min}$ is the minimum value of the interferent j quantity during monitoring
 $Int_{j,max}$ is the maximum value of the interferent j quantity during monitoring
 $Int_{j,adj}$ is the concentration of the interferent j in the cal gas used to adjust the analyser
 $S_{int,p}$ is the sum of interferences with positive impact
 $S_{int,n}$ is the sum of interferences with negative impact

Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2) $U(C_m) = u(C_m) \times k$

Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:
 C_{NOx} is the concentration of NOx measured by the analyser
 R is the ratio of NO:Nox in the stack gas
 η is the NOx converter efficiency

Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left(\frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O ₂ ref. concentration	in	mg/m ³
$C_{O_2,ref}$	=	mass concentration at O ₂ reference concentration	in	mg/m ³
$O_{2,meas}$	=	O ₂ measured concentration	in	% volume
$u((O_{2,meas})_{dry})$	=	uncertainty associated to the measured O ₂ concentration	in	% (relative to O _{2,meas})

APPENDIX 4

Uncertainty Estimate For The Measurement Of Total Organic Carbon BS EN12619:2013

Analysers Type/Model Sick Maihak
 Reference Oxygen % 0 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m ³	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	4.4	3.6	4.8
Measured concentration	mg/m ³	7.0	5.8	7.6
Concentration at O ₂ ref. concentration	mg/m ³	N/A	N/A	N/A

Calibration gas	ppm	78.8	78.8	78.8
Calibration gas	mg/m ³	126.6	126.6	126.6
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m ³	15.0	15.0	15.0

Correction of Lack of Fit				
Lack of fit	% range	2.0	2.0	2.0
	u(Corr _{lof})	0.11	0.11	0.11

Corrections of Zero and Span Drift (*All drift is calculated for ∴ the residual is assumed to be < 5% u(max))				
Zero Drift	% range	0.00	0.00	0.00
	u(Corr _{zdr})	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr _{spd})	0.00	0.00	0.00

Correction of Repeatability of Measurement				
Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr _{rpb})	0.00	0.00	0.00

Correction of adjustment				
Losses in the line	% range	0.52	0.52	0.52
	u(Corr _{loss})	0.01	0.01	0.01
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr _{cbl})	0.04	0.04	0.05

Correction of Influence of Interferents				
N ₂ O	% range			
	u(Corr _{N2O})	0.00	0.00	0.00
CO ₂	% range			
	u(Corr _{CO2})	0.00	0.00	0.00
CH ₄	% range			
	u(Corr _{CH4})	0.00	0.00	0.00
Total of interferent influences u(ΣCorr _{int}) = max[S _{int,p} · S _{int,n}]	% range	2.50	2.50	2.50
	u(ΣCorr _{int})	0.16	0.16	0.16

Correction of Influence Quantities				
Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr _{flow})	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr _{press})	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr _{temp})	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr _{volt})	0.10	0.10	0.10

Oxygen reference concentration				
Measured oxygen	%	#DIV/0!	#DIV/0!	#DIV/0!
Overall uncertainty of O ₂ measurement	U(O _{2,meas})	#REF!	#REF!	#REF!
	u(Corr _{O2})	N/A	N/A	N/A

Maximum standard uncertainty	u(Corr _{max})	0.11	0.11	0.11
5% of maximum standard uncertainty	u(Corr _{5%})	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH ₄ range	0	10	0	50	mg/m ³
N ₂ O range	0	0	0	20	mg/m ³
CO ₂ range	8	12	0	15	mg/m ³
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m ³

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty		Test 1	Test 2	Test 3
Combined uncertainty	ppm	0.37	0.37	0.37
Combined uncertainty	mg/m ³	0.59	0.59	0.59
Combined uncertainty at oxygen reference	mg/m ³	0.59	0.59	0.59

Expanded uncertainty expressed with a level of confidence of 95%, k=2				
Overall uncertainty	ppm	0.7	0.7	0.7
Overall uncertainty	mg/m ³	1.2	1.2	1.2
Overall uncertainty relative to measured value	%	16.8	20.2	15.5
Overall uncertainty relative to range	%	7.9	7.9	7.9
Overall uncertainty relative to ELV	%	0.9	0.9	0.9

Expanded uncertainty at oxygen reference conditions expressed with a level of confidence of 95%, k=2				
Overall uncertainty	mg/m ³	N/A	N/A	N/A
Overall uncertainty relative to measured value	%	N/A	N/A	N/A
Overall uncertainty relative to range	%	N/A	N/A	N/A
Overall uncertainty relative to ELV	%	N/A	N/A	N/A

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



a division of Resource and Environmental Consultants Ltd

Client Xaarjet Ltd.
 1 Hurricane Close
 Ermine Business Park
 Huntingdon
 Cambridgeshire
 PE29 6XX

Part 1: Executive Summary

Report for the Periodic Monitoring of Emissions to Air.

Site	Huntingdon
Plant	LEV 14
Sampling Date	15th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

Report Approved by:	Sign	
	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

REC Environmental Monitoring
 10 Broad Lane
 Moldgreen
 Huddersfield
 HD5 9BX



1783

Tel: 0845 676 9303
 Company Registration No 03133832



Contents

Page 1	Part 1: Executive Summary
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results, Exhaust Gases
Page 5	Operating Information
Page 5	Comments On Monitoring Procedures
Page 6	Part 2: Supporting Information
Page 7	Appendix 1
Page 8	Emission Monitoring Procedures and Instrumentation
Page 9	Sampling Personnel
Page 9	Equipment References
Page 10	Appendix 2
Page 11	Preliminary Velocity Traverse & Moisture Data
Page 12	Exhaust Gases - Continuous Analysis Data
Page 13	Chart 1 - Exhaust Gases
Page 14	Appendix 3
Page 15	Photograph of Sampling Location
Page 16	Generic Calculations
Page 17	Flow Calculations
Page 18	Concentration Calculation
Page 19	Uncertainty Estimate Calculations - Instrumental Techniques
Page 20	Appendix 4
Page 21	Uncertainty Estimates:- TOC

Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
LEV 14	Total organic carbon

Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow	TPM/01A	BS EN ISO 16911-1:2013
TOC	TPM/13	BS EN 12619 : 2013

Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Xaarjet Ltd.**
The results were measured from the sample positions downstream of the arrestment plant.

Emission at Huntingdon LEV 14		Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
		Date	Start	End	mg/m ³ *	mg/m ³ *	mg/m ³ *	mg/m ³ *	g/h
TOC	Test 1	15/01/15	15:00	15:30	18.0	75	1.26	0.16	65.1
TOC	Test 2	15/01/15	15:30	16:00	13.0	75	1.22	0.16	47.1
TOC	Test 3	15/01/15	16:00	16:30	8.40	75	1.19	0.16	30.4

* at ref	Stack Gas Weight	0 °C	Wet Gas
Conditions	29.00 Kg/kmol	101.3 kpa	Oxygen None %

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide
TOC results are expressed as total carbon

Throughout Report: * Reference conditions (see above) Nm³ 273 K, 101.3 kPa
** Analysis not required # - UKAS accredited only
ND Non detectable ## - Not Accredited
s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



Operating Information

The tables below shows details of the operating information on each sampling date for: **LEV 14**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
15/01/2015	Production and cleaning of inkjet cartridges	Continuous	N/A	N/A	N/A	Normal

There are no CEMs present on this process

Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-
The homogeneity test is not applicable to non-combustion processes.

All monitoring was performed in accordance with the relevant procedures.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



a division of Resource and Environmental Consultants Ltd

Part 2: Supporting Information

Report for the Periodic Monitoring of Emissions to Air.

Client	Xaarjet Ltd.
Site	Huntingdon
Plant	LEV 14
Sampling Date	15th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

Report Approved by:	Sign		
	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



Tel: 0845 676 9303
Company Registration No 03133832



APPENDIX 1

Emission Monitoring Procedures And Instrumentation

Gas velocity and temperature

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013
Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

Total organic carbon

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013.
Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Report authorised by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Team leader:	Chris Rhodes	MM02 117	-	30/09/2017	28/02/2018	28/02/2018	31/08/2018	31/12/2018
Technician:	Tom Clarkson	MM02 120	-	-	-	-	-	-

Equipment References

Equipment	Reference Number
FID	VC09
Heated Line	HL24
Data Logger	DL06
Stack Thermocouple	PTTS138
Barometer	Met. Office
Pitot	PT138

APPENDIX 2

Date	15/01/2015
Time	15:15
Pitot Cp	1.02

Barometric pressure	98.5	kPa
Duct static pressure	-0.04	kPa
Stack Area	0.159	m ²
Oxygen		%

Stack Diameter (circular)	0.45	m
		m
		m
Carbon dioxide		%

Traverse Point	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s
1	A	5.0					B	5.0				
2	A	5.0					B	5.0				
3	A	5.3	3.3	25	<15	7.6	B	5.3				
4	A	8.0	3.1	25	<15	7.4	B	8.0				
5	A	11.3	3.2	25	<15	7.5	B	11.3				
6	A	16.0	3.1	25	<15	7.4	B	16.0				
7	A	29.0	2.9	25	<15	7.1	B	29.0				
8	A	33.8	2.7	25	<15	6.9	B	33.8				
9	A	37.0	2.4	25	<15	6.6	B	37.0				
10	A	39.7	2.3	25	<15	6.4	B	39.7				
11	A	40.0					B	40.0				
12	A	40.0					B	40.0				

Average Pitot DP	2.85	mmH ₂ O
Average Temperature	298.2	K
Average Velocity	7.1	m/s
Average volumetric flow rate	1.13	m ³ /s at stack conditions
Average volumetric flow rate	1.01	m ³ /s (wet STP)
Average volumetric flow rate		m ³ /s (dry STP)
Average volumetric flow rate		m ³ /s (dry, STP, reference oxygen concentraion)

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

a	Angel of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	6.4
	Maximum local gas velocity	7.6
	Ratio of highest to lowest local gas velocity	1.18

Date 15/01/2015

From 15:00 to 15:30 30 minute mean

Volatile organic compounds	vppm, wet	11.19	mg/m ³ *	17.99
----------------------------	-----------	-------	---------------------	-------

From 15:30 to 16:00 30 minute mean

Volatile organic compounds	vppm, wet	8.10	mg/m ³ *	13.01
----------------------------	-----------	------	---------------------	-------

From 16:00 to 16:30 30 minute mean

Volatile organic compounds	vppm, wet	5.23	mg/m ³ *	8.40
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m ³ *	0.16
----------------------------	------	------	---------------------	------


Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VC174989	-	± 2
Volatile organic compounds	vppm	78.8	VCSMG4537	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	14:33	Final Time	16:35
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	78.80	0.10	78.92

Chart 1 - Exhaust Gases, LEV 14, 15th January 2015



APPENDIX 3

Photograph Of The Sampling Location



LEV 14
Room extract



General Calculations

Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

π = 3.142

Pressure conversion:

1mmH2O = 0.00980665 kPa

1mmH2O = 9.80665 Pa

1 mar = 0.1 kPa

Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m³ of water vapour in m³ of wet gas)

Vm(std) = Dry gas volume measured, corrected to standard conditions (m³)

mWC = Mass of water collected in the impingers (g)

Mw = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

Vmol(std) = Molar volume of water at standard conditions = 0.0224 (m³/mol)

Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

Vm(std) = Dry gas meter volume at standard conditions (m³)

yd = Gas meter calibration coefficient

(V2-V1) = Dry gas meter volume at actual conditions (m³)

Tm = Actual Temperature (K)

Tstd = Standard temperature (273 K)

pm = Absolute pressure at the gas meter (kPa)

pstd = Standard gas pressure (101.3 kPa)

Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

Flow Calculations

Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

\bar{v} = Average velocity (m/s)

C = velocity calculation constant = 129

T_s = Average stack temperature (K)

M_s = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

K = Pitot calibration coefficient

p_e = Absolute gas pressure (kPa)

Δp = Average pitot tube pressure differential (kPa)

Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

q_{va} = Average flow rate (m³/s)

\bar{v} = Average velocity (m/s)

A = Stack cross-sectional area (m²)

Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

H_a = Moisture at actual conditions (%volume)

H_m = Reference moisture (%volume)

Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

T_a = Temperature at actual conditions (K)

T_m = Reference Temperature (K)

p_a = Absolute gas pressure at actual conditions (kPa)

p_m = Reference pressure (kPa)

Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

$O_{2,m}$ = Actual oxygen concentration (%)

$O_{2,ref}$ = Reference oxygen concentration (%)

Concentration Calculations

Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

c = Concentration
 m = Mass of substance
 V = Volume sampled

Mass Emission

$$\text{Mass emission} = c \times q_m$$

c = Concentration
 q = Volume flow rate

Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

cm = Concentration at reference conditions
 ca = Actual concentration
 O_2, ref = Reference oxygen (%)
 O_2, a = Actual Oxygen (%)

Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

c_{wet} = Concentration wet gas
 c_{dry} = Concentration dry gas
 H_a = Water vapour content (%vol)

Conversion of parts per million (ppm) to mg/m³

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{0,dr} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

C_{ppm}	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left(\frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$ is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:
 $S_{r,0}$ is the standard uncertainty at zero level
 $S_{r,s}$ is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:
 $u(Corr_{loss})$ is the uncertainty due to losses in sample line
 $u(Corr_{cal})$ is the uncertainty due to losses in sample line
 $C_{j,loss}$ is the concentration of sample loss at span level
 U_{cal} is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:
 c_j is the sensitivity coefficient of the influence quantity
 $x_{j,min}$ is the minimum value of the influence quantity during monitoring
 $x_{j,max}$ is the maximum value of the influence quantity during monitoring
 $x_{j,adj}$ is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\sum Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:
 c_j is the sensitivity coefficient of the interferent j
 $Int_{j,test}$ is the concentration of the interferent j used to determine c_j
 $Int_{j,min}$ is the minimum value of the interferent j quantity during monitoring
 $Int_{j,max}$ is the maximum value of the interferent j quantity during monitoring
 $Int_{j,adj}$ is the concentration of the interferent j in the cal gas used to adjust the analyser
 $S_{int,p}$ is the sum of interferences with positive impact
 $S_{int,n}$ is the sum of interferences with negative impact

Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2) $U(C_m) = u(C_m) \times k$

Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:
 C_{NOx} is the concentration of NOx measured by the analyser
 R is the ratio of NO:Nox in the stack gas
 η is the NOx converter efficiency

Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left(\frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O ₂ ref. concentration	in	mg/m ³
$C_{O_2,ref}$	=	mass concentration at O ₂ reference concentration	in	mg/m ³
$O_{2,meas}$	=	O ₂ measured concentration	in	% volume
$u(O_{2,meas,dry})$	=	uncertainty associated to the measured O ₂ concentration	in	% (relative to O _{2,meas})

APPENDIX 4

Uncertainty Estimate For The Measurement Of Total Organic Carbon BS EN12619:2013

Analysers Type/Model Sick Maihak
 Reference Oxygen % 0 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m ³	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	11.2	8.1	5.2
Measured concentration	mg/m ³	18.0	13.0	8.4
Concentration at O ₂ ref. concentration	mg/m ³	N/A	N/A	N/A

Calibration gas	ppm	78.8	78.8	78.8
Calibration gas	mg/m ³	126.6	126.6	126.6
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m ³	15.0	15.0	15.0

Correction of Lack of Fit				
Lack of fit	% range	2.0	2.0	2.0
	u(Corr _{lof})	0.11	0.11	0.11

Corrections of Zero and Span Drift (*All drift is calculated for ∴ the residual is assumed to be < 5% u(max))				
Zero Drift	% range	0.00	0.00	0.00
	u(Corr _{zdr})	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr _{spd})	0.00	0.00	0.00

Correction of Repeatability of Measurement				
Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr _{rpb})	0.00	0.00	0.00

Correction of adjustment				
Losses in the line	% range	1.28	1.28	1.28
	u(Corr _{loss})	0.08	0.06	0.04
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr _{cbl})	0.11	0.08	0.05

Correction of Influence of Interferents				
N ₂ O	% range			
	u(Corr _{N2O})	0.00	0.00	0.00
CO ₂	% range			
	u(Corr _{CO2})	0.00	0.00	0.00
CH ₄	% range			
	u(Corr _{CH4})	0.00	0.00	0.00
Total of interferent influences u(ΣCorr _{int}) = max[S _{int,p} · S _{int,n}]	% range	2.50	2.50	2.50
	u(ΣCorr _{int})	0.16	0.16	0.16

Correction of Influence Quantities				
Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr _{flow})	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr _{press})	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr _{temp})	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr _{volt})	0.10	0.10	0.10

Oxygen reference concentration				
Measured oxygen	%	#DIV/0!	#DIV/0!	#DIV/0!
Overall uncertainty of O ₂ measurement	U(O _{2,meas})	#REF!	#REF!	#REF!
	u(Corr _{O2})	N/A	N/A	N/A

Maximum standard uncertainty	u(Corr _{max})	0.11	0.11	0.11
5% of maximum standard uncertainty	u(Corr _{5%})	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH ₄ range	0	10	0	50	mg/m ³
N ₂ O range	0	0	0	20	mg/m ³
CO ₂ range	8	12	0	15	mg/m ³
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m ³

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty				
Combined uncertainty	ppm	0.39	0.38	0.37
	mg/m ³	0.63	0.61	0.60
Combined uncertainty at oxygen reference	mg/m ³	0.63	0.61	0.60

Expanded uncertainty expressed with a level of confidence of 95%, k=2				
Overall uncertainty	ppm	0.8	0.8	0.7
Overall uncertainty	mg/m ³	1.3	1.2	1.2
Overall uncertainty relative to measured value	%	7.0	9.3	14.2
Overall uncertainty relative to range	%	8.4	8.1	7.9
Overall uncertainty relative to ELV	%	1.0	1.0	0.9

Expanded uncertainty at oxygen reference conditions expressed with a level of confidence of 95%, k=2				
Overall uncertainty	mg/m ³	N/A	N/A	N/A
Overall uncertainty relative to measured value	%	N/A	N/A	N/A
Overall uncertainty relative to range	%	N/A	N/A	N/A
Overall uncertainty relative to ELV	%	N/A	N/A	N/A

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



a division of Resource and Environmental Consultants Ltd

Client Xaarjet Ltd.
 1 Hurricane Close
 Ermine Business Park
 Huntingdon
 Cambridgeshire
 PE29 6XX

Part 1: Executive Summary

Report for the Periodic Monitoring of Emissions to Air.

Site	Huntingdon
Plant	LEV 17
Sampling Date	16th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

Report Approved by:	Sign	
	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

REC Environmental Monitoring
 10 Broad Lane
 Moldgreen
 Huddersfield
 HD5 9BX



Tel: 0845 676 9303
 Company Registration No 03133832



Contents

Page 1	Part 1: Executive Summary
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results, Exhaust Gases
Page 5	Operating Information
Page 5	Comments On Monitoring Procedures
Page 6	Part 2: Supporting Information
Page 7	Appendix 1
Page 8	Emission Monitoring Procedures and Instrumentation
Page 9	Sampling Personnel
Page 9	Equipment References
Page 10	Appendix 2
Page 11	Preliminary Velocity Traverse & Moisture Data
Page 12	Exhaust Gases - Continuous Analysis Data
Page 13	Chart 1 - Exhaust Gases
Page 14	Appendix 3
Page 15	Generic Calculations
Page 16	Flow Calculations
Page 17	Concentration Calculation
Page 18	Uncertainty Estimate Calculations - Instrumental Techniques
Page 19	Appendix 4
Page 20	Uncertainty Estimates:- TOC

Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
LEV 17	Total organic carbon

Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow	TPM/01A	BS EN ISO 16911-1:2013
TOC	TPM/13	BS EN 12619 : 2013

Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Xaarjet Ltd.**
 The results were measured from the sample positions downstream of the arrestment plant.

Emission at Huntingdon LEV 17		Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
		Date	Start	End	mg/m ³ *	mg/m ³ *	mg/m ³ *	mg/m ³ *	g/h
TOC	Test 1	16/01/15	09:20	09:50	7.85	75	1.18	0.16	0.75
TOC	Test 2	16/01/15	09:50	10:20	6.92	75	1.18	0.16	0.66
TOC	Test 3	16/01/15	10:20	10:50	9.75	75	1.19	0.16	0.94

* at ref Conditions	Stack Gas Weight 29.00 Kg/kmol	0 °C 101.3 kpa	Wet Gas Oxygen None %
------------------------	-----------------------------------	-------------------	--------------------------

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide
 TOC results are expressed as total carbon

Throughout Report: * Reference conditions (see above) Nm³ 273 K, 101.3 kPa
 ** Analysis not required # - UKAS accredited only
 ND Non detectable ## - Not Accredited
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



Operating Information

The tables below shows details of the operating information on each sampling date for: **LEV 17**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
16/01/2015	Production and cleaning of inkjet cartridges	Continuous	N/A	N/A	N/A	Normal

There are no CEMs present on this process

Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-
The homogeneity test is not applicable to non-combustion processes.

All monitoring was performed in accordance with the relevant procedures.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.



a division of Resource and Environmental Consultants Ltd

Part 2: Supporting Information

Report for the Periodic Monitoring of Emissions to Air.

Client	Xaarjet Ltd.
Site	Huntingdon
Plant	LEV 17
Sampling Date	16th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

Report Approved by:	Sign		
	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



Tel: 0845 676 9303
Company Registration No 03133832



a CONCEPT LIFE SCIENCES company

APPENDIX 1

Emission Monitoring Procedures And Instrumentation

Gas velocity and temperature

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013
Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

Total organic carbon

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013.
Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Report authorised by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Team leader:	Chris Rhodes	MM02 117	-	30/09/2017	28/02/2018	28/02/2018	31/08/2018	31/12/2018
Technician:	Tom Clarkson	MM02 120	-	-	-	-	-	-

Equipment References

Equipment	Reference Number
FID	VC12
Heated Line	HL24
Data Logger	DL06
Stack Thermocouple	PTTS138
Barometer	Met. Office
Pitot	PT138

APPENDIX 2

Date	16/01/2015
Time	09:10
Pitot Cp	1.02

Barometric pressure	100.4	kPa
Duct static pressure	0.06	kPa
Stack Area	0.006	m ²
Oxygen		%

Stack Diameter (circular)	0.09	m
		m
		m
Carbon dioxide		%

Traverse Point	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s
1	A	5.0					B	5.0				
2	A	5.0					B	5.0				
3	A	5.0					B	5.0				
4	A	5.0					B	5.0				
5	A	5.0					B	5.0				
6	A	5.0	1.2	16	<15	4.5	B	5.0				
7	A	4.0					B	4.0				
8	A	4.0					B	4.0				
9	A	4.0					B	4.0				
10	A	4.0					B	4.0				
11	A	4.0					B	4.0				
12	A	4.0					B	4.0				

Average Pitot DP	1.19	mmH ₂ O
Average Temperature	289.2	K
Average Velocity	4.5	m/s
Average volumetric flow rate	0.03	m ³ /s at stack conditions
Average volumetric flow rate	0.03	m ³ /s (wet STP)
Average volumetric flow rate		m ³ /s (dry STP)
Average volumetric flow rate		m ³ /s (dry, STP, reference oxygen concentraion)

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

a	Angel of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	4.5
	Maximum local gas velocity	4.5
	Ratio of highest to lowest local gas velocity	1.00

Date 16/01/2015

From 09:20 to 09:50 30 minute mean

Volatile organic compounds	vppm, wet	4.89	mg/m ³ *	7.85
----------------------------	-----------	------	---------------------	------

From 09:50 to 10:20 30 minute mean

Volatile organic compounds	vppm, wet	4.30	mg/m ³ *	6.92
----------------------------	-----------	------	---------------------	------

From 10:20 to 10:50 30 minute mean

Volatile organic compounds	vppm, wet	6.07	mg/m ³ *	9.75
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m ³ *	0.16
----------------------------	------	------	---------------------	------


Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VC174989	-	± 2
Volatile organic compounds	vppm	78.8	VCSMG4537	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	09:09	Final Time	12:40
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	78.56	0.08	78.68

Chart 1 - Exhaust Gases, LEV 17, 16th January 2015



APPENDIX 3

General Calculations

Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

π = 3.142

Pressure conversion:

1mmH2O = 0.00980665 kPa

1mmH2O = 9.80665 Pa

1 mar = 0.1 kPa

Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m³ of water vapour in m³ of wet gas)

Vm(std) = Dry gas volume measured, corrected to standard conditions (m³)

mWC = Mass of water collected in the impingers (g)

Mw = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

Vmol(std) = Molar volume of water at standard conditions = 0.0224 (m³/mol)

Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

Vm(std) = Dry gas meter volume at standard conditions (m³)

yd = Gas meter calibration coefficient

(V2-V1) = Dry gas meter volume at actual conditions (m³)

Tm = Actual Temperature (K)

Tstd = Standard temperature (273 K)

pm = Absolute pressure at the gas meter (kPa)

pstd = Standard gas pressure (101.3 kPa)

Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

Flow Calculations

Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

\bar{v} = Average velocity (m/s)

C = velocity calculation constant = 129

T_s = Average stack temperature (K)

M_s = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

K = Pitot calibration coefficient

p_e = Absolute gas pressure (kPa)

Δp = Average pitot tube pressure differential (kPa)

Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

q_{va} = Average flow rate (m³/s)

\bar{v} = Average velocity (m/s)

A = Stack cross-sectional area (m²)

Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

H_a = Moisture at actual conditions (%volume)

H_m = Reference moisture (%volume)

Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

T_a = Temperature at actual conditions (K)

T_m = Reference Temperature (K)

p_a = Absolute gas pressure at actual conditions (kPa)

p_m = Reference pressure (kPa)

Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

$O_{2,m}$ = Actual oxygen concentration (%)

$O_{2,ref}$ = Reference oxygen concentration (%)

Concentration Calculations

Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

c = Concentration
 m = Mass of substance
 V = Volume sampled

Mass Emission

$$\text{Mass emission} = c \times q_m$$

c = Concentration
 q = Volume flow rate

Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

cm = Concentration at reference conditions
 ca = Actual concentration
 O_2, ref = Reference oxygen (%)
 O_2, a = Actual Oxygen (%)

Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

c_{wet} = Concentration wet gas
 c_{dry} = Concentration dry gas
 H_a = Water vapour content (%vol)

Conversion of parts per million (ppm) to mg/m³

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{k_{0,dr}} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

C_{ppm}	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left(\frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$ is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:
 $S_{r,0}$ is the standard uncertainty at zero level
 $S_{r,s}$ is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:
 $u(Corr_{loss})$ is the uncertainty due to losses in sample line
 $u(Corr_{cal})$ is the uncertainty due to losses in sample line
 $C_{j,loss}$ is the concentration of sample loss at span level
 U_{cal} is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:
 c_j is the sensitivity coefficient of the influence quantity
 $x_{j,min}$ is the minimum value of the influence quantity during monitoring
 $x_{j,max}$ is the maximum value of the influence quantity during monitoring
 $x_{j,adj}$ is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:
 c_j is the sensitivity coefficient of the interferent j
 $Int_{j,test}$ is the concentration of the interferent j used to determine c_j
 $Int_{j,min}$ is the minimum value of the interferent j quantity during monitoring
 $Int_{j,max}$ is the maximum value of the interferent j quantity during monitoring
 $Int_{j,adj}$ is the concentration of the interferent j in the cal gas used to adjust the analyser
 $S_{int,p}$ is the sum of interferences with positive impact
 $S_{int,n}$ is the sum of interferences with negative impact

Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2) $U(C_m) = u(C_m) \times k$

Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:
 C_{NOx} is the concentration of NOx measured by the analyser
 R is the ratio of NO:Nox in the stack gas
 η is the NOx converter efficiency

Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left(\frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O ₂ ref. concentration	in	mg/m ³
$C_{O_2,ref}$	=	mass concentration at O ₂ reference concentration	in	mg/m ³
$O_{2,meas}$	=	O ₂ measured concentration	in	% volume
$u((O_{2,meas})_{dry})$	=	uncertainty associated to the measured O ₂ concentration	in	% (relative to O _{2,meas})

APPENDIX 4

Uncertainty Estimate For The Measurement Of Total Organic Carbon BS EN12619:2013

Analysers Type/Model Sick Maihak
 Reference Oxygen % 0 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m ³	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	4.9	4.3	6.1
Measured concentration	mg/m ³	7.9	6.9	9.8
Concentration at O ₂ ref. concentration	mg/m ³	N/A	N/A	N/A

Calibration gas	ppm	78.8	78.8	78.8
Calibration gas	mg/m ³	126.6	126.6	126.6
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m ³	15.0	15.0	15.0

Correction of Lack of Fit				
Lack of fit	% range	2.0	2.0	2.0
	u(Corr _{lof})	0.11	0.11	0.11

Corrections of Zero and Span Drift (*All drift is calculated for ∴ the residual is assumed to be < 5% u(max))				
Zero Drift	% range	0.00	0.00	0.00
	u(Corr _{zdr})	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr _{spd})	0.00	0.00	0.00

Correction of Repeatability of Measurement				
Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr _{rpb})	0.00	0.00	0.00

Correction of adjustment				
Losses in the line	% range	0.18	0.18	0.18
	u(Corr _{loss})	0.01	0.00	0.01
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr _{cbl})	0.05	0.04	0.06

Correction of Influence of Interferents				
N ₂ O	% range			
	u(Corr _{N2O})	0.00	0.00	0.00
CO ₂	% range			
	u(Corr _{CO2})	0.00	0.00	0.00
CH ₄	% range			
	u(Corr _{CH4})	0.00	0.00	0.00
Total of interferent influences u(ΣCorr _{int}) = max[S _{int,p} · S _{int,n}]	% range	2.50	2.50	2.50
	u(ΣCorr _{int})	0.16	0.16	0.16

Correction of Influence Quantities				
Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr _{flow})	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr _{press})	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr _{temp})	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr _{volt})	0.10	0.10	0.10

Oxygen reference concentration				
Measured oxygen	%	#DIV/0!	#DIV/0!	#DIV/0!
Overall uncertainty of O ₂ measurement	U(O _{2,meas})	#REF!	#REF!	#REF!
	u(Corr _{O2})	N/A	N/A	N/A

Maximum standard uncertainty	u(Corr _{max})	0.11	0.11	0.11
5% of maximum standard uncertainty	u(Corr _{5%})	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH ₄ range	0	10	0	50	mg/m ³
N ₂ O range	0	0	0	20	mg/m ³
CO ₂ range	8	12	0	15	mg/m ³
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m ³

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty				
Combined uncertainty	ppm	0.37	0.37	0.37
	mg/m ³	0.59	0.59	0.59
Combined uncertainty at oxygen reference	mg/m ³	0.59	0.59	0.59

Expanded uncertainty expressed with a level of confidence of 95%, k=2				
Overall uncertainty	ppm	0.7	0.7	0.7
Overall uncertainty	mg/m ³	1.2	1.2	1.2
Overall uncertainty relative to measured value	%	15.1	17.1	12.2
Overall uncertainty relative to range	%	7.9	7.9	7.9
Overall uncertainty relative to ELV	%	0.9	0.9	0.9

Expanded uncertainty at oxygen reference conditions expressed with a level of confidence of 95%, k=2				
Overall uncertainty	mg/m ³	N/A	N/A	N/A
Overall uncertainty relative to measured value	%	N/A	N/A	N/A
Overall uncertainty relative to range	%	N/A	N/A	N/A
Overall uncertainty relative to ELV	%	N/A	N/A	N/A

The uncertainty evaluation has been carried out in accordance with UKAS requirements.



a division of Resource and Environmental Consultants Ltd

Client Xaarjet Ltd.
1 Hurricane Close
Ermine Business Park
Huntingdon
Cambridgeshire
PE29 6XX

Part 1: Executive Summary

Report for the Periodic Monitoring of Emissions to Air.

Site	Huntingdon
Plant	LEV 19
Sampling Date	16th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

Report Approved by:	Sign	
	Print	Emily Buffam
	MCERTS No.	MM04 502 Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



Tel: 0845 676 9303
Company Registration No 03133832



Contents

Page 1	Part 1: Executive Summary
Page 2	Contents
Page 3	Monitoring Objectives
Page 3	Special Monitoring Requirements
Page 3	Summary Of Methods
Page 4	Summary Of Results, Exhaust Gases
Page 5	Operating Information
Page 5	Comments On Monitoring Procedures
Page 6	Part 2: Supporting Information
Page 7	Appendix 1
Page 8	Emission Monitoring Procedures and Instrumentation
Page 9	Sampling Personnel
Page 9	Equipment References
Page 10	Appendix 2
Page 11	Preliminary Velocity Traverse & Moisture Data
Page 12	Exhaust Gases - Continuous Analysis Data
Page 13	Chart 1 - Exhaust Gases
Page 14	Appendix 3
Page 15	Generic Calculations
Page 16	Flow Calculations
Page 17	Concentration Calculation
Page 18	Uncertainty Estimate Calculations - Instrumental Techniques
Page 19	Appendix 4
Page 20	Uncertainty Estimates:- TOC

Monitoring Objectives

The monitoring was undertaken to check compliance with authorised emission limits.

All monitoring procedures were carried out to the MCERTS requirements under the REC Environmental Monitoring quality system to ISO 17025: 2005.

Monitoring was undertaken for the listed emissions from the following sampling positions:

Sampling Location	Emission
LEV 19	Total organic carbon

Special Monitoring Requirements

There were no special requirements for this monitoring campaign.

Summary of Methods

Emission	Method number	Method standard
Gas velocity and volume flow	TPM/01A	BS EN ISO 16911-1:2013
TOC	TPM/13	BS EN 12619 : 2013

Summary Of Results, Exhaust Gases

The table presents the atmospheric emissions from the tests undertaken on behalf of **Xaarjet Ltd.**
The results were measured from the sample positions downstream of the arrestment plant.

Emission at Huntingdon LEV 19		Sampling Time			Emission Result	Authorised Limit	Uncertainty +/-	Detection Limit	Mass Emission
		Date	Start	End	mg/m ^{3*}	mg/m ^{3*}	mg/m ^{3*}	mg/m ^{3*}	g/h
TOC	Test 1	16/01/15	11:00	11:30	3.69	75	1.17	0.16	6.80
TOC	Test 2	16/01/15	11:30	12:00	2.67	75	1.17	0.16	4.91
TOC	Test 3	16/01/15	12:00	12:42	4.19	75	1.18	0.16	7.72

* at ref	Stack Gas Weight	0 °C	Wet Gas
Conditions	29.00 Kg/kmol	101.3 kpa	Oxygen None %

Where applicable Oxides of nitrogen results are expressed as nitrogen dioxide
TOC results are expressed as total carbon

Throughout Report: * Reference conditions (see above) Nm³ 273 K, 101.3 kPa
 ** Analysis not required # - UKAS accredited only
 ND Non detectable ## - Not Accredited
 s - Subcontracted laboratory analysis N/A Not applicable

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2, providing a 95% confidence level. The uncertainty evaluation has been carried out in accordance with UKAS requirements.



All tests included in this report are accredited under UKAS and MCERTS accreditation schemes unless otherwise stated. Opinions and interpretations expressed herein are outside the scope of MCERTS and UKAS accreditation.



Operating Information

The tables below shows details of the operating information on each sampling date for: **LEV 19**

Date	Process type	Process duration	Fuel	Feedstock	Abatement	Load
16/01/2015	Production and cleaning of inkjet cartridges	Continuous	N/A	N/A	N/A	Normal

There are no CEMs present on this process

Comments & Monitoring Deviations

A waste gas homogeneity test to BS EN 15259:2007 (MID) is not required:-
The homogeneity test is not applicable to non-combustion processes.

All monitoring was performed in accordance with the relevant procedures.

The velocity and temperature profile at the sampling location met the requirements of BS EN 13284-1: 2002.

When the results are expressed as non-detected the mass emissions are calculated from the detection limit and therefore they are worst case results.

The power tripped between 12:08 and 12:17, data from within this period was removed



a division of Resource and Environmental Consultants Ltd

Part 2: Supporting Information

Report for the Periodic Monitoring of Emissions to Air.

Client	Xaarjet Ltd.
Site	Huntingdon
Plant	LEV 19
Sampling Date	16th January 2015
Report Date	26th February 2015
Job Number	EM02708
Permit Number	B22/11

Report Prepared by:	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

Report Approved by:	Sign		
	Print	Emily Buffam	
	MCERTS No.	MM04 502	Level 2 TE: 1,2,3,4

REC Environmental Monitoring
10 Broad Lane
Moldgreen
Huddersfield
HD5 9BX



Tel: 0845 676 9303
Company Registration No 03133832



APPENDIX 1

Emission Monitoring Procedures And Instrumentation

Gas velocity and temperature

Documented in-house procedure TPM01/A to the main procedural requirements of BS EN ISO 16911-1:2013
Velocity and temperature measurements are performed using a calibrated Pitot tube, a calibrated pressure differential reading device and a calibrated thermocouple. Velocity and possible flow deviation measurements are carried out at selected, representative points in the gas stream.

Total organic carbon

Documented in-house procedure TPM/13 to the main procedural requirements of BS EN 12619:2013.
Continuous analysis using probe, sample line and multi range Flame Ionisation Detector (FID) analyser. The analyser is calibrated before and during the tests using certified gas mixtures of nitrogen, oxygen and propane. Sampling points are selected in accordance with the findings of any BS EN 15259 assessment.

Sampling Project Personnel Competency And Expiry Dates

		MCERTS No	Level 1	Level 2	TE1	TE2	TE3	TE4
Report prepared by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Report authorised by:	Emily Buffam	MM04 502	-	30/06/2016	30/06/2016	31/08/2016	31/08/2016	31/08/2016
Team leader:	Chris Rhodes	MM02 117	-	30/09/2017	28/02/2018	28/02/2018	31/08/2018	31/12/2018
Technician:	Tom Clarkson	MM02 120	-	-	-	-	-	-

Equipment References

Equipment	Reference Number
FID	VC12
Heated Line	HL24
Data Logger	DL06
Stack Thermocouple	PTTS138
Barometer	Met. Office
Pitot	PT138

APPENDIX 2

Date	16/01/2015
Time	09:10
Pitot Cp	1.02

Barometric pressure	100.4	kPa
Duct static pressure	0.08	kPa
Stack Area	0.096	m ²
Oxygen		%

Stack Diameter (circular)	0.35	m
		m
		m
Carbon dioxide		%

Traverse Point	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s	Traverse Line	Depth cm	ΔP mmH ₂ O	T °C	Angle °	velocity m/s
1	A	5.0					B	5.0				
2	A	5.0					B	5.0				
3	A	5.0	2.1	19	<15	6.0	B	5.0				
4	A	6.2	2.2	19	<15	6.2	B	6.2				
5	A	8.8	1.9	19	<15	5.7	B	8.8				
6	A	12.5	1.8	19	<15	5.6	B	12.5				
7	A	22.5	2.0	19	<15	5.9	B	22.5				
8	A	26.3	1.9	19	<15	5.7	B	26.3				
9	A	28.8	1.7	19	<15	5.4	B	28.8				
10	A	30.0	1.6	19	<15	5.3	B	30.0				
11	A	30.0					B	30.0				
12	A	30.0					B	30.0				

Average Pitot DP	1.93	mmH ₂ O
Average Temperature	292.2	K
Average Velocity	5.7	m/s
Average volumetric flow rate	0.55	m ³ /s at stack conditions
Average volumetric flow rate	0.51	m ³ /s (wet STP)
Average volumetric flow rate		m ³ /s (dry STP)
Average volumetric flow rate		m ³ /s (dry, STP, reference oxygen concentraion)

Sampling plane requirements Re: BS EN 13284-1:2001 5.2

a	Angel of gas flow less than 15° with regard to duct axis	YES
b	No local negative flow	YES
c	Minimum pitot greater than 5Pa	YES
d	Ratio of highest to lowest local gas velocity less than 3:1	YES
	Minimum local gas velocity	5.3
	Maximum local gas velocity	6.2
	Ratio of highest to lowest local gas velocity	1.17

Date 16/01/2015

From 11:00 to 11:30 30 minute mean

Volatile organic compounds	vppm, wet	2.30	mg/m ³ *	3.69
----------------------------	-----------	------	---------------------	------

From 11:30 to 12:00 30 minute mean

Volatile organic compounds	vppm, wet	1.66	mg/m ³ *	2.67
----------------------------	-----------	------	---------------------	------

From 12:00 to 12:42 30 minute mean

Volatile organic compounds	vppm, wet	2.61	mg/m ³ *	4.19
----------------------------	-----------	------	---------------------	------

Sampling Detection Limits

Volatile organic compounds	vppm	0.10	mg/m ³ *	0.16
----------------------------	------	------	---------------------	------


Reference Gas Details

Species	Units	Value	Cylinder Reference	Analyser Range	Uncertainty <i>k</i> = 2
Nitrogen	%	99.999	VC174989	-	± 2
Volatile organic compounds	vppm	78.8	VCSMG4537	100	± 2

Zero And Span Gas Details

Species	units	Initial Time	09:09	Final Time	12:40
		Initial Zero	Initial Span	Final Zero	Final Span
Volatile organic compounds	vppm	0.00	78.56	0.08	78.68

Chart 1 - Exhaust Gases, LEV 19, 16th January 2015



APPENDIX 3

General Calculations

Stack area:

$$\text{Area of a circle} = \frac{\pi \cdot D^2}{4}$$

D = Diameter (m)

π = 3.142

Pressure conversion:

1mmH2O = 0.00980665 kPa

1mmH2O = 9.80665 Pa

1 mar = 0.1 kPa

Water vapour concentration:

From reference calculations (taken from BS EN 14790):

$$V_{WC(\%)} = \frac{\frac{m_{WC} \cdot V_{mol(std)}}{M_w}}{\frac{m_{WC} \cdot V_{mol(std)}}{M_w} + V_{m(std)}} \times 100$$

WVC (%) = Water vapour content on wet basis, in volume % (m³ of water vapour in m³ of wet gas)

Vm(std) = Dry gas volume measured, corrected to standard conditions (m³)

mWC = Mass of water collected in the impingers (g)

Mw = Molecular weight of water, 18.01534 rounded to 18 (g/mol)

Vmol(std) = Molar volume of water at standard conditions = 0.0224 (m³/mol)

Gas meter volume at standard conditions (STP)

From reference calculations (taken from BS EN 14790):

$$V_{m(std)} = y_d \times (V_2 - V_1) \times \frac{T_{std}}{T_m} \times \frac{P_m}{P_{std}}$$

Vm(std) = Dry gas meter volume at standard conditions (m³)

yd = Gas meter calibration coefficient

(V2-V1) = Dry gas meter volume at actual conditions (m³)

Tm = Actual Temperature (K)

Tstd = Standard temperature (273 K)

pm = Absolute pressure at the gas meter (kPa)

pstd = Standard gas pressure (101.3 kPa)

Isokenetic Ratio (%):

From reference calculations (taken from EA TGN M2):

$$\text{IsokineticRatio}(\%) = \frac{\text{Velocity at the sampling nozzle}}{\text{Velocity of the stack gas}} \times 100$$

Estimating Measurement Uncertainty

Uncertainty estimates are calculated using the general rule of uncertainty propagation. Guidance is taken from publications including UKAS document M3003 and ISO 20988:2007.

Flow Calculations

Velocity:

From reference calculations (taken from ISO 10780):

$$\bar{v} = KC \sqrt{\frac{T_s \Delta p}{p_e M_s}}$$

\bar{v} = Average velocity (m/s)

C = velocity calculation constant = 129

T_s = Average stack temperature (K)

M_s = Molar mass of gas; assume 29 kg/kmol unless the molar mass is < 27 kg/kmol or > 31 g/kmol

K = Pitot calibration coefficient

p_e = Absolute gas pressure (kPa)

Δp = Average pitot tube pressure differential (kPa)

Volume flow rate

From reference calculations (taken from ISO 10780):

$$q_{va} = \bar{v}A$$

q_{va} = Average flow rate (m³/s)

\bar{v} = Average velocity (m/s)

A = Stack cross-sectional area (m²)

Volume flow rate corrected for moisture

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(100 - H_a)}{(100 - H_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

H_a = Moisture at actual conditions (%volume)

H_m = Reference moisture (%volume)

Volume flow rate corrected for temperature and pressure

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(T_m p_a)}{(T_a p_m)}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

T_a = Temperature at actual conditions (K)

T_m = Reference Temperature (K)

p_a = Absolute gas pressure at actual conditions (kPa)

p_m = Reference pressure (kPa)

Volume flow rate corrected for oxygen

From reference calculations (taken from BS ISO 9096):

$$q_m = q_{va} \frac{(20.9 - O_{2,ref})}{(20.9 - O_{2,m})}$$

q_m = Corrected volume flowrate (m³/s)

q_{va} = Volume flow rate at actual conditions (m³/s)

$O_{2,m}$ = Actual oxygen concentration (%)

$O_{2,ref}$ = Reference oxygen concentration (%)

Concentration Calculations

Concentration:

From reference calculations (taken from BS EN 13284-1):

$$c = \frac{m}{V}$$

c = Concentration
 m = Mass of substance
 V = Volume sampled

Mass Emission

$$\text{Mass emission} = c \times q_m$$

c = Concentration
 q = Volume flow rate

Concentration corrected for oxygen:

From reference calculations (taken from BS ISO 9096):

$$c_m = c_a \times \frac{20.9 - O_{2,ref}}{20.9 - O_{2,a}}$$

cm = Concentration at reference conditions
 ca = Actual concentration
 $O_{2, ref}$ = Reference oxygen (%)
 $O_{2, a}$ = Actual Oxygen (%)

Concentration corrected for moisture:

From reference calculations (taken from BS ISO 9096):

Convert wet gas to dry gas

$$c_{dry} = c_{wet} \times \frac{100}{100 - H_a}$$

Convert dry gas to wet gas

$$c_{wet} = c_{dry} \times \frac{100 - H_a}{100}$$

c_{wet} = Concentration wet gas
 c_{dry} = Concentration dry gas
 H_a = Water vapour content (%vol)

Conversion of parts per million (ppm) to mg/m³

From reference calculations (taken from EA TGN M2):

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

When Converting TOC

$$\text{Concentration}(mg / m^3) = \frac{\text{Concentration}(ppm) \times \text{molecular weight of carbon in span gas}(g)}{\text{molar volume}(l) \text{ at a given temperature}}$$

molar volume at 273K = 22.4 litres

Calculation of Uncertainty Estimates - Instrumental Monitoring Techniques

Model equation

$$C_{ppm} = C_{reading} + Corr_{fit} + Corr_{k_{0,dr}} + Corr_{s,dr} + Corr_{rep} + Corr_{adj} + \sum_{i=1}^p Corr_{inf} + Corr_{int}$$

Where:

C_{ppm}	=	concentration in ppm	$Corr_{rep}$	=	correction of repeatability of measurement
$C_{NO,reading}$	=	concentration given by analyser	$Corr_{adj}$	=	correction of adjustment
$Corr_{fit}$	=	correction of lack of fit	$Corr_{inf}$	=	correction of influence quantities
$Corr_{0,dr}$	=	correction of zero drift	$Corr_{int}$	=	correction of interferences
$Corr_{s,dr}$	=	correction of span drift			

Calculation of partial uncertainties

$$u(Corr_{fit}) = \frac{\left(\frac{X_{fit,max}}{100 \times range} \right)}{\sqrt{3}} \quad \text{Where:}$$

$X_{fit,max}$ is the maximum allowable deviation from linearity

Expressed as % of the range and calculated by applying a rectangular probability distribution

$$u(Corr_{0,dr}) = \frac{X_{0,dr}}{\sqrt{3}} \quad u(Corr_{s,dr}) = \frac{X_{s,dr}}{\sqrt{3}}$$

$$u(Corr_{rep}) = \max(S_{0,rep}; S_{s,rep}) = S_{rep}$$

Where:
 $S_{r,0}$ is the standard uncertainty at zero level
 $S_{r,s}$ is the standard uncertainty at span level

$$u(Corr_{adj}) = u(Corr_{loss}) + u(Corr_{cal})$$

Where:
 $u(Corr_{loss})$ is the uncertainty due to losses in sample line
 $u(Corr_{cal})$ is the uncertainty due to losses in sample line
 $C_{j,loss}$ is the concentration of sample loss at span level
 U_{cal} is the expanded uncertainty of the calibration gas

$$u(Corr_{loss}) = \frac{C_{j,loss}}{\sqrt{3}}$$

$$u(Corr_{cal}) = \frac{U_{cal}}{2}$$

$$u(Corr_{int}) = c_j \sqrt{\frac{(x_{j,max} - x_{j,adj})^2 + (x_{j,min} - x_{j,adj})^2 + (x_{j,max} - x_{j,adj})(x_{j,min} - x_{j,adj})}{3}}$$

Where:
 c_j is the sensitivity coefficient of the influence quantity
 $x_{j,min}$ is the minimum value of the influence quantity during monitoring
 $x_{j,max}$ is the maximum value of the influence quantity during monitoring
 $x_{j,adj}$ is the value of the influence quantity during adjustment

$$u(Corr_{int}) = \frac{c_j}{Int_{j,test}} \sqrt{\frac{Int_{j,max}^2 + Int_{j,min} \times Int_{j,max} + Int_{j,min}^2}{3}}$$

and

$$u(\Sigma Corr_{int}) = \max[S_{int,p}; S_{int,n}]$$

Where:
 c_j is the sensitivity coefficient of the interferent j
 $Int_{j,test}$ is the concentration of the interferent j used to determine c_j
 $Int_{j,min}$ is the minimum value of the interferent j quantity during monitoring
 $Int_{j,max}$ is the maximum value of the interferent j quantity during monitoring
 $Int_{j,adj}$ is the concentration of the interferent j in the cal gas used to adjust the analyser
 $S_{int,p}$ is the sum of interferences with positive impact
 $S_{int,n}$ is the sum of interferences with negative impact

Combined uncertainty

$$u(C_{ppm}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2}$$

Overall expanded uncertainty (k = 2) $U(C_m) = u(C_m) \times k$

Uncertainty of NOx measurements

$$u(C_{NOx,conv}) = \frac{C_{NOx} \times R \times \eta}{\sqrt{3}}$$

Where:
 C_{NOx} is the concentration of NOx measured by the analyser
 R is the ratio of NO:Nox in the stack gas
 η is the NOx converter efficiency

Combined uncertainty NOx measurements

$$u(C_{NOx,stack}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + u^2(Corr_{NOx,conv})}$$

Uncertainty of mass concentration at oxygen reference concentration

$$u(C_{O_2,ref}) = \sqrt{u^2(Corr_{fit}) + u^2(Corr_{0,dr}) + u^2(Corr_{s,dr}) + u^2(Corr_{rep}) + u^2(Corr_{s,yf}) + u^2(Corr_{a,press}) + u^2(Corr_{temp}) + u^2(Corr_{volt}) + u^2(Corr_{adj}) + S_{int}^2 + \left(\frac{u^2(O_{2,meas,dry})}{(21 - O_{2,meas,dry})^2} \right)}$$

Where:

$u(C_{O_2,ref})$	=	uncertainty associated with the mass concentration at O ₂ ref. concentration	in	mg/m ³
$C_{O_2,ref}$	=	mass concentration at O ₂ reference concentration	in	mg/m ³
$O_{2,meas}$	=	O ₂ measured concentration	in	% volume
$u((O_{2,meas})_{dry})$	=	uncertainty associated to the measured O ₂ concentration	in	% (relative to O _{2,meas})

APPENDIX 4

Uncertainty Estimate For The Measurement Of Total Organic Carbon BS EN12619:2013

Analysers Type/Model Sick Maihak
 Reference Oxygen % 0 (0 = No correction)

		Test 1	Test 2	Test 3
Limit value	mg/m ³	75	75	75
Limit value	ppm	46.7	46.7	46.7
Measured concentration	ppm	2.3	1.7	2.6
Measured concentration	mg/m ³	3.7	2.7	4.2
Concentration at O ₂ ref. concentration	mg/m ³	N/A	N/A	N/A

Calibration gas	ppm	78.8	78.8	78.8
Calibration gas	mg/m ³	126.6	126.6	126.6
Analyser range	ppm	9.3	9.3	9.3
Analyser range	mg/m ³	15.0	15.0	15.0

Correction of Lack of Fit				
Lack of fit	% range	2.0	2.0	2.0
	u(Corr _{lof})	0.11	0.11	0.11

Corrections of Zero and Span Drift (*All drift is calculated for ∴ the residual is assumed to be < 5% u(max))				
Zero Drift	% range	0.00	0.00	0.00
	u(Corr _{zdr})	0.00	0.00	0.00
Span Drift	% range	0.00	0.00	0.00
	u(Corr _{spd})	0.00	0.00	0.00

Correction of Repeatability of Measurement				
Repeatability SD at span level (Not reported)	% range	0.0	0.0	0.0
	u(Corr _{rpb})	0.00	0.00	0.00

Correction of adjustment				
Losses in the line	% range	0.18	0.18	0.18
	u(Corr _{loss})	0.00	0.00	0.00
Uncertainty of calibration gas	% range	2.0	2.0	2.0
	u(Corr _{cbl})	0.02	0.02	0.03

Correction of Influence of Interferents				
N ₂ O	% range			
	u(Corr _{N2O})	0.00	0.00	0.00
CO ₂	% range			
	u(Corr _{CO2})	0.00	0.00	0.00
CH ₄	% range			
	u(Corr _{CH4})	0.00	0.00	0.00
Total of interferent influences u(ΣCorr _{int}) = max[S _{int,p} · S _{int,n}]	% range	2.50	2.50	2.50
	u(ΣCorr _{int})	0.16	0.16	0.16

Correction of Influence Quantities				
Sensitivity to sample volume flow	% range	1.60	1.60	1.60
	u(Corr _{flow})	0.09	0.09	0.09
Sensitivity to atmospheric pressure (Not reported)	% range			
	u(Corr _{press})	0.00	0.00	0.00
Sensitivity to ambient temperature	% range	-2.40	-2.40	-2.40
	u(Corr _{temp})	-0.28	-0.28	-0.28
Sensitivity to electrical voltage (Not reported)	% range	0.50	0.50	0.50
	u(Corr _{volt})	0.10	0.10	0.10

Oxygen reference concentration				
Measured oxygen	%	#DIV/0!	#DIV/0!	#DIV/0!
Overall uncertainty of O ₂ measurement	U(O _{2,meas})	#REF!	#REF!	#REF!
	u(Corr _{O2})	N/A	N/A	N/A

Maximum standard uncertainty	u(Corr _{max})	0.11	0.11	0.11
5% of maximum standard uncertainty	u(Corr _{5%})	0.01	0.01	0.01

Interferent Concentration Variations	Minimum	Maximum	Value at cal	Performance	Units
CH ₄ range	0	10	0	50	mg/m ³
N ₂ O range	0	0	0	20	mg/m ³
CO ₂ range	8	12	0	15	mg/m ³
Oxygen effect variations	Minimum	Maximum	Value at cal	Performance	Units
Oxygen effect	0	20	0	2	mg/m ³

Influence Quantity Variations	Minimum	Maximum	Value at cal	Performance	Units
Sensitivity to sample volume flow	55	65	60	5	l/h
Sensitivity to atmospheric pressure	99	100	99	1	kPa
Sensitivity to ambient temperature	278	313	288	10	K
Sensitivity to electrical voltage	187	250	230	5	V

Measurement uncertainty				
Combined uncertainty	ppm	0.37	0.37	0.37
	mg/m ³	0.59	0.59	0.59
Combined uncertainty at oxygen reference	mg/m ³	0.59	0.59	0.59

Expanded uncertainty expressed with a level of confidence of 95%, k=2				
Overall uncertainty	ppm	0.7	0.7	0.7
Overall uncertainty	mg/m ³	1.2	1.2	1.2
Overall uncertainty relative to measured value	%	31.8	44.0	28.1
Overall uncertainty relative to range	%	7.8	7.8	7.8
Overall uncertainty relative to ELV	%	0.9	0.9	0.9

Expanded uncertainty at oxygen reference conditions expressed with a level of confidence of 95%, k=2				
Overall uncertainty	mg/m ³	N/A	N/A	N/A
Overall uncertainty relative to measured value	%	N/A	N/A	N/A
Overall uncertainty relative to range	%	N/A	N/A	N/A
Overall uncertainty relative to ELV	%	N/A	N/A	N/A

The uncertainty evaluation has been carried out in accordance with UKAS requirements.