

## Report for Periodic Monitoring of Emissions to Atmosphere

Part 1: **Executive Summary**

Permit Number: **N/A**

Operator: **Glynwed Pipe Systems Ltd**

Installation: **Cambridgeshire**

Emission Points: **Fluidised Bed Exhaust**

Monitoring Dates: **29<sup>th</sup> April 2014**



Contract Reference: FTBS 30301

Operator: Glynwed Pipe Systems Ltd

Address: St Peters Road  
Huntington  
Cambridgeshire  
PE29 7DA

Monitoring Organisation: RPS Consultants

Address: Noble House, Capital Drive, Linford  
Wood,  
Milton Keynes, MK14 6QP

Report Date: 2<sup>nd</sup> June 2014

Report Approved By: Ian Baggley

Position: Consultant

MCERTS Registration No.: MM 05 653

MCERTS Certification Level: 2

Technical Endorsements: TE1, TE2, TE3, TE4

Signature:

A handwritten signature in blue ink, appearing to read 'I Baggley', written over a light blue grid background.

RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

## **CONTENTS**

### **Part 1: Executive Summary**

<b>Section 1 – Monitoring Objectives.....</b>	<b>3</b>
<b>Section 2 – Monitoring Results.....</b>	<b>4</b>
<b>Section 3 – Operating Information.....</b>	<b>5</b>
<b>Section 4 – Monitoring Deviations.....</b>	<b>6</b>

### **Part 2: Supporting Information**

#### **Appendix 1 – Staff & Methodology Details**

#### **Appendix 2 - Fluidised Bed Exhaust Sampling, Analysis & Uncertainty Data**

## Monitoring Objectives

At the request of Eric Cross of Glynwed Pipe Systems Ltd, RPS Consultants conducted stack emission monitoring at the Cambridgeshire site in April 2014.

The monitoring programme at this installation was carried out to provide data on emissions to atmosphere for comparison with the limits specified in the air emission criteria for this site.

The following tables detail the parameters requested for monitoring at each emission point and the actual monitoring conducted.

**Table 1.1**

Parameters Requested to be Monitored	Emission Point
	Fluidised Bed Exhaust
Total Particulate Matter	✓
Volatile Organic Compounds	✓
Specific Requirements	Normal

Notes:

✓ Represents pollutants sampled

## Monitoring Results

**Table 2.1 Monitoring results for emission point Fluidised Bed Exhaust, Carried out on 29<sup>th</sup> April 2014**

Substance Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (Expressed expanded k=2)	Reference Conditions 273K, 101.3kPa	Sampling Date	Sampling Times	Monitoring Reference Method	Accreditation Status	Operating Status
Total Particulate Matter	20	< 0.44	mg/m <sup>3</sup>	+/- 0.23	273K, 101.3kPa, Wet	29/04/14	12:43 – 13:43	BS EN 13284-1:2002	MCERTS	Normal
Volatile Organic Compounds (as Carbon)	20	< 1.0	mg/m <sup>3</sup>	+/- 0.013	273K, 101.3kPa, Wet	29/04/14	12:43 – 13:43	BS EN 13526	MCERTS	Normal

Note : The Total Particulate Matter result is reported at the limit of detection.

## Operating Information

**Table 3.1 Operating conditions during the monitoring of emission point Fluidised Bed Exhaust carried out on 29<sup>th</sup> April 2014**

Parameter	Result
Sample Date	29/04/14
Process Type	Batch
Process Duration	4 Hour
If 'Batch', was monitoring carried out over the whole batch?	No – 1hr sample required
Abatement/Operational?	Afterburner & Candle Filters

Comparison of Operator CEM and Periodic Monitoring Results		
Substance	CEMs Results (mg/m <sup>3</sup> )	Periodic Monitoring Results (mg/m <sup>3</sup> )
No CEMS Installed/Data Available		

## Monitoring Deviations

**Table 4.1 Monitoring Deviations for Emission Point Fluidised Bed Exhaust**

Pollutant	Substance Deviations	Monitoring Deviations	Other Relevant Issues
Total Particulate Matter & Volatile Organic Compounds	None	None	None

## Report for Periodic Monitoring of Emissions to Atmosphere

Part 2: **Supporting Information**

Permit Number: **N/A**

Operator: **Glynwed Pipe Systems Ltd**

Installation: **Cambridgeshire**

Emission Points: **Fluidised Bed Exhaust**

Monitoring Dates: **29<sup>th</sup> April 2014**



Contract Reference: FTBS 30301

Operator: Glynwed Pipe Systems Ltd

Address: St Peters Road  
Huntington  
Cambridgeshire  
PE29 7DA

Monitoring Organisation: RPS Consultants

Address: Noble House, Capital Drive, Linford  
Wood,  
Milton Keynes, MK14 6QP

Report Date: 2<sup>nd</sup> June 2014

Report Approved By: Ian Baggley

Position: Consultant

MCERTS Registration No.: MM 05 653

MCERTS Certification Level: 2

Technical Endorsements: TE1, TE2, TE3, TE4

Signature:

A handwritten signature in blue ink, appearing to read 'I Baggley', written over a light blue grid background.

RPS Consultants has produced this report within the term of the contract with the client and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above. This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

## **CONTENTS**

### **Part 1: Executive Summary**

<b>Section 1 – Monitoring Objectives.....</b>	<b>3</b>
<b>Section 2 – Monitoring Results.....</b>	<b>4</b>
<b>Section 3 – Operating Information.....</b>	<b>5</b>
<b>Section 4 – Monitoring Deviations.....</b>	<b>6</b>

### **Part 2: Supporting Information**

#### **Appendix 1 – Staff & Methodology Details**

#### **Appendix 2 - Fluidised Bed Exhaust Sampling, Analysis & Uncertainty Data**



## **APPENDIX 1: General Information**

## Monitoring Organisation Staff Details

**Table 5.1 Sampling Personnel**

Sampling Personnel	Position	MCERTS Level	Technical Endorsements & Expiries	MCERTS Registration Number
Carl Redgrove	Senior Consultant	Level 2	01/10/14 09/03/15 11/03/16 11/03/16	MM 03 173
Alex Shepherd	Trainee	Trainee	-	MM 14 1270
Nick Mills	Trainee	Trainee	-	MM 14 TBC

**Table 5.2 Report Author**

Report Author	Position	MCERTS Level	Technical Endorsements & Expiries	MCERTS Registration Number
Carl Redgrove	Senior Consultant	Level 2	TE1 Oct 14 TE2 Mar 15 TE3 Mar 16 TE4 Mar 16	MM 03 173

**Table 5.3 Report Reviewer**

Report Reviewer	Position	MCERTS Level	Technical Endorsements & Expiries	MCERTS Registration Number
Ian Baggley	Consulatnt	Level 2	TE1 Jun 18 TE2 Mar 15 TE3 Dec 17 TE4 Mar 17	MM 05 653

## Monitoring Organisation Method Details

**Table 6.1 Monitoring Methods**


Emission Parameter	Standard Method	Monitoring Procedure No.	Monitoring Accreditation	Analysis	Analysis Procedure No.	Analytical Laboratory	Analysis Accreditation
Practical Considerations Prior to Monitoring	N/A	RPSCE/1/1	UKAS	N/A	N/A	N/A	N/A
Gas Flows	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Gas Temperatures	BS-EN 13284-1:2001	RPSCE/1/2	MCERTS	N/A	N/A	N/A	N/A
Low Concentration Total Particulate Matter	BS EN 13284-1:2002	RPSCE/1/7c	MCERTS	Gravimetric	D9	RPS Laboratories	UKAS
TOCs at high concentrations	BS EN 13526	RPSCE/1/4c	MCERTS	Flame Ionisation Detector	N/A	N/A	N/A

**Table 7.1 – Checklist Used**

Equipment Checklist Used	File Location Address
FTBS 30301 Checklist	FTBS 30301 Electronic & Work File

**APPENDIX 2:**  
**Fluidised Bed Exhaust Sampling, Analysis & Uncertainty Data**

## Sample Point Diagram



Company Name: Glynwed Pipe Systems Ltd.  
Site Name: Huntingdon  
Sampling Point Ref: Fluidised Bed Exhaust  
Project Reference: FTBS 30301

Date: 29/04/14

Run: TPM

Project Reference:FTBS 30301				Stack Width (m)		0.58	
				Stack Depth (m)		0.36	
Stack Static press.mm H <sub>2</sub> O:				20	Stack Area (m2):		0.204
Traverse Point No.	Port A			Port B			
	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	Δ p, mm H <sub>2</sub> O	Root Δ p	Stack Temp °C	
1	30	5.477	94	19	4.359	96	
2	22	4.690	94	15	3.873	96	
3							
4							
5							
6							
7							
8							
9							
10							
Minimum	22.0	4.690	94	15.0	3.873	96	
Maximum	30.0	5.477	94	19.0	4.359	96	
Mean	26.0	5.084	94.0	17.0	4.116	96.0	
Sum	52	10.168	188	34	8.232	192	
Total Sum							

Max. pitot press. = 30.0  
Min. pitot press. = 15.0  
Ratio Max:Min = 2.0 :1

**Gas Data**

Oxygen %	21.0
CO <sub>2</sub> %	0.04
CO %	

**Oxygen Correction**

Required Correction Value	0
Actual Oxygen Factor	1.000
Enter 0 if correction is not required	

BS EN 13284-1 & M1 Sample Point Requirements	Requirement Met?
Duct gas Flow: angle with regard to duct access <15°?	Y
Duct Gas Flow Negative Velocity: Not Permitted	Y
Duct Gas Flow: Ratio of max to min velocity <3:1?	Y
Working Area > 5m <sup>2</sup> ?	N
Handrails with removable chains / self closing gates across the top of the ladder?	Y
Handrails (approx 0.5 and 1.0 m high) and vertical baseboards (approx 0.25m high)?	Y
Scaffold Built to 'Heavy Duty' Scafftag Rating or at least 2.5kN/m <sup>2</sup> loading	N/A
Handrails not restricting access to ports?	Y
Room opposite sampling port equal or greater than the length of the sampling probe plus 1 metre?	N
Sufficient Power (Waterproof 110V BS4343 Standard) close or on the platform?	Y

Company Name: Glynwed Pipe Systems L In-stack Filter?  Bar. Press.mm Hg  K Factor  Ambient Temp.   
 Site Name: Huntingdon Outstack Filter?  Cp  Dn used  Start Time  Leak Rate (fin / %)   
 Project Reference: FTBS 30301 Date: 29/04/14 Operators  Bws%  Nozzle No.  Stop Time  Leak Rate (start / %)   
 Run: TPM Box/Probe setting   
 Sampling Point Ref: Fluidised Bed Exhaust Meter Correction Yd

Sample Filter Weights

	Sample ID	Laboratory	Increase, mg
Filter	109076	RPS	0.04
Probe Washings	30003797	RPS	0.5

Sample Filter Blank Weighings

	Sample ID	Laboratory	Increase, mg
Filter	109077	RPS	0.04
Probe Wash	30003796	RPS	0.5

Impinger Weights

Weights	Initial	Final	Increase, g
Impinger 1	724.5	724.5	0.0
Impinger 2	548.4	548.4	0.0
Impinger 3			0.0
Impinger 4			0.0
Impinger 5			0.0
Silica Gel	907.1	928	20.9
		Total	20.9

Sample Point	Clock Time min	Pitot Δ p, mm H <sub>2</sub> O	Stack Temp, °C	Orifice Δ H, mm H <sub>2</sub> O		Gas Meter Reading  m <sup>3</sup>	Temp at Gas Meter Outlet °C	Condenser Temp, °C	Filter Box Temp °C	Probe Temp °C	Pump Vacuum Inches Hg	Impinger Stem Temp. °C	Root Δ p,
				Desired	Actual								
	0	30	98	69.3	69.3	43985.5	21				-6	20	5.477
	5	30	99	69.3	69.3		22				-6	21	5.477
	10	29	100	66.99	66.99		22				-6	22	5.385
	15	21.5	100	49.665	49.665		24				-6	24	4.637
	20	21	101	48.51	48.51		23				-5	26	4.583
	25	20	101	46.2	46.2		24				-5	26	4.472
Endpoint	30												
	0	19	100	43.89	43.89	45430	24				-5	27	4.359
	5	19	100	43.89	43.89		25				-5	27	4.359
	10	18.2	100	42.042	42.042		26				-5	27	4.266
	15	17.6	100	40.656	40.656		27				-5	28	4.195
	20	11	93	25.41	25.41		28				-4	28	3.317
	25	11	92	25.41	25.41		28				-4	28	3.317
Endpoint	30												
	60.00	20.608	98.7	47.6	47.6	1.445	24.5	#DIV/0!	#DIV/0!	#DIV/0!	-5.2	25.3	4.5

Company Name: Glynwed Pipe Systems Ltd.  
Site Name: Huntingdon  
Project Reference: FTBS 30301

Date: 29/04/14

Sampling Point Ref: Fluidised Bed Exhaust	Run: TPM
Meter Volume Sampled, acm	1.445
Sample Run Start Time	12:43
Sample Run End Time	13:43
Total Actual Sampling Time, min	60.0
Barometric Pressure, mm Hg	747.00
Stack Pressure, mm Hg	748.47
Average Stack Temp, °C	98.7
Meter Volume at STP, scm	1.238
Stack Moisture Content, %	2.1
Average Stack Velocity, m/sec	17.335
Nozzle Diameter, mm	5.97
<b>% Isokinetic Variation</b>	<b>99.9</b>
Total Mass of Particulate, mg	0.5
Percentage of Total Particulate Collected on Filter	7.4
<b>Stack Particulate Concentration, mg/m<sup>3</sup></b>	<b>0.436</b>
Particulate Mass rate, kg/hour	0.004
Emission Limit value	<b>20</b>

Sample Train Blank Results	
Sample Blank Particulate Concentration, mg/m <sup>3</sup>	0.43
Total Weight Gain, mg (Sample Train Blank)	0.54
Blank Result Less than 10% of Limit Value	Y



### Uncertainty Calculation for Total Particulate Matter to BS EN 13284-1

Determined Concentration	0.436	mg/m3 (at Reference Cond)
--------------------------	-------	---------------------------

#### Measured Values

Sampled Volume	1.4445	m <sup>3</sup>
Sampled gas Temperature	297.5	K
Sampled gas Pressure	99.79	kPa
Sampled gas Humidity	0	% by volume
Oxygen content	21	% by volume
Mass	0.54	mg

Leak	0.00	%
Uncollected Mass	0	mg

#### Standard Uncertainties for Measured Values

Sampled Volume	0.001	m3
Sampled gas Temperature	2	K
Sampled gas Pressure	1	kPa
Sampled gas Humidity	1	% by volume
Oxygen content	0.1	% by volume
Mass	0.14152385	mg

Uncertainty Calculation for Volume Correction				Uncertainty Calculation for Oxygen Correction			
Volume Correction Factor	0.904			Oxygen Correction Factor	1.0000		
	Sensitivity Coefficient		Uncertainty, Uv		Sensitivity Coefficient		Uncertainty, Uo
Sampled gas Temperature	0.0030		0.0061	Oxygen Measurement	N/A		N/A
Sampled gas Pressure	0.0091		0.0091				
Sampled gas Humidity	0.0090		0.0090				
	Sqrt (Uv)^2		0.0142				
	Total Uv		0.020			Total Uo	N/A

#### Uncertainty Contributions (Itemised)

	Value		Sensitivity coefficient	Uncertainty Contribution	
				Concentration	%
Volume Correction	1.238	m3	0.35	0.01 mg.m <sup>-3</sup>	1.66 %
Mass (weighing)	0.54	mg	0.81	0.11 mg.m <sup>-3</sup>	26.21 %
Oxygen Correction	N/A		0.00	0.00 mg.m <sup>-3</sup>	0.00 %
System Leak	0.00	mg.m <sup>-3</sup>	1.00	0.00 mg.m <sup>-3</sup>	0.00 %
Uncollected Mass	0.00	mg	0.81	0.00 mg.m <sup>-3</sup>	0.00 %
Total Uncertainty				0.11 mg.m <sup>-3</sup>	

#### Uncertainty Result (Uncertainty has been expanded with a coveragefactor of 2 (K=2))

Expanded Uncertainty =	0.2292	mg.m <sup>-3</sup>
=>	52.52	% of Result
=>	1.15	% of ELV

Company Name: Glynwed Pipe Systems  
Site Ref: Huntingdon  
Stack Ref: Fluidised Bed Exhaust

Date: 29/04/14  
Run: VOC

	VOC (as Carbon) ppm	VOC (as Carbon) mg/m3	VOC (as Carbon) kg/h	VOC (as Toluene) mg/m3	VOC (as Toluene) kg/h
Average	0.2727	0.4383	0.0043	0.4801	0.0047
Max	1.6000	2.5714	0.0251	2.8163	0.0275
Min	0.0000	0.0000	0.0000	0.0000	0.0000
Emission Limit		20			
Moisture, %	#DIV/0!				
Oxygen Reference, %	0.0				

Stack Gas Volume Flow Rate, m3/s (scms WET) O2 Corrected	2.713029114
--	-------------

Calibrations	ppm
Analyser - Start Zero	0.00
Analyser - Start Span	81.40
Analyser - Zero Check	0.00
System - Zero Check	0.20
System - Span Check	81.30
System - End Zero Check	0.30
System - End Span Check	81.20
Span Value	81.40
Analyser Range (0 - X)	0-100

Equipment ID	
FID	1575

## ISO 14956 Calculation Sheet - TOC (BS EN 13526)

Studied Concentration (mg/m <sup>3</sup> as C)	0.438311688
Range of Instrument (mg/m <sup>3</sup> as C)	161

Sampling Parameters to be met	Requirement Met?
Response Time < 60s	Yes
Operating temperature (5 - 45°C)	Yes
Atmospheric pressure (700 - 1240 mbar)	Yes
Relative Humidity (10 - 90%, non condensing)	Yes
Altitude (< 2000 m)	Yes
Zero Drift 2% of FS	Yes
Span Drift 4% of FS	Yes

Selected Performance Characteristic	Value of Performance Characteristic			Operating Conditions compared to calibration condition		
	%	Numerical	Units	Required	Variable due to sampling conditions	Units
Deviation from Linearity	1	0.01	% FS	0.01	1	% FS
Repeatability Standard Deviation	1	0.01	% FS	0.01	1	% FS
8 Hour Drift	2	0.02	%	0.02	1	%
Atmospheric Pressure Dependence	0.1	0.001	% kPa	0.001	1	% kPa
Temperature Dependence	0.2	0.002	%K	0.002	1	%K
Sum Interference	2	0.02	%	0.02	2	%
Voltage Supply	0.1	0.001	%V	0.001	1	%V
Uncertainty of Calibration Gas	2	0.02	%	0.02	1	%
Moisture Effect	1	0.01	%Vol H2O Error	0.01	2	%Vol H2O Error
Loss in sample line (Leaks)	2	0.02	%	0.02	2	%

Measurement Performance related to stationary conditions								
Value of Uncertainty Quantity								
Performance Characteristic	Uncertainty Quantity		At Calibration Conditions			At Sampling Conditions		
			Units	U	U <sup>2</sup>	Units	U	U <sup>2</sup>
Deviation from Linearity	U <sub>Fit</sub>		% FS	1.61	2.592	% FS	0.0043831	0.000
Repeatability Standard Deviation	U <sub>R</sub>		% FS	0.003	0.000	% FS	0.003	0.000
8 Hour Drift	U <sub>drift</sub>		%	0.0051	0.000	%	0.005	0.000
Atmospheric Pressure Dependence	U <sub>Atmos</sub>		% / kPa	0.000	0.000	% / kPa	0.000	0.000
Temperature Dependence	U <sub>Temp</sub>		% / K	0.001	0.000	% / K	0.001	0.000
Sum Interference	U <sub>Interference</sub>		%	0.005	0.000	%	0.000	0.000
Voltage Supply	U <sub>Voltage</sub>		% / V	0.000	0.000	% / V	0.000	0.000
Uncertainty of Calibration Gas	U <sub>Calibration gas</sub>		%	0.005	0.000	%	0.005	0.000
Loss in sample line (Leaks)	U <sub>Losses, leak</sub>		%	0.005	0.000	%	0.010	0.000
Sum				1.634	2.592	Sum	0.028	0.000


Measurement Uncertainty at	0.438311688	mg/m <sup>3</sup> C			
U <sub>tot</sub>	0.013	mg/m <sup>3</sup> C			
U <sub>tot</sub> <sup>%</sup>	3.059	%	U <sub>limit</sub>	30	%
Pass	Yes				

## BS EN 13526:2001 Performance Requirements

Performance Characteristic	Minimum Performance Requirement
Detection Limit	5% of the emission limit value
Response Time	less than 1 minute
Linearity Deviation	permissible deviation 5% of emission limit
Response Factors	Permissible range
Methane	0.9 to 1.2
Aliphatic Hydrocarbons	0.9 to 1.1
Aromatic Hydrocarbons	0.8 to 1.1
Aliphatic alcohols	0.7 to 1.0
Esters	0.7 to 1.0
Ketones	0.7 to 1.0
Organic Acids	0.5 to 1.0
Oxygen Effect	permissible deviation 5% of emission limit

For more details on the above figures see BS EN 13526:2001.

**TOC Emissions Profile from the Fluidised Bed Exhaust on 29/4/14 at Glynwed Pipe Systems Ltd,  
Huntingdon.**



### **Appendix 3 – Certificates of Analysis**



Test Certificate

Date 09/05/2014

Client	RPS Milton Keynes HSED Noble House Capital Drive Linford Wood Milton Keynes MK14 6QP		Order No.	FTBS 30301
			Certificate No.	WK14-2773
			Issue No.	1
Contact	Carl Redgrove		Date Received	01/05/2014
Description	2 filters & 2 washes for TPM		Technique	Gravimetric Stack
Sample No.	789000	109076	Method	
Total particulate matter		<0.04 mg	D9(U)	
Sample No.	789001	30003797	Method	
Total particulate matter		<0.5 mg	D9(U)	
Sample No.	789002	109077	Method	
Total particulate matter		<0.04 mg	D9(U)	
Sample No.	789003	30003796	Method	
Total particulate matter		<0.5 mg	D9(U)	

Page 1 of 2

RPS Laboratories Ltd, Unit 12, Waters Edge Business Park, Modwen Road, Salford, M6 3EZ  
Tel: (0161) 872 2443 Fax: (0161) 877 3969



Test Certificate

Date 09/05/2014

Client	RPS Milton Keynes HSED	Certificate No.	WK14-2773
		Issue No.	1

Tested By Kirstie Davenport Date 08/05/2014

Approved By  Date 08/05/2014

Joanne Dewhurst  
Laboratory Manager

For and on authority of RPS Laboratories Ltd.

Method Symbols (U) Analysis is UKAS Accredited  
(N) Analysis is not UKAS Accredited

Concentration values (mg/m<sup>3</sup> and ppm) are calculated on the basis of information provided by the customer.  
Results stated as ml are referring to the sample volume.

RPS Laboratories terms and conditions apply - a copy is available on request.

Analysis carried out on samples 'as received'

This document may not be reproduced other than in full, except with the written approval of the issuing laboratory.

Page 2 of 2

RPS Laboratories Ltd, Unit 12, Waters Edge Business Park, Modwen Road, Salford, M6 3EZ  
Tel: (0161) 872 2443 Fax: (0161) 877 3969