

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

APPENDIX 1

Premise Peterborough Sewer Station Person Seen Ms Stephanie Wilson
Address Hadden Peterborough PE7 3UQ

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

Inspection conducted by H Shepherd Cambridgehire Trading Standards on behalf of Hinchingdon District Council.

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N _____ Satisfactory Y/N _____

Notes:
No incidents

d) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES (Annual)

Inspected ☒ Y/N _____ Satisfactory ☒ Y/N _____

Notes:
Cert states date of next test 05/12/09 -> EXPIRED
VR tested 28/07/11 certificate seen brought into compliance.

b) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N _____ Satisfactory Y/N _____

Notes:
No incidents

e) STAFF COMPETENCE & TRAINING

No of Staff No Questioned

Inspected Y/N _____ Satisfactory Y/N _____

Notes:
12 staff on site not all competent - training records to be updated.

c) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N _____ Satisfactory Y/N _____

Notes: Technical advice received dated 08/08/11 -> vents have been labelled
Vents 6, 7, 8 to be labelled

Does the site have stage II vapour recovery? ☒ Y/N _____

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory ☒ Y/N _____

Notes:

Are procedures in place adequate in the event of any leaks or spillages? ☒ Y/N _____

Notes:

Inspector H.R. Shepherd Date 7/7/11

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.