

Environmental Protection Report – Vapour Recovery

Premises Tesco Almonds Ripon Person seen C HORSTED

Address _____

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection your attention is drawn to the following matters:

Vapour recovery inspection conducted on behalf of the
District Council

a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK

Inspected Y/N

Satisfactory Y/N

Notes

None

b) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES

Inspected Y/N

Satisfactory Y/N

Notes

7th May 2020 (Stage I)
18th Dec 122 → for Stage II

c) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)

Inspected Y/N

Satisfactory Y/N

Notes

None

d) STAFF COMPETENCE & TRAINING

No of Staff ☐

No Questioned ☐

1

Inspected Y/N

Satisfactory Y/N

Notes

DCD Box required but
Training records in order

e) VAPOUR RECOVERY CONNECTIONS & SIGNS

Inspected Y/N

Satisfactory Y/N

Notes

Tank Tops not lifted
high level table damaged
requirements

Does the site have stage II vapour recovery? Y/N

Notes

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes

All dooratches inspected
in order

Are procedures in place adequate in the event of any leaks or spillages? Y/N

Notes

As per R.A.

Signed [Signature]

Tel/Email: 211819

Received by _____

Date/Time: _____

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.