

**ENVIRONMENTAL PROTECTION  
REPORT - VAPOUR RECOVERY**

Premises Tesco Pet Person Seen DNI  
Address Emford Rd, Lymington

**OBSERVATIONS, ADVICE AND RECOMMENDATIONS:**

As a result of the inspection of your premises your attention is drawn to the following matters:

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS  
AND ASSOCIATED LOG BOOK**

Inspected Y/~~N~~ Satisfactory Y/~~N~~

Notes:

Register in Power.

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF  
VALVES**

Inspected Y/~~N~~ Satisfactory Y/~~N~~

Notes:

Stage 1-2  
November 2017.

**c) LOG BOOK DETAILING MAINTENANCE,  
EXAMINATION & TESTING, INVENTORY  
CHECKING, INSTALLATION & REPAIR WORK  
(SITE REGISTER)**

Inspected Y/~~N~~ Satisfactory Y/~~N~~

Notes:

Site Register

**d) STAFF COMPETENCE & TRAINING**

No of Staff 13 No Questioned 1

Inspected Y/~~N~~ Satisfactory Y/~~N~~

Notes:

Silver Rollers Training in  
Place and to date.

**e) VAPOUR RECOVERY CONNECTIONS &  
SIGNS**

Inspected Y/~~N~~ Satisfactory Y/~~N~~

Notes:

All Steels  
Exposed but Legible.  
Added

Does the site have stage II vapour recovery? Y/~~N~~

Notes:

**f) SITE MANAGEMENT & OTHER COMMENTS**

Satisfactory Y/~~N~~

Notes:

All Present and Correct.

Are procedures in place adequate in the event of any leaks  
or spillages? Y/~~N~~

Notes:

Signed [Signature]

Tel /Email [Signature]

Received by [Signature]

Date/Time 22/1/2018

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.