

**ENVIRONMENTAL PROTECTION
REPORT - VAPOUR RECOVERY**

Premises Steel Kumblyden Person Seen Prater
Address _____

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

conducted on behalf of District Council

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes:

No incidents

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes:

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N Satisfactory Y/N

Notes:

No incidents

d) STAFF COMPETENCE & TRAINING

No of Staff No Questioned

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes:

Staff training being updated

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected ☒ Y/N Satisfactory ☒ Y/N

Notes:

Does the site have stage II vapour recovery? ☒ Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Site defect report 25/4/18 seen
VR Pipe brackets not supporting Pipe
- has this been addressed? - yes.

Are procedures in place adequate in the event of any leaks
or spillages? Y/N

Notes:

Signed _____

Tel /Email 1/1/2018 12.11

Received by _____

Date/Time 01/05/2018 1628

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.