

**ENVIRONMENTAL PROTECTION  
REPORT – VAPOUR RECOVERY**

Premises Texaco service st Person Seen Mary Ward  
 Address St Marys Road Ramsey

**OBSERVATIONS, ADVICE AND RECOMMENDATIONS:**  
 As a result of the inspection of your premises your attention is drawn to the following matters:  
Inspection conducted by H. Sheppard Trading Standards  
 officer on behalf of Fenland District Council

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS AND ASSOCIATED LOG BOOK**

Inspected  Y/N Satisfactory  Y/N

Notes:  
No incidents

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF VALVES**

Inspected  Y/N Satisfactory  Y/N

Notes:  
July 2012

**c) LOG BOOK DETAILING MAINTENANCE, EXAMINATION & TESTING, INVENTORY CHECKING, INSTALLATION & REPAIR WORK (SITE REGISTER)**

Inspected  Y/N Satisfactory  Y/N

Notes:  
No checklist → all faults  
 No incidents  
 recorded in generic log book

**d) STAFF COMPETENCE & TRAINING**

No of Staff  No Questioned

Inspected  Y/N Satisfactory  Y/N

Notes:

**e) VAPOUR RECOVERY CONNECTIONS & SIGNS**

Inspected  Y/N Satisfactory  Y/N

Notes:

Does the site have stage II vapour recovery?  Y/N

Notes:

**f) SITE MANAGEMENT & OTHER COMMENTS**

Satisfactory  Y/N

Notes:

Are procedures in place adequate in the event of any leaks or spillages?  Y/N

Notes:  
KA

Signed [Signature] Tel /Email 01954 234620  
 Received by [Signature] Date/Time 2/10/2012

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.