

12 9 14 15

**ENVIRONMENTAL PROTECTION  
REPORT - VAPOUR RECOVERY**

Premises PACE REDWINGS

Person Seen Mr A Rasouli

Address SAUTRY SERVICE STATION

**OBSERVATIONS, ADVICE AND RECOMMENDATIONS:**

As a result of the inspection of your premises your attention is drawn to the following matters:

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS  
AND ASSOCIATED LOG BOOK**

Inspected Y/N Satisfactory Y/N

Notes: ADVICE GIVEN  
RE SITE INFORMATION

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF  
VALVES**

Inspected Y/N Satisfactory Y/N <sup>7</sup>

Notes: CONTACT WITH HSE APRIL  
RE ISSUE OF CERT TO  
BE CHECKED

**c) LOG BOOK DETAILING MAINTENANCE,  
EXAMINATION & TESTING, INVENTORY  
CHECKING, INSTALLATION & REPAIR WORK  
(SITE REGISTER)**

Inspected Y/N Satisfactory Y/N

Notes: RECORDS NOT ON  
SITE, ADVISED  
ACCORDINGLY

**d) STAFF COMPETENCE & TRAINING**

No of Staff 1 No Questioned 1

Inspected Y/N Satisfactory Y/N <sup>7</sup>

Notes: BEING RUN BY OWNER  
NO OTHER STAFF AT THIS  
TIME

**e) VAPOUR RECOVERY CONNECTIONS &  
SIGNS**

Inspected Y/N Satisfactory Y/N

Notes: SIGN SLIGHTLY FADED

**f) SITE MANAGEMENT & OTHER COMMENTS**

Satisfactory Y/N <sup>7</sup>

Notes:

Does the site have stage II vapour recovery? Y/N

Notes:

Are procedures in place adequate in the event of any leaks  
or spillages? Y/N

Notes: NEW SITE SINGLE OWNER  
SLOW TRADE, MAINTENANCE ISSUES

Signed [Signature]

Tel /Email John.goodwin@cambridgeshire.gov.uk

Received by [Signature]

Date/Time 13.30 9/7/15

This report only covers the areas inspected at the time of the inspection. It does not indicate compliance with any legislation.