

**ENVIRONMENTAL PROTECTION
REPORT – VAPOUR RECOVERY**

Premises SHELL FENSTANTON

Person Seen WAYNE GIBBIE

Address CAMBRIDGE RD, FENSTANTON

OBSERVATIONS, ADVICE AND RECOMMENDATIONS:

As a result of the inspection of your premises your attention is drawn to the following matters:

**a) INCIDENTS OF VAPOUR LEAKS & LOCKS
AND ASSOCIATED LOG BOOK**

Inspected Y/N

Satisfactory Y/N

Notes:

SITE REGISTER,
ANY ISSUES WOULD BE
REPORTED, NO ISSUES
RECORDED

**b) TESTING CERTIFICATE FOR PRESSURE RELIEF
VALVES**

Inspected Y/N

Satisfactory Y/N

Notes:

TESTED 18/5/15
CERT N° 150818 UK RW

**c) LOG BOOK DETAILING MAINTENANCE,
EXAMINATION & TESTING, INVENTORY
CHECKING, INSTALLATION & REPAIR WORK
(SITE REGISTER)**

Inspected Y/N

Satisfactory Y/N

Notes:

RECORDS REQUIRE
TIDYING & UPDATING

d) STAFF COMPETENCE & TRAINING

No of Staff

9

No Questioned

1

Inspected Y/N

Satisfactory Y/N

Notes:

SHELL E-LEARNING PORTAL

**e) VAPOUR RECOVERY CONNECTIONS &
SIGNS**

Inspected Y/N

Satisfactory Y/N

Notes:

TOP PART OF SIGN
VERY FADED

Does the site have stage II vapour recovery? Y/N

Notes:

f) SITE MANAGEMENT & OTHER COMMENTS

Satisfactory Y/N

Notes:

Are procedures in place adequate in the event of any leaks
or spillages? Y/N

Notes:

SHELL E-LEARNING
TRAINING

Signed [Signature]

Tel /Email 01954 284 641

Received by [Signature]

Date/Time 8/9/15